

Address all relevant correspondence to:

Ausgrid
Design Hunter
PO Box 196
MUSWELLBROOK NSW 2333
AUSTRALIA

Telephone: 02 6542 9091

Facsimile: 02 6542 9037

Email: Cops_Upper_Hunter@ausgrid.com.au



570 George Street
Sydney NSW 2000
All mail to GPO Box 4009
Sydney NSW 2001
T +61 2 131 525
F +61 2 9269 2830
www.ausgrid.com.au

14 January 2020

Vernon Trust
Attn: Andrew King
PO Box 420
TERRY HILLS NSW 2084

Email: kevin.heydt@renewablemanagement.com.au

Notification No: 1900097343

Reference No: DA 102/2019

Dear Andrew,

Thank you for your enquiry dated 19/11/2019. Currently, Ausgrid has 11kV overhead powerlines that traverse Lot 12 DP 1042612, 1333 Merriwa Road, Sandy Hollow.

Ausgrid has no objection to the proposal, however, provides the following -

- 1) Heavy vehicle access to all pole locations must be maintained.
- 2) No structures are to be constructed within Ausgrid's easement.
- 3) No structures are to be constructed under or near Ausgrid poles and overhead/underground powerlines that are covered under Section 53 of the Electricity Supply Act 1995 No 94 in accordance with Ausgrid's usual easement widths.
- 4) Existing ground levels under overhead powerlines are to be maintained.
- 5) A Connection Application should be submitted to Ausgrid for assessment prior to the commencement of construction.

Regards,

A handwritten signature in blue ink, appearing to read "Dannielle", followed by a stylized flourish.

Dannielle Constable-Howe
Connected Customers
Design Hunter – Technical Operations