



TELEPHONE: (02) 4399 8103  
EMAIL: mholmes@ausgrid.com.au  
REFERENCE: TRIM 2017/11/346

ATTN: Salli Pendergast  
Development Assessment Planner  
PO Box 20  
Wyong NSW 2259

24-28 Campbell St  
Sydney NSW 2000  
All mail to  
GPO Box 4009  
Sydney NSW 2001  
T +61 2 131 525  
ausgrid.com.au

**Re: DA/2317/2023 - 3 Warren Rd Warnervale - Asphalt Batching Plant & Waste or Resources Management Facility.**

I refer to Central Coast Council development application DA/2317/2023.

This letter is Ausgrid's response under clause 45(2) of the State Environmental planning Policy (Infrastructure) 2007.

The assessment and evaluation of environmental impacts for a new development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the Environmental Planning and Assessment Act 1979. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

**With Regard to: Asphalt Batching Plant & Waste or Resources Management Facility at 3 Warren Rd Warnervale**

- Appendix C - Concept Designs\_V1\_PAN-391916
- Enviro Impact Statement Warnervale EIS 20231211.reduced\_AI-1135630

Ausgrid consents to the above mentioned development subject to the following conditions:-

**Method of Electricity Connection**

The method of connection will be in line with Ausgrid's Electrical Standard (ES)1 – 'Premise Connection Requirements.

**Supply of Electricity**

It is recommended for the nominated electrical consultant/contractor to provide a preliminary enquiry to Ausgrid to obtain advice for the connection of the proposed development to the adjacent electricity network infrastructure. An assessment will be carried out based on the enquiry which may include whether or not:

- The existing network can support the expected electrical load of the development
- A substation may be required on-site, either a pad mount kiosk or chamber style and;
- site conditions or other issues that may impact on the method of supply.

Please direct the developer to Ausgrid's website, [www.ausgrid.com.au](http://www.ausgrid.com.au) about how to connect to Ausgrid's network.

**Conduit Installation**

The need for additional electricity conduits in the footway adjacent to the development will be assessed and documented in Ausgrid's Design Information, used to prepare the connection project design.

**Proximity to Existing Network Assets**  
**Underground Cables**

There are existing underground electricity network assets as follows: In Service 11kV High Voltage Under Ground Cables and Conduits in Warren Rd adjacent development. In Service 415V Low Voltage Under Ground Cables and Conduits in Warren Rd adjacent development..

Special care should also be taken to ensure that driveways and any other construction activities within the footpath area do not interfere with the existing cables in the footpath. Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed. Hence it is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area.

Safework Australia – Excavation Code of Practice, and Ausgrid's Network Standard NS156 outlines the minimum requirements for working around Ausgrid's underground cables.

### **Substation**

There are existing electricity substation assets Existing Substation S18365 is located in Road Reserve in Warren Rd adjacent property..

The substation ventilation openings, including substation duct openings and louvered panels, must be separated from building air intake and exhaust openings, natural ventilation openings and boundaries of adjacent allotments, by separation distances which meet the requirements of all relevant authorities, building regulations, BCA and Australian Standards including AS 1668.2: The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings.

In addition to above, Ausgrid requires the substation ventilation openings, including duct openings and louvered panels, to be separated from building ventilation system air intake and exhaust openings, including those on buildings on adjacent allotments, by not less than 6 metres.

Any portion of a building other than a BCA class 10a structure constructed from non combustible materials, which is not sheltered by a non-ignitable blast-resisting barrier and is within 3 metres in any direction from the housing of a kiosk substation, is required to have a Fire Resistance Level (FRL) of not less than 120/120/120. Openable or fixed windows or glass blockwork or similar, irrespective of their fire rating, are not permitted within 3 metres in any direction from the housing of a kiosk substation, unless they are sheltered by a non-ignitable blast resisting barrier.

The development must comply with both the Reference Levels and the precautionary requirements of the ICNIRP Guidelines for Limiting Exposure to Time-varying Electric and Magnetic Fields (1 HZ – 100 kHz) (ICNIRP 2010).

For further details on fire segregation requirements refer to Ausgrid's Network Standard 141.

Existing Ausgrid easements, leases and/or right of ways must be maintained at all times to ensure 24 hour access. No temporary or permanent alterations to this property tenure can occur without written approval from Ausgrid.

For further details refer to Ausgrid's Network Standard 143.

Please do not hesitate to contact Marcus Holmes on Ph: (02) 4399 8103 (please quote our ref: Trim 2017/11/346) should you require any further information.

Regards

*Marcus Holmes*

Marcus Holmes  
Engineering Officer - Sydney North & Central Coast - Customer, Assets & Digital  
Ausgrid  
Ph: (02) 4399 8103

I/We have read and understood my/our responsibilities as stated in Ausgrid's letter:-

**Re: DA/2317/2023 - 3 Warren Rd Warnervale - Asphalt Batching Plant & Waste or Resources Management Facility**

(Additional individual property details e.g lot or unit No.) \_\_\_\_\_

Signed:- \_\_\_\_\_ Date: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Name/s:- \_\_\_\_\_  
(owner/authorised representative of the abovementioned property)