

TELEPHONE:(02) 4399 8103EMAIL:mholmes@ausgrid.com.auREFERENCE:TRIM 2017/11/322

ATTN: Salli Pendergast Project Manager PO Box 20 Wyong NSW 2259 24-28 Campbell St Sydney NSW 2000 All mail to GPO Box 4009 Sydney NSW 2001 T+61 2 131 525 ausgrid.com.au

# Re: DA/1295/2023 - 80 Pacific Highway Doyalson - Subdivision of land and construction of associated infrastructure.

I refer to Central Coast Council development application DA/1295/2023.

This letter is Ausgrid's response under clause 45(2) of the State Environmental planning Policy (Infrastructure) 2007.

The assessment and evaluation of environmental impacts for a new development consent (or where a development consent is modified) is undertaken in accordance with requirements of Section 79C of the Environmental Planning and Assessment Act 1979. One of the obligations upon consent authorities, such as local councils, is to consider the suitability of the site for the development which can include a consideration of whether the proposal is compatible with the surrounding land uses and the existing environment.

In this regard, Ausgrid requires that due consideration be given to the compatibility of proposed development with existing Ausgrid infrastructure, particularly in relation to risks of electrocution, fire risks, Electric & Magnetic Fields (EMFs), noise, visual amenity and other matters that may impact on Ausgrid or the development.

## With Regard to: Subdivision of land and construction of associated infrastructure at 80 Pacific Highway Doyalson

- LandscapeManagement Plan 80 120 Pacific Highway, Doyalson\_Al-938795
- Plan of Subdivision 80-120 Pacific Highway Doyalosn\_PAN-340527

Ausgrid consents to the above mentioned development subject to the following conditions:-

## **Method of Electricity Connection**

The method of connection will be in line with Ausgrid's Electrical Standard (ES)1 – 'Premise Connection Requirements.

## **Supply of Electricity**

It is recommended for the nominated electrical consultant/contractor to provide a preliminary enquiry to Ausgrid to obtain advice for the connection of the proposed development to the adjacent electricity network infrastructure. An assessment will be carried out based on the enquiry which may include whether or not:

- The existing network can support the expected electrical load of the development
- A substation may be required on-site, either a pad mount kiosk or chamber style and;
- site conditions or other issues that may impact on the method of supply.

Please direct the developer to Ausgrid's website, www.ausgrid.com.au about how to connect to Ausgrid's network.

## **Conduit Installation**

The need for additional electricity conduits in the footway adjacent to the development will be assessed and documented in Ausgrid's Design Information, used to prepare the connection project design.

## Vegetation

All proposed vegetation underneath overhead power lines and above underground cables must comply with the requirements of ISSC 3 Guideline For Managing Vegetation Near Power Lines.

## Streetlighting

The developer is to consider the impact that existing streelighting and any future replacement streetlighting and maintenance may have on the development. Should the developer determine that any existing streetlighting may impact the development, the developer should either review the development design, particular the placement of windows, or discuss with Ausgrid the options for relocating the streetlighting. The relocating of any streetlighting will generally be at the developers cost. In many cases is not possible to relocate streetlighting due to its strategic positioning.

## Service Mains

It appears the existing overhead electricity service mains, that supply the subject property, may not have sufficient clearance to the proposed construction as per the requirements of "The Installation and Service Rules of NSW".

It is recommended that the developer engage a Level 2 Acreditted Service Provider (ASP) Electrician to ensure that the installation will comply with the Service Rules.

## Proximity to Existing Network Assets

## Overhead Powerlines

There are existing overhead electricity network assets in In Service 33kV Overhead Feeder in Pacific Hwy adjacent development with associated fibre optic. In Service 33kV Overhead Feeder behind development parallel to Pacific Hwy with auxiliary and associated fibre optic cables.

Safework NSW Document – Work Near Overhead Powerlines: Code of Practice, outlines the minimum safety separation requirements between these mains/poles to structures within the development throughout the construction process. It is a statutory requirement that these distances be maintained throughout construction. Special consideration should be given to the positioning and operating of cranes and the location of any scaffolding.

The "as constructed" minimum clearances to the mains should also be considered. These distances are outlined in the Ausgrid Network Standard, NS220 Overhead Design Manual. This document can be sourced from Ausgrid's website, www.ausgrid.com.au

Based on the design of the development provided, it is expected that the "as constructed" minimum clearances will not be encroached by the building development. However it remains the responsibility of the developer and relevant contractors to verify and maintain these clearances onsite.

Should the existing overhead mains require relocating due to the minimum safety clearances being compromised in either of the above scenarios, this relocation work is generally at the developers cost.

It is also the responsibility of the developer to ensure that the existing overhead mains have sufficient clearance from all types of vehicles that are expected be entering and leaving the site.

## **Underground Cables**

There are existing underground electricity network assets in In Service 11kV Under Ground Cables and Conduits in Pacific Hwy adjacent development. Existing HV & LV Conduit and cable in Wentworth Ave to existing Sub S64919 'Wentworth Pacific' on development site..

Special care should also be taken to ensure that driveways and any other construction activities within the footpath area do not interfere with the existing cables in the footpath. Ausgrid cannot guarantee the depth of cables due to possible changes in ground levels from previous activities after the cables were installed. Hence it is recommended that the developer locate and record the depth of all known underground services prior to any excavation in the area.

Safework Australia – Excavation Code of Practice, and Ausgrid's Network Standard NS156 outlines the minimum requirements for working around Ausgrid's underground cables.

## Substation

There are existing electricity substation assets Existing Sub S64919 'Wentworth Pacific' on development site..

There is an existing kiosk style electricity substation that may be impacted by the proposed construction. Subsidence and vibration must minimised at the substation site. The use of ground anchors under a substation is generally not permitted due to the presence of underground cabling and earthing conductors which may be more than 10m deep. A further area of exclusion may be required in some circumstances.

The substation ventilation openings, including substation duct openings and louvered panels, must be separated from building air intake and exhaust openings, natural ventilation openings and boundaries of adjacent allotments, by separation distances which meet the requirements of all relevant authorities, building regulations, BCA and Australian Standards including AS 1668.2: The use of ventilation and air-conditioning in buildings - Mechanical ventilation in buildings.

In addition to above, Ausgrid requires the substation ventilation openings, including duct openings and louvered panels, to be separated from building ventilation system air intake and exhaust openings, including those on buildings on adjacent allotments, by not less than 6 metres.

Any portion of a building other than a BCA class 10a structure constructed from non combustible materials, which is not sheltered by a non-ignitable blast-resisting barrier and is within 3 metres in any direction from the housing of a kiosk substation, is required to have a Fire Resistance Level (FRL) of not less than 120/120/120. Openable or fixed windows or glass blockwork or similar, irrespective of their fire rating, are not permitted within 3 metres in any direction from the housing of a kiosk substation, unless they are sheltered by a non-ignitable blast resisting barrier.

The development must comply with both the Reference Levels and the precautionary requirements of the ICNIRP Guidelines for Limiting Exposure to Time-varying Electric and Magnetic Fields (1 HZ - 100 kHZ) (ICNIRP 2010).

For further details on fire segregation requirements refer to Ausgrid's Network Standard 141.

Existing Ausgrid easements, leases and/or right of ways must be maintained at all times to ensure 24 hour access. No temporary or permanent alterations to this property tenure can occur without written approval from Ausgrid.

For further details refer to Ausgrid's Network Standard 143.

Please do not hesitate to contact Marcus Holmes on Ph: (02) 4399 8103 (please quote our ref: Trim 2017/11/322) should you require any further information.

Regards, Marcus

Marcus Holmes

Marcus Holmes Engineering Officer - Asset Management Sydney North & Central Coast Ausgrid Ph: (02) 4399 8103

I/We have read and understood my/our responsibilities Re: DA/1295/2023 - 80 Pacific Highway Doyalson - S infrastructure	as stated in Ausgrid's let Subdivision of land and	ter:- I <b>constrı</b>	uction of a	ssociated
(Additional individual property details e.g lot or unit No.)				
Signed:	Date:	/	/	
Name/s: (owner/authorised representative of the	abovementioned propert	y)		