

Solar Access

Building 1 - North

Supporting Material

Building 1 - Detailed Assessment

Building 1 – North Tower

Total apartments: 191

Solar access (9 am–3 pm):

- 135 apartments (70% of 191) receive ≥2 hours

- 39 apartments (20% of 191) receive no direct sunlight

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.

Level	Apartment Number	Direct sunlight between 9am-3pm			09:00–09:15	09:15–09:30	09:30–09:45	09:45–10:00	10:00–10:15	10:15–10:30	10:30–10:45	10:45–11:00	11:00–11:15	11:15–11:30	11:30–11:45	11:45–12:00	12:00–12:15	12:15–12:30	12:30–12:45	12:45–13:00	13:00–13:15	13:15–13:30	13:30–13:45	13:45–14:00	14:00–14:15	14:15–14:30	14:30–14:45	14:45–15:00
		Hours	ADG 4A-1.1 ≥2 hours	ADG 4A-1.3 Receives ≥15mins																								
01	01	4.5	✓	✓	✓	✓	✓	✓	✓	✓							✓	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓
	02	4.25	✓	✓	✓	✓	✓	✓	✓	✓		✓					✓	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓
	03	4.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓					✓	✓	✓	✓	✓	✓	✓	✓
	04	2.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓												
	05	0.25		✓	✓																							
	06	0.25		✓	✓																							
	07	0.25		✓	✓																							
02	01	4.5	✓	✓	✓	✓	✓	✓	✓	✓							✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	4.25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓				✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	03	4.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓
	04	2.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	✓										
	05	0.25		✓	✓																							
	06	0.25		✓	✓																							
	07	0.25		✓	✓																							
03	01	4.5	✓	✓	✓	✓	✓	✓	✓	✓							✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	4.25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓				✓	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓
	03	5.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓
	04	2.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	✓										
	05	0.25		✓	✓																							
	06	0.25		✓	✓																							
	07	0.25		✓	✓																							
05	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓														
	05	0.																										
	06	0.25		✓	✓													✓	✓									
06	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓														
	05	0.																										
	06	0.																										
	07	0.25		✓	✓													✓	✓									
07	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓														
	05	0.																										
	06	0.																										
	07	0.5		✓	✓													✓	✓									
08	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓														
	05	0.																										
	06	0.																										
	07	0.75		✓	✓													✓	✓	✓	✓							
09	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓														
	05	0.																										
	06	0.																										
	07	0.75		✓	✓													✓	✓	✓	✓							

Supporting Material

Building 1 - Detailed Assessment

Building 1 – North Tower

Total apartments: 191

Solar access (9 am–3 pm):

- 135 apartments (70% of 191) receive ≥2 hours

- 39 apartments (20% of 191) receive no direct sunlight

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.

Level	Apartment Number	Direct sunlight between 9am-3pm																											
		Hours	ADG 4A-1.1 ≥2 hours	ADG 4A-1.3 Receives ≥15mins	09:00–09:15	09:15–09:30	09:30–09:45	09:45–10:00	10:00–10:15	10:15–10:30	10:30–10:45	10:45–11:00	11:00–11:15	11:15–11:30	11:30–11:45	11:45–12:00	12:00–12:15	12:15–12:30	12:30–12:45	12:45–13:00	13:00–13:15	13:15–13:30	13:30–13:45	13:45–14:00	14:00–14:15	14:15–14:30	14:30–14:45	14:45–15:00	
10	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
10	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
10	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
10	04	2.5	✓		✓																								✓
10	05	0.																											
10	06	0.																											
10	07	1.			✓														✓	✓	✓	✓	✓						
11	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
11	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
11	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
11	04	2.5	✓		✓																								✓
11	05	0.																											
11	06	0.																											
11	07	1.25			✓														✓	✓	✓	✓	✓	✓					
12	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
12	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
12	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
12	04	2.5	✓		✓																								✓
12	05	0.																											
12	06	0.																											
12	07	1.75			✓														✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
13	04	2.5	✓		✓																								✓
13	05	0.																											
13	06	0.																											
13	07	2.25	✓		✓														✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
14	04	2.5	✓		✓																								✓
14	05	0.																											
14	06	0.																											
14	07	2.5	✓		✓														✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
15	04	2.5	✓		✓																								✓
15	05	0.																	</										

Supporting Material

Building 1 - Detailed Assessment

Building 1 – North Tower

Total apartments: 191

Solar access (9 am–3 pm):

- 135 apartments (70% of 191) receive ≥2 hours

- 39 apartments (20% of 191) receive no direct sunlight

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.

Level	Apartment Number	Direct sunlight between 9am-3pm																										
		Hours	ADG 4A-1.1 ≥2 hours	ADG 4A-1.3 Receives ≥15mins	09:00–09:15	09:15–09:30	09:30–09:45	09:45–10:00	10:00–10:15	10:15–10:30	10:30–10:45	10:45–11:00	11:00–11:15	11:15–11:30	11:30–11:45	11:45–12:00	12:00–12:15	12:15–12:30	12:30–12:45	12:45–13:00	13:00–13:15	13:15–13:30	13:30–13:45	13:45–14:00	14:00–14:15	14:15–14:30	14:30–14:45	14:45–15:00
17	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
17	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
17	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
17	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
17	05	0.																										
17	06	0.																										
17	07	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
18	05	0.																										
18	06	0.																										
18	07	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
19	05	0.																										
19	06	0.																										
19	07	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
20	05	0.																										
20	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
21	05	0.																										
21	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
22	05	0.																										
22	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	05	0.																										
23	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

Supporting Material

Building 1 - Detailed Assessment

Building 1 – North Tower

Total apartments: 191

Solar access (9 am–3 pm):

- 135 apartments (70% of 191) receive ≥2 hours

- 39 apartments (20% of 191) receive no direct sunlight

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.


Level	Apartment Number	Direct sunlight between 9am-3pm																										
		Hours	ADG 4A-1.1 ≥2 hours	ADG 4A-1.3 Receives ≥15mins	09:00–09:15	09:15–09:30	09:30–09:45	09:45–10:00	10:00–10:15	10:15–10:30	10:30–10:45	10:45–11:00	11:00–11:15	11:15–11:30	11:30–11:45	11:45–12:00	12:00–12:15	12:15–12:30	12:30–12:45	12:45–13:00	13:00–13:15	13:15–13:30	13:30–13:45	13:45–14:00	14:00–14:15	14:15–14:30	14:30–14:45	14:45–15:00
23	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
23	05	0.																										
23	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
24	05	0.																										
24	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
25	05	0.																										
25	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
26	05	0.																										
26	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
27	05	0.																										
27	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
28	05	0.																										
28	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
29	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
29	02	5.75	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
29	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
29	04	2.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
29	05	0.																										
29	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30	01	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30	02	5.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30	03	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30	04	2.25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30	05	6.	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
30	06	2.5	✓	✓															✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Total			135	152																								

Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study

To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

 Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.



9:00am - June 21



9:15am - June 21

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.



9:30am - June 21




9:45am - June 21


Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study


To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

 Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.



10:00am - June 21



10:15am - June 21


OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.



10:30am - June 21



10:45am - June 21


Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study

To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.




11:00am - June 21




11:15am - June 21

OBJECTIVE 4A-1

- 1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.
- 3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.



11:30am - June 21




11:45am - June 21


Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study


To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

 Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.



12:00pm - June 21




12:15pm - June 21

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.



12:30pm - June 21




12:45pm - June 21

Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study


To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

 Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.




1:00pm - June 21




1:15pm - June 21

OBJECTIVE 4A-1

- 1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.
- 3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.



1:30pm - June 21




1:45pm - June 21

Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study

To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

 Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.



2:00pm - June 21



2:15pm - June 21


OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.



2:30pm - June 21



2:45pm - June 21


Supporting Material

Building 1 - Detailed Assessment - Sun Eye View Study

To assist with manual verification of the solar access methodology, the following diagrams present sun-eye views in parallel projection.

Legend:

Living room windows are highlighted to illustrate areas tested for direct solar access at each 15-minute interval.



3:00pm - June 21

OBJECTIVE 4A-1

1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.

3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid winter.