



NSW RURAL FIRE SERVICE

Central Coast Council
PO Box 20
WYONG NSW 2259

Your reference: DA58884 (CNR-10674)
Our reference: DA20200902003164-Original-1

ATTENTION: Belinda Jennett

Date: Monday 7 September 2020

Dear Sir/Madam,

Integrated Development Application
s100B – SFPP – Child Care Centre
27 Sunny Bank Road Lisarow NSW 2250, 1//DP880254, 1//DP880254

I refer to your correspondence dated 31/07/2020 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

Asset Protection Zones

Intent of measures: to provide sufficient space and maintain reduced fuel loads to ensure radiant heat levels at the buildings are below critical limits and prevent direct flame contact.

1. At the commencement of building works or the issue of a subdivision certificate (whichever comes first), and in perpetuity to ensure ongoing protection from the impact of bush fires, the subject land outside of the revegetated corridor and landscaped area along the western boundary must be managed as an Inner Protection Area (IPA) in accordance with the requirements of Appendix 4 of *Planning for Bush Fire Protection 2019*. When establishing and maintaining an IPA the following requirements apply:

- tree canopy cover should be less than 15% at maturity;
- trees at maturity should not touch or overhang the building;
- lower limbs should be removed up to a height of 2m above the ground;
- tree canopies should be separated by 2 to 5m;
- preference should be given to smooth barked and evergreen trees;
- large discontinuities or gaps in vegetation should be provided to slow down or break the progress of fire towards buildings;
- shrubs should not be located under trees;
- shrubs should not form more than 10% ground cover;
- clumps of shrubs should be separated from exposed windows and doors by a distance of at least twice the height of the vegetation.

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au

- grass should be kept mown (as a guide grass should be kept to no more than 100mm in height); and
- leaves and vegetation debris should be removed

Construction Standards

Intent of measures: to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.

2. Construction of the proposed child care centre must comply with Sections 3 and 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bush fire-prone areas* or NASH Standard (1.7.14 updated) *National Standard Steel Framed Construction in Bushfire Areas – 2014* as appropriate and Section 7.5 of *Planning for Bush Fire Protection 2019*.

Water and Utility Services

Intent of measures: to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.

3. The provision of water, electricity and gas must comply the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- fire hydrant, spacing, design and sizing complies with the relevant clauses of Australian Standard AS 2419.1:2005;
- hydrants are and not located within any road carriageway;
- reticulated water supply to urban subdivisions uses a ring main system for areas with perimeter roads;
- fire hydrant flows and pressures comply with the relevant clauses of AS 2419.1:2005;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
 - lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and
 - no part of a tree is closer to a power line than the distance set out in accordance with the specifications in *ISSC3 Guideline for Managing Vegetation Near Power Lines*.
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - *The storage and handling of LP Gas*, the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

Emergency and Evacuation Planning Assessment

Intent of measures: to provide suitable emergency and evacuation arrangements for occupants of SFPP developments.

4. Bush Fire Emergency Management and Evacuation Plan is prepared consistent with the:

- The NSW RFS document: *A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan*; and,
- *NSW RFS Schools Program Guide*

The Bush Fire Emergency Management and Evacuation Plan should include planning for the early relocation of occupants. A copy of the Bush Fire Emergency Management and Evacuation Plan should be provided to the Local Emergency Management Committee for its information prior to occupation of the development. An Emergency Planning Committee needs to be established to consult with residents (and their families in the case of aged care accommodation and schools) and staff in developing and implementing an Emergency Procedures Manual.

Detailed plans of all emergency assembly areas including on site and off-site arrangements as stated in AS 3745:2010 are to be clearly displayed, and an annual emergency evacuation exercise is to be conducted.

For any queries regarding this correspondence, please contact Emma Jensen on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese

Team Leader, Dev. Assessment & Planning
Planning and Environment Services



NSW RURAL FIRE SERVICE

BUSH FIRE SAFETY AUTHORITY

SFPP – Child Care Centre

27 Sunny Bank Road Lisarow NSW 2250, 1//DP880254, 1//DP880254

RFS Reference: DA20200902003164-Original-1

Your Reference: DA58884 (CNR-10674)

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

Kalpana Varghese

Team Leader, Dev. Assessment & Planning
Planning and Environment Services

Monday 7 September 2020