

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

No.	Control	Comments	Compliance		
PART 3 – SETTING THE DEVELOPMENT					
3A	Site Analysis		Yes	No	N/A
3A-1	Site analysis illustrates that design decisions have been based on opportunities and constraints of the site conditions and their relationship to the surrounding context.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3B	Orientation		Yes	No	N/A
3B-1	Building types and layouts respond to the streetscape and site while optimising solar access within the development.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3B-2	Overshadowing of neighbouring properties is minimised during mid-winter.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3C	Public Domain Interface		Yes	No	N/A
3C-1	Transition between private and public domain is achieved without compromising safety and security.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3C-2	Amenity of the public domain is retained and enhanced.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3D	Communal and Public Open Space		Yes	No	N/A
3D-1	An adequate area of communal open space is provided to enhance residential amenity and to provide opportunities for landscaping.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Design Criteria</b> Communal open space has a minimum area equal to 25% of the site.  <b>Required:</b> 25% x 2,191m <sup>2</sup> = 547.75m <sup>2</sup>	<p>The development proposes a total communal open space provision of 427.4m<sup>2</sup>, which equates to 19.5% of the site area.</p> <p>Communal open space has been provided in the form of roof terraces across two (2) levels of the building, being levels 14 and 15. These spaces have been designed to maximise views to the Auburn Memorial Park to the south as well as to provide a sense of residential activation to the urban street wall character when viewed from the park. The spaces have been designed to facilitate both active and passive recreation for residents.</p> <p>The variation to the provision of communal open space is considered acceptable on merit, having regard to the quality and functionality of the communal open space areas.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid-winter).	Between 9am and 3pm on 21 June, the COS area achieves a minimum 50% direct sunlight to the principal useable part of the COS.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3D-2	Communal open space is designed to allow for a range of activities, respond to site conditions and be attractive and inviting.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

3D-3	Communal open space is designed to maximise safety.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
3D-4	Public open space, where provided, is responsive to the existing pattern and uses of the neighbourhood.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>												
3E	Deep Soil Zones		Yes	No	N/A												
3E-1	Deep soil zones provide areas on the site that allow for and support healthy plant and tree growth. They improve residential amenity and promote management of water and air quality.	Deep soil zones have been provided on the site.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<div>Design Criteria</div> <div>Deep soil zones are to meet the following minimum requirements:</div> <table><thead><tr><th>Site area</th><th>Minimum dimensions</th><th>Deep soil zone (% of site area)</th></tr></thead><tbody><tr><td>less than 650m<sup>2</sup></td><td>-</td><td rowspan="4">7%</td></tr><tr><td>650m<sup>2</sup> - 1,500m<sup>2</sup></td><td>3m</td></tr><tr><td>greater than 1,500m<sup>2</sup></td><td>6m</td></tr><tr><td>greater than 1,500m<sup>2</sup> with significant existing tree cover</td><td>6m</td></tr></tbody></table>	Site area	Minimum dimensions	Deep soil zone (% of site area)	less than 650m <sup>2</sup>	-	7%	650m <sup>2</sup> - 1,500m <sup>2</sup>	3m	greater than 1,500m <sup>2</sup>	6m	greater than 1,500m <sup>2</sup> with significant existing tree cover	6m	A deep soil provision (with minimum dimension of 3m) of 27.47sqm is provided, which equates to 1.3% of the site.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Site area	Minimum dimensions	Deep soil zone (% of site area)															
less than 650m <sup>2</sup>	-	7%															
650m <sup>2</sup> - 1,500m <sup>2</sup>	3m																
greater than 1,500m <sup>2</sup>	6m																
greater than 1,500m <sup>2</sup> with significant existing tree cover	6m																
3F	Visual Privacy		Yes	No	N/A												
3F-1	Adequate building separation distances are shared equitably between neighbouring sites, to achieve reasonable levels of external and internal visual privacy.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<div>Design Criteria</div> <div>Separation between windows and balconies is provided to ensure visual privacy is achieved. Minimum required separation distances from buildings to the side and rear boundaries are as follows:</div> <table><thead><tr><th>Building height</th><th>Habitable rooms and balconies</th><th>Non-habitable rooms</th></tr></thead><tbody><tr><td>up to 12m (4 storeys)</td><td>6m</td><td>3m</td></tr><tr><td>up to 25m (5-8 storeys)</td><td>9m</td><td>4.5m</td></tr><tr><td>over 25m (9+ storeys)</td><td>12m</td><td>6m</td></tr></tbody></table> <div>Note:</div> <div>Separation distances between buildings on the same site should combine required building separations depending on the type of room.</div> <div>Gallery access circulation should be treated as habitable space when measuring privacy separation distances between neighbouring properties.</div>	Building height	Habitable rooms and balconies	Non-habitable rooms	up to 12m (4 storeys)	6m	3m	up to 25m (5-8 storeys)	9m	4.5m	over 25m (9+ storeys)	12m	6m	<div>The development provides a zero boundary setback to the north-western boundary and a partial zero boundary setback to the north-eastern boundary. For that part of the north-eastern boundary not subject to the zero boundary setback, for Level 1, the balconies of the units facing the side boundary maintain a 6.5 metre setback from the boundary.</div> <div>For Levels 2 and 3, the balconies of the north-westernmost units maintain a 6.5 metre setback, with the remaining building walls maintaining a 9 metre setback to the boundary.</div> <div>For Levels 4 to 14, the balconies and building walls maintain a 9 metre setback to the boundary.</div> <div>The development does not achieve the minimum 12 metre building separation distance required for those units above 25 metres.</div>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Building height	Habitable rooms and balconies	Non-habitable rooms															
up to 12m (4 storeys)	6m	3m															
up to 25m (5-8 storeys)	9m	4.5m															
over 25m (9+ storeys)	12m	6m															

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

		<p>In order to mitigate potential overlooking impacts from those units, the design of the building incorporates angled walls and orients the units to the north which facilitates access to north light while directing views away from the neighbouring site to maintain visual privacy for the adjoining site.</p> <p>On this basis, the variation from the required 12 metre building separation for that part of the building above 25 metres is considered acceptable on merit.</p>			
<b>3F-2</b>	Site and building design elements increase privacy without compromising access to light and air and balance outlook and views from habitable rooms and private open space.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>3G</b>	<b>Pedestrian Access and Entries</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>
<b>3G-1</b>	Building entries and pedestrian access connects to and addresses the public domain.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>3G-2</b>	Access, entries and pathways are accessible and easy to identify.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>3G-3</b>	Large sites provide pedestrian links for access to streets and connection to destinations.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>3H</b>	<b>Vehicle Access</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>
<b>3H-1</b>	Vehicle access points are designed and located to achieve safety, minimise conflicts between pedestrians and vehicles and create high quality streetscapes.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>3J</b>	<b>Bicycle and Car Parking</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>
<b>3J-1</b>	Car parking is provided based on proximity to public transport in metropolitan Sydney and centres in regional areas.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p><b>Design Criteria</b> For development in the following locations:</p> <ul style="list-style-type: none"> <li>on sites that are within 800 metres of a railway station or light rail stop in the Sydney Metropolitan Area; or</li> <li>on land zoned, and sites within 400 metres of land zoned, B3 Commercial Core, B4 Mixed Use or equivalent in a nominated regional centre,</li> </ul> <p>The minimum car parking requirement for residents and visitors is set out in the Guide to Traffic Generating Developments, or the car parking requirement prescribed by the relevant council, whichever is less.</p> <p>The car parking needs for a development must be provided off street.</p>	<p>For the purpose of calculating car park required for the development, the Traffic Generating Development requirements of the RMS have been applied:</p> <p>26 x 0.6 = 15.6 53 x 0.9 = 47.7 17 x 1.4 = 23.8 Total = 87.1 spaces = 88 spaces Provided – 88 spaces</p> <p>96 x 0.2 = 20 visitor spaces Provided – 20 visitor spaces</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Control</b>				

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

	<table border="1"> <tr> <td>1 bedroom spaces</td><td>0.6</td></tr> <tr> <td>2 bed</td><td>0.9 spaces</td></tr> <tr> <td>3 bed</td><td>1.4 spaces</td></tr> <tr> <td>4+ bed</td><td>1.4 spaces</td></tr> <tr> <td>Visitor</td><td>0.2 spaces per dwelling</td></tr> </table>	1 bedroom spaces	0.6	2 bed	0.9 spaces	3 bed	1.4 spaces	4+ bed	1.4 spaces	Visitor	0.2 spaces per dwelling				
1 bedroom spaces	0.6														
2 bed	0.9 spaces														
3 bed	1.4 spaces														
4+ bed	1.4 spaces														
Visitor	0.2 spaces per dwelling														
3J-2	Parking and facilities are provided for other modes of transport.	Bicycle parking has been provided.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
3J-3	Car park design and access is safe and secure		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
3J-4	Visual and environmental impacts of underground car parking are minimised.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
3J-5	Visual and environmental impacts of on-grade car parking are minimised.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
3J-6	Visual and environmental impacts of above ground enclosed car parking are minimised.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
<b>PART 4 – DESIGNING THE BUILDING</b>															
4A	<b>Solar and Daylight Access</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>										
4A-1	To optimise the number of apartments receiving sunlight to habitable rooms, primary windows and private open space.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
	<b>Design Criteria</b> Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas.  <b>Required:</b> 70% x 96 units = 68 units minimum	59 of the 96 units (61.4%) receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>										
	A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid-winter.  <b>Maximum:</b> 15% x 96 units = 15 units maximum	12 of the 96 units receive no direct sunlight between 9 am and 3 pm at mid-winter.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4A-2	Daylight access is maximised where sunlight is limited.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4A-3	Design incorporates shading and glare control, particularly for warmer months.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4B	<b>Natural Ventilation</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>										
4B-1	All habitable rooms are naturally ventilated.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4B-2	The layout and design of single aspect apartments maximises natural ventilation.	Satisfactory	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4B-3	The number of apartments with natural cross ventilation is maximised to create a comfortable indoor environment for residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
	<b>Design Criteria</b> At least 60% of apartments are naturally cross ventilated in the first nine storeys of the building. Apartments at ten storeys or greater are deemed to be cross ventilated only if any enclosure of the balconies at these levels allows adequate natural ventilation and cannot	71 units are naturally cross ventilated which equates to 73.9%	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

	be fully enclosed.  <b>Required:</b> 60% x 96 = 58 units																
	Overall depth of a cross-over or cross-through apartment does not exceed 18m, measured glass line to glass line.	Single aspect units are less than 18m in depth.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
<b>4C</b>	<b>Ceiling Heights</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>												
<b>4C-1</b>	Ceiling height achieves sufficient natural ventilation and daylight access.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
	<b>Design Criteria</b> Measured from finished floor level to finished ceiling level, minimum ceiling heights are: <table><tr><th colspan="2">Minimum ceiling height for apartment and mixed use buildings</th></tr><tr><td>Habitable rooms</td><td>2.7m</td></tr><tr><td>Non-habitable</td><td>2.4m</td></tr><tr><td>For 2 storey apartments</td><td>2.7m for main living area floor 2.4m for second floor, where its area does not exceed 50% of the apartment area</td></tr><tr><td>Attic spaces</td><td>1.8m at edge of room with a 30 degree minimum ceiling slope</td></tr><tr><td>If located in mixed used areas</td><td>3.3m for ground and first floor to promote future flexibility of use</td></tr></table> These minimums do not preclude higher ceilings if desired.	Minimum ceiling height for apartment and mixed use buildings		Habitable rooms	2.7m	Non-habitable	2.4m	For 2 storey apartments	2.7m for main living area floor 2.4m for second floor, where its area does not exceed 50% of the apartment area	Attic spaces	1.8m at edge of room with a 30 degree minimum ceiling slope	If located in mixed used areas	3.3m for ground and first floor to promote future flexibility of use	All residential units maintain a minimum floor to ceiling heights.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Minimum ceiling height for apartment and mixed use buildings																	
Habitable rooms	2.7m																
Non-habitable	2.4m																
For 2 storey apartments	2.7m for main living area floor 2.4m for second floor, where its area does not exceed 50% of the apartment area																
Attic spaces	1.8m at edge of room with a 30 degree minimum ceiling slope																
If located in mixed used areas	3.3m for ground and first floor to promote future flexibility of use																
<b>4C-2</b>	Ceiling height increases the sense of space in apartments and provides for well-proportioned rooms.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												
<b>4C-3</b>	Ceiling heights contribute to the flexibility of building use over the life of the building.	The ground floor ceiling heights contribute to the flexibility of the building use.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>												

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

4D	Apartment Size and Layout		Yes	No	N/A										
4D-1	The layout of rooms within an apartment is functional, well organised and provides a high standard of amenity.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
	<b>Design Criteria</b>  Apartments are required to have the following minimum internal areas: <table><tr><th>Apartment type</th><th>Minimum internal area</th></tr><tr><td>Studio</td><td>35m<sup>2</sup></td></tr><tr><td>1 bedroom</td><td>50m<sup>2</sup></td></tr><tr><td>2 bedroom</td><td>70m<sup>2</sup></td></tr><tr><td>3 bedroom</td><td>90m<sup>2</sup></td></tr></table>  The minimum internal areas include only one bathroom. Additional bathrooms increase the minimum internal area by 5m <sup>2</sup> each.  A fourth bedroom and further additional bedrooms increase the minimum internal area by 12m <sup>2</sup> each.	Apartment type	Minimum internal area	Studio	35m <sup>2</sup>	1 bedroom	50m <sup>2</sup>	2 bedroom	70m <sup>2</sup>	3 bedroom	90m <sup>2</sup>	All units comply with the minimum internal areas.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Apartment type	Minimum internal area													
	Studio	35m <sup>2</sup>													
1 bedroom	50m <sup>2</sup>														
2 bedroom	70m <sup>2</sup>														
3 bedroom	90m <sup>2</sup>														
Every habitable room must have a window in an external wall with a total minimum glass area of not less than 10% of the floor area of the room. Daylight and air may not be borrowed from other rooms.	All habitable rooms have adequate access to daylight and ventilation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>											
4D-2	Environmental performance of the apartment is maximised.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
	<b>Design Criteria</b> Habitable room depths are limited to a maximum of 2.5 x the ceiling height.	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
	In open plan layouts (where the living, dining and kitchen are combined) the maximum habitable room depth is 8m from a window.	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

<b>4D-3</b>	Apartment layouts are designed to accommodate a variety of household activities and needs.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	<b>Design Criteria</b> Master bedrooms have a minimum area of 10m <sup>2</sup> and other bedrooms 9m <sup>2</sup> (excluding wardrobe space).	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Bedrooms have a minimum dimension of 3m (excluding wardrobe space).	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	Living rooms or combined living/dining rooms have a minimum width of: • 3.6m for studio and 1 bedroom apartments • 4m for 2 and 3 bedroom apartments.	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	The width of cross-over or cross-through apartments are at least 4m internally to avoid deep narrow apartment layouts.	All units comply.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
<b>4E</b>	<b>Private Open Space and Balconies</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>															
<b>4E-1</b>	Apartments provide appropriately sized private open space and balconies to enhance residential amenity.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	<b>Design Criteria</b> All apartments are required to have primary balconies as follows: <table border="1" style="margin-top: 10px;"> <thead> <tr> <th>Dwelling type</th> <th>Minimum area</th> <th>Minimum depth</th> </tr> </thead> <tbody> <tr> <td>Studio apartments</td> <td>4m<sup>2</sup></td> <td>-</td> </tr> <tr> <td>1 bedroom apartments</td> <td>8m<sup>2</sup></td> <td>2m</td> </tr> <tr> <td>2 bedroom apartments</td> <td>10m<sup>2</sup></td> <td>2m</td> </tr> <tr> <td>3+ bedroom apartments</td> <td>12m<sup>2</sup></td> <td>2.4m</td> </tr> </tbody> </table> The minimum balcony depth to be counted as contributing to the balcony area is 1m.	Dwelling type	Minimum area	Minimum depth	Studio apartments	4m <sup>2</sup>	-	1 bedroom apartments	8m <sup>2</sup>	2m	2 bedroom apartments	10m <sup>2</sup>	2m	3+ bedroom apartments	12m <sup>2</sup>	2.4m	Each unit is provided with the minimum POS area, in the form of balconies.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Dwelling type	Minimum area	Minimum depth																	
	Studio apartments	4m <sup>2</sup>	-																	
1 bedroom apartments	8m <sup>2</sup>	2m																		
2 bedroom apartments	10m <sup>2</sup>	2m																		
3+ bedroom apartments	12m <sup>2</sup>	2.4m																		
For apartments at ground level or on a podium or similar structure, a private open space is provided instead of a balcony. It must have a minimum area of 15m <sup>2</sup> and a minimum depth of 3m.	Private open space areas for ground level apartments have been maximised wherever possible and exceed the minimum requirements.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																
<b>4E-2</b>	Primary private open space and balconies are appropriately located to enhance liveability for residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
<b>4E-3</b>	Private open space and balcony design is integrated into and contributes to the overall architectural form and detail of the building.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
<b>4E-4</b>	Private open space and balcony design maximises safety.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
<b>4F</b>	<b>Common Circulation and Spaces</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>															
<b>4F-1</b>	Common circulation spaces achieve good amenity and properly service the number of apartments.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	<b>Design Criteria</b> The maximum number of apartments off a circulation core on a single level is eight.	The maximum number of units off the circulation core is seven.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
	For buildings of 10 storeys and over, the maximum number of apartments sharing a single lift is 40.	The development provides a total of 96 units across 15 storeys, with two lifts provided.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
<b>4F-2</b>	Common circulation spaces promote safety and provide for social interaction between residents.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>															
<b>4G</b>	<b>Storage</b>		<b>Yes</b>	<b>No</b>	<b>N/A</b>															
<b>4G-1</b>	Adequate, well designed storage is provided in each apartment.																			

## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

	<div><b>Design Criteria</b> In addition to storage in kitchens, bathrooms and bedrooms, the following storage is provided:</div> <table><tr><th>Dwelling type</th><th>Storage size volume</th></tr><tr><td>Studio apartments</td><td>4m³</td></tr><tr><td>1 bedroom apartments</td><td>6m³</td></tr><tr><td>2 bedroom apartments</td><td>8m³</td></tr><tr><td>3+ bedroom apartments</td><td>10m³</td></tr></table> <div>At least 50% of the required storage is to be located within the apartment.</div>	Dwelling type	Storage size volume	Studio apartments	4m³	1 bedroom apartments	6m³	2 bedroom apartments	8m³	3+ bedroom apartments	10m³	All units provide a minimum 50% storage within the unit.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Dwelling type	Storage size volume														
Studio apartments	4m³														
1 bedroom apartments	6m³														
2 bedroom apartments	8m³														
3+ bedroom apartments	10m³														
4G-2	Additional storage is conveniently located, accessible and nominated for individual apartments.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4H	<b>Acoustic Privacy</b>		Yes	No	N/A										
4H-1	Noise transfer is minimised through the siting of buildings and building layout.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4H-2	Noise impacts are mitigated within apartments through layout and acoustic treatments.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4J	<b>Noise and Pollution</b>		Yes	No	N/A										
4J-1	In noisy or hostile environments the impacts of external noise and pollution are minimised through the careful siting and layout of buildings.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4J-2	Appropriate noise shielding or attenuation techniques for the building design, construction and choice of materials are used to mitigate noise transmission.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4K	<b>Apartment Mix</b>		Yes	No	N/A										
4K-1	A range of apartment types and sizes is provided to cater for different household types now and into the future.	A variety of apartment types are proposed, ranging from 1 bed to 3 bed apartments in a mix of configurations. The proposed mix is reflective of the site's location and demographics and provides for apartments that can accommodate single person or family households.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4K-2	The apartment mix is distributed to suitable locations within the building.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4L	<b>Ground Floor Apartments</b>		Yes	No	N/A										
4L-1	Street frontage activity is maximised where ground floor apartments are located.	No ground floor units are proposed.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
4L-2	Design of ground floor apartments delivers amenity and safety for residents.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>										
4M	<b>Façades</b>		Yes	No	N/A										
4M-1	Building facades provide visual interest along the street while respecting the character of the local area.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4M-2	Building functions are expressed by the façade.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4N	<b>Roof Design</b>		Yes	No	N/A										
4N-1	Roof treatments are integrated into the building design and positively respond to the street.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4N-2	Opportunities to use roof space for residential accommodation and open space are maximised.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4N-3	Roof design incorporates sustainability features.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4O	<b>Landscape Design</b>		Yes	No	N/A										
4O-1	Landscape design is viable and sustainable.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4O-2	Landscape design contributes to the streetscape and amenity.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>										
4P	<b>Planting on Structures</b>		Yes	No	N/A										



## ATTACHMENT 9 - Apartment Design Guide (ADG) Assessment Table

4P-1	Appropriate soil profiles are provided.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4P-2	Plant growth is optimised with appropriate selection and maintenance.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4P-3	Planting on structures contributes to the quality and amenity of communal and public open spaces.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4Q	<b>Universal Design</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4Q-1	Universal design features are included in apartment design to promote flexible housing for all community members.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<i>Developments achieve a benchmark of 20% of the total apartments incorporating the Liveable Housing Guideline's silver level universal design features</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4Q-2	A variety of apartments with adaptable designs are provided.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4Q-3	Apartment layouts are flexible and accommodate a range of lifestyle needs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4R	<b>Adaptive Reuse</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4R-1	New additions to existing buildings are contemporary and complementary and enhance an area's identity and sense of place.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4R-2	Adapted buildings provide residential amenity while not precluding future adaptive reuse.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4S	<b>Mixed Use</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4S-1	Mixed use developments are provided in appropriate locations and provide active street frontages that encourage pedestrian movement.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4S-2	Residential levels of the building are integrated within the development, and safety and amenity is maximised for residents.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4T	<b>Awnings and Signage</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4T-1	Awnings are well located and complement and integrate with the building design.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4T-2	Signage responds to the context and desired streetscape character.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4U	<b>Energy Efficiency</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4U-1	Development incorporates passive environmental design.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4U-2	Development incorporates passive solar design to optimise heat storage in winter and reduce heat transfer in summer.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4U-3	Adequate natural ventilation minimises the need for mechanical ventilation.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4V	<b>Water Management and Conservation</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4V-1	Potable water use is minimised.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4V-2	Urban stormwater is treated on site before being discharged to receiving waters.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4V-3	Flood management systems are integrated into site design.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
4W	<b>Waste Management</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4W-1	Waste storage facilities are designed to minimise impacts on the streetscape, building entry and amenity of residents.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4W-2	Domestic waste is minimised by providing safe and convenient source separation and recycling.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4X	<b>Building Maintenance</b>	<b>Yes</b>	<b>No</b>	<b>N/A</b>
4X-1	Building design detail provides protection from weathering.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4X-2	Systems and access enable ease of maintenance.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4X-3	Material selection reduces ongoing maintenance costs.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>