

# Mechanical Services Ventilation Design

Project	<b>The HUB</b> <b>2 Bachell Avenue, Lidcombe</b>
Development Application No	<b>DA2023/0775</b>
Client	<b>Raad Property Acquisition No 10 Pty Ltd</b>
Report No	<b>1748-R1</b>
Title	<b>Ventilation Design</b>
Date issued	<b>28<sup>th</sup> August, 2024</b>
Revision	<b>B</b>





152 Wollongong Rd  
Arncliffe NSW 2205  
PO Box A98  
T : (02) 9599 1969  
Email: [msarkis@twoms.com.au](mailto:msarkis@twoms.com.au)  
Web: [www.twoms.com.au](http://www.twoms.com.au)

## Contents

---

Contents	2
DISCLAIMER	5
ABBREVIATIONS & REFERENCES	6
NOTES & ASSUMPTIONS	7
Referenced Documents	7
EXECUTIVE SUMMARY	8

## **Revision Table**

<b>Rev</b>	<b>Date</b>	<b>Description</b>	<b>Prepared By</b>	<b>Signed</b>
A	28.08.2024	For Information	M. Sarkis	 MIEAust, CPEng, CBSEng, NPER, RPEQ, APREng BE. Mech, M. Arch Sc and Building Services National Engineering Register (NER) Chartered Professional Engineer (EA CPEng) DBP Registered Design Practitioner (DEP0000263) DBP Principal Design Practitioner (PDP0000095) Victorian AMR Registered Design Practitioner (PE0005538) QLD Registered Professional Engineer (RPEQ) AIRAH Registered Professional Engineer (APREng) NABERS Accredited Assessor CBD Accredited Assessor C9 and C11 Accredited Certifier 30 Years experience in Building Services
B	18.09.24	Upgraded report to include: 1. Commercial Kitchen Ventilation 2. Exhaust Discharges locations	M. Sarkis	

**Copyright**

This report is copyright to TWO MS Group Pty Ltd. All rights reserved. No material may be reproduced without prior permission. The design, format and processes used in calculating and processing the content, and the analysis contained herein is and remains the intellectual property of TWO MS Group Pty Ltd, and may not be reproduced, republished, distributed, transmitted, displayed, broadcast or otherwise exploited in any manner either in part or in whole without the express prior written permission of the author. Copyright is protected and governed by the Copyright Act 1968.

## **DISCLAIMER**

---

TWO MS Group Pty Ltd takes all reasonable care when performing the services.

TWO MS Group Pty Ltd, does not make any representation or give any warranties or assurances as to the accuracy or completeness of the information contained in the Report, or the Report is free from errors or omission.

Information in this report is based on referenced documents provided. Variations to the information and outcomes presented in this report is a certainty. It is influenced by a number of criteria including: accuracy of information provided, material/product data properties, build quality, weather details and modeling software.

The accuracy of the information contained herein, is to the best of our knowledge, not false or misleading. TWO MS Group Pty Ltd and all its directors and employees, accept no liability for any costs, losses and/or, damages, whether direct, indirect or consequential, incurred as a result of relying of this report, and whether caused by reason of any error, negligent act, omission or misrepresentation in the Report or otherwise or specialized conditions implemented for tenancy equipment or processes.

## ABBREVIATIONS & REFERENCES

---

<b>ABCB</b>	Australian Building Codes Board
<b>ACH</b>	Air Change per Hour
<b>AS1668.2-2012</b>	The use of ventilation and airconditioning in buildings Mechanical ventilation in buildings
<b>BCA</b>	Building Code of Australia (version 2022)
<b>CC</b>	Construction Certificate
<b>CFD</b>	Computational Fluid Dynamics
<b>DA</b>	Development Application
<b>DTS</b>	Deemed To Satisfy (refers to the prescriptive method in the NCC)
<b>NCC</b>	National Construction Code Series (NCC-1, Volume 1)
<b>Reference Building</b>	(also referred to as <b>DTS</b> building) The Reference Building is a theoretical building based on prescribed criteria as detailed in NCC volume 1 Section J
<b>Proposed Building</b>	The actual building that will be built

## **NOTES & ASSUMPTIONS**

---

1. This report must be read in conjunction with the referenced documents.

## **Referenced Documents**

---

1. Arch drawings received on the 27.08.24;
2. BCA 2022 NCC-1;
3. AS1668.2-2012;
4. Council additional information request dated 30 July 2024.

## EXECUTIVE SUMMARY

---

I have been commissioned by the client as the Mechanical Services consultant and have assisted in the planning and spatial consideration for the Mechanical Services.

The purpose of this report is to support council requirements in relation to the additional information request dated 30 July 2024, in relation to the ventilation of the proposed Childcare. The following is an extract from council' letter:

### *'Environmental Health*

#### *2. Details of mechanical ventilation to be provided to show compliance with AS1668 and childcare ventilation requirements.*

<b>110. Ventilation and natural light</b>	<p>There is insufficient detail on the plans for me to confirm this however my comments are as follows:</p> <p><u>Playrooms 1 &amp; 2</u></p> <ul style="list-style-type: none"><li>• Appear to not have any windows, only the doors that lead out onto the outdoor play space.</li><li>• There are no windows in the children's bathrooms/nappy change area</li></ul> <p><u>Playroom 3</u></p> <ul style="list-style-type: none"><li>• No natural light or ventilation in the cot room</li><li>• No window, only the door leading out to the outdoor play space.</li><li>• No window in the children's toilet, only the door leading out to the playground</li></ul>
---	---

The DTS provisions of BCA2022 NCC-1 clause F6D6 requires that ventilation of habitable rooms may be via Natural ventilation complying with clause F6D7, or via mechanical ventilation compliant with AS1668.2-2012.

Proposed Playrooms 1, 2 and 3 for the L5 Childcare as shown on the architectural plans, have direct door openings to outdoor space which allows for natural ventilation. But doors are not kept open because the habitable space is airconditioned. That is why mechanical outside air ventilation is typically added to the space to ensure adequate ventilation that is compliant with AS1668.2-2012 is provided.

It is not unusual for Cot rooms to be located internally where there is no direct connection to outside. In this case, and even if natural ventilation may be compliant, mechanical outside air ventilation is provided in compliance with AS1668.2-2012. This is because the Cot room will be airconditioned and any natural openings are not kept open.

Similarly, the DTS provisions of BCA2022 NCC-1 clause F6D6 requires that ventilation of sanitary compartments may be via Natural ventilation complying with clause F6D7, or via mechanical ventilation compliant with AS1668.2-2012. The bathrooms and nappy change areas are typically always ventilated via mechanical exhaust for effective removal of emissions. Make-up air can be provided directly from outside via louvre intakes or via make-up air from inside that is otherwise discharged to outside as relief air.

The proposed Childcare can be readily ventilated to comply with the DTS requirements of the BCA. The details of the ventilation will be provided during the CC stage.



In relation to council query of food businesses, I confirm that commercial Kitchen ventilation for food and beverage areas have been considered in the planning, and adequate spatials have been incorporated. All commercial kitchen ventilation will be compliant with BCA 2022 NCC-1 clause F6D12 and referenced AS1668.2-2012. Full details will be provided during the CC stage.

In relation to exhaust ventilation discharge locations, I confirm that all exhaust discharges have been considered during the planning stage and provisions made to ensure full compliance with AS1688.2-2012 including part 3.10- AIR DISCHARGES. Full details will be provided during the CC stage.