

ANNEXURE 3

ADG Assessment

ADG Ref Item description	Proposal	Compliance
PART 3 Siting the development		
<p><i>Objective 3A-1</i></p> <p>Site analysis illustrates that design decisions have been based on opportunities and constraints of the site conditions and their relationship to the surrounding context</p> <p>Design guidance</p> <p>Each element in the Site Analysis Checklist should be addressed (see Appendix 1)</p>	<p>The proposal has provided a detailed Site Analysis which demonstrates good design decisions have been made in relation to the site-specific context.</p>	Yes
3B Orientation		
<p><i>Objective 3B-1</i></p> <p>Building types and layouts respond to the streetscape and site while optimising solar access within the development</p> <p>Design guidance</p> <p>Buildings along the street frontage define the street, by facing it and incorporating direct access from the street (see figure 3B.1)</p> <p>Where the street frontage is to the east or west, rear buildings should be orientated to the north</p> <p>Where the street frontage is to the north or south, overshadowing to the south should be minimised and buildings behind the street frontage should be orientated to the east and west (see figure 3B.2)</p>	<p>Provided.</p> <p>The proposal is orientated to reflect the street grid and to create a block defining the urban character over the two sites. The proposal provides compliant separation to adjoining future development with overshadowing minimised where possible.</p>	Yes
<p><i>Objective 3B-2</i></p> <p>Overshadowing of neighbouring properties is minimised during mid-winter</p> <p>Design guidance</p> <p>Living areas, private open space and communal open space should receive solar access in accordance with sections 3D Communal and public open space and 4A Solar and daylight access</p> <p>Solar access to living rooms, balconies and private open spaces of neighbours should be considered</p> <p>Where an adjoining property does not currently receive the required hours of solar access, the proposed building ensures solar access to neighbouring properties is not reduced by more than 20%</p>	<p>The proposal is designed in accordance with the masterplan envelopes and minimises the overshadow impact to south neighbouring properties by coordinating with adjacent site the location of habitable rooms.</p>	Yes

ADG Ref Item description	Proposal	Compliance
<p>If the proposal will significantly reduce the solar access of neighbours, building separation should be increased beyond minimums contained in section 3F Visual privacy</p> <p>Overshadowing should be minimised to the south or down-hill by increased upper level setbacks</p> <p>It is optimal to orientate buildings at 90 degrees to the boundary with neighbouring properties to minimise overshadowing and privacy impacts, particularly where minimum setbacks are used and where buildings are higher than the adjoining development</p> <p>A minimum of 4 hours of solar access should be retained to solar collectors on neighbouring buildings</p>	<p>The design proposes appropriate building separation distances to all relevant boundaries and the amended design is fully compliant with DCP setbacks. It would provide a compliant solar access outcome to the immediate neighbours.</p> <p>Orientation reasonable in context of site.</p>	
3C Public domain interface		
<p><i>Objective 3C-1</i></p> <p>Transition between private and public domain is achieved without compromising safety and security</p> <p>Design guidance</p> <p>Terraces, balconies and courtyard apartments should have direct street entry, where appropriate</p> <p>Changes in level between private terraces, front gardens and dwelling entries above the street level provide surveillance and improve visual privacy for ground level dwellings (see figure 3C.1)</p> <p>Upper level balconies and windows should overlook the public domain</p> <p>Front fences and walls along street frontages should use visually permeable materials and treatments. The height of solid fences or walls should be limited to 1m</p> <p>Length of solid walls should be limited along street frontages</p> <p>Opportunities should be provided for casual interaction between residents and the public domain. Design solutions may include seating at building entries, near letter boxes and in private courtyards adjacent to streets</p>	<p>Provided.</p> <p>In this instance street-level activation to all frontages (Marshall, Holdsworth and Berry) is adequately achieved for each dwelling. Individual and Communal entries and individual entries to each ground floor terrace fronting Berry Road and Park Road are clearly defined, safe and secure.</p> <p>Easy-to-navigate pedestrian paths provide secure access egress throughout the site.</p> <p>Changes in levels appropriately managed to achieve relevant outcomes.</p> <p>Provided. Facades and solid walls broken up on all frontages by recessed lift cores to ensure greater articulation.</p> <p>Satisfactory on merit.</p> <p>Appropriately limited and broken up by openings for stairs, landscaping and driveway access.</p>	<p>Yes</p>

ADG Ref Item description	Proposal	Compliance
<p>In developments with multiple buildings and/or entries, pedestrian entries and spaces associated with individual buildings/entries should be differentiated to improve legibility for residents, using a number of the following design solutions:</p> <p>architectural detailing changes in materials plant species colours</p> <p>Opportunities for people to be concealed should be minimised</p>	<p>Activated entries/lobbies to Berry/Holdsworth and the Green Spine would allow for active uses within buildings setback areas.</p> <p>Achieved</p>	

<p><i>Objective 3C-2</i></p> <p>Amenity of the public domain is retained and enhanced</p> <p>Design guidance</p> <p>Planting softens the edges of any raised terraces to the street, for example above sub-basement car parking</p> <p>Mailboxes should be located in lobbies, perpendicular to the street alignment or integrated into front fences where individual street entries are provided</p> <p>The visual prominence of underground car park vents should be minimised and located at a low level where possible</p> <p>Substations, pump rooms, garbage storage areas and other service requirements should be located in basement car parks or out of view</p> <p>Ramping for accessibility should be minimised by building entry location and setting ground floor levels in relation to footpath levels</p> <p>Durable, graffiti resistant and easily cleanable materials should be used</p> <p>Where development adjoins public parks, open space or bushland, the design positively addresses this interface and uses a number of the following design solutions:</p> <ul style="list-style-type: none"> street access, pedestrian paths and building entries which are clearly defined paths, low fences and planting that clearly delineate between communal/private open space and the adjoining public open space minimal use of blank walls, fences and ground level parking 	<p>Satisfactory- public domain enhanced through clearly defined and focal building entries. All services, loading areas and vehicle parking are to be located behind screening (where possible).</p> <p>Provided.</p> <p>Mailbox location conditioned by police comments to be integrated into design. Police recommendation- 'Mailboxes and parcel delivery areas should be secure and covered with CCTV cameras. If possible, a secure method for parcel delivery should be set up in the building'.</p> <p>Achieved where possible. Fire pump room proposed in basement 1. Cold water pump room in basement 2.</p> <p>Ramping minimised where possible</p>	
---	---	--

On sloping sites protrusion of car parking above ground level should be minimised by using split levels to step underground car parking		
Such areas appropriately designed in this instance	Appropriately integrated/treated	Satisfactory
<p>3D Communal and public open space</p> <p><i>Objective 3D-1</i></p> <p>An adequate area of communal open space is provided to enhance residential amenity and to provide opportunities for landscaping</p> <p>Design criteria</p> <ol style="list-style-type: none"> Communal open space has a minimum area equal to 25% of the site (see figure 3D.3) Developments achieve a minimum of 50% direct sunlight to the principal usable part of the communal open space for a minimum of 2 hours between 9 am and 3 pm on 21 June (mid-winter) <p>Design guidance</p> <p>Communal open space should be consolidated into a well-designed, easily identified and usable area</p> <p>Communal open space should have a minimum dimension of 3m, and larger developments should consider greater dimensions</p> <p>Communal open space should be co-located with deep soil areas</p> <p>Direct, equitable access should be provided to communal open space areas from common circulation areas, entries and lobbies</p> <p>Where communal open space cannot be provided at ground level, it should be provided on a podium or roof</p> <p>Where developments are unable to achieve the design criteria, such as on small lots, sites within business zones, or in a dense urban area, they should:</p> <ul style="list-style-type: none"> provide communal spaces elsewhere such as a landscaped roof top terrace or a common room provide larger balconies or increased private open space for apartments demonstrate good proximity to public open space and facilities and/or provide contributions to public open space 	<p>Appropriate common open space areas provided throughout the development where possible in green spine and on roof tops.</p> <p>2215.7 sqm of communal open space Total = 38% Achieved</p> <p>Greater than 50% of total communal open space (Green Spine) and the roof top open space areas to Area 13 receiving 2 hours solar access during mid-winter.</p> <p>Complies. Provided consolidated areas of communal open space at green spine and roof of all Area 13.</p> <p>The proposal provides for dimensions significantly greater than the ADG minimum.</p> <p>Provided: Greater than 50% of green spine communal area at ground floor is unencumbered deep soil (894.8sqm).</p> <p>Green spine and communal roof garden areas on Area 13 accessed by lift and accessible paths.</p> <p>Complies.</p> <p>Communal space provided a ground level and roof top of Area 13.</p> <p>Design Criteria Achieved.</p>	

<p>Objective 3D-2</p> <p>Communal open space is designed to allow for a range of activities, respond to site conditions and be attractive and inviting</p> <p>Design guidance</p> <p>Facilities are provided within communal open spaces and common spaces for a range of age groups (see also 4F Common circulation and spaces), incorporating some of the following elements:</p> <p>seating for individuals or groups barbecue areas play equipment or play areas swimming pools, gyms, tennis courts or common rooms</p> <p>The location of facilities responds to microclimate and site conditions with access to sun in winter, shade in summer and shelter from strong winds and down drafts</p> <p>Visual impacts of services should be minimised, including location of ventilation duct outlets from basement car parks, electrical substations and detention tanks</p>	<p>The proposal provides high quality facilities, which would promote a range of passive and active uses.</p> <p>GREEN SPINE: Facilities provided include landscaping, alfresco dining/ BBQ, lounge seating, open lawn with picnic tables and pergolas above, water fountains and waste bins.</p> <p>ROOF TOP: communal vegetable patch and nature trail, dining and lounge area, BBQs, communal exercise area, library area, pergola shade structures, and landscaping.</p> <p>Achieved.</p> <p>Achieved.</p>	<p>Yes</p>
<p>Objective 3D-3</p> <p>Communal open space is designed to maximise safety</p> <p>Design guidance</p> <p>Communal open space and the public domain should be readily visible from habitable rooms and private open space areas while maintaining visual privacy. Design solutions may include:</p> <p>bay windows corner windows balconies</p> <p>Communal open space should be well lit</p> <p>Where communal open space/facilities are provided for children and young people they are safe and contained</p>	<p>The proposed communal open space would be secure for residents only.</p> <p>Green Spine would be readily visible from all units facing allowing appropriate passive surveillance.</p> <p>Can comply.</p> <p>All areas within the green spine which is secure to residents only.</p>	<p>Yes</p>
<p>3D Communal and public open space</p>		
<p>Objective 3D-4</p> <p>Public open space, where provided, is responsive to the existing pattern and uses of the neighbourhood</p> <p>Design guidance</p> <p>The public open space should be well connected with public streets along at least one edge</p>	<p>N/A. No public open space required.</p> <p>N/A. No public open space required.</p>	<p>N/A</p>

<p>The public open space should be connected with nearby parks and other landscape elements</p> <p>Public open space should be linked through view lines, pedestrian desire paths, termination points and the wider street grid</p> <p>Solar access should be provided year-round along with protection from strong winds</p> <p>Opportunities for a range of recreational activities should be provided for people of all ages</p> <p>A positive address and active frontages should be provided adjacent to public open space</p> <p>Boundaries should be clearly defined between public open space and private areas</p>	<p>Sun access diagrams display solar access achieved to at least 2 hours, more than 50% of the public open space</p> <p>Larger vegetation around the perimeter of roof top also provides wind protection.</p>																
<p>3E Deep soil zones</p>																	
<p>Deep soil zones provide areas on the site that allow for and support healthy plant and tree growth. They improve residential amenity and promote management of water and air quality.</p>	<p>The proposal provides for high quality deep soil zones where possible and its entirety under the green spine. Greater than 50% of the green spine has no basement carparking encroachments.</p>	<p>Yes</p>															
<p>Design criteria</p> <p>1. Deep soil zones are to meet the following minimum requirements:</p> <table border="1" data-bbox="86 1108 719 1480"> <thead> <tr> <th>Site area</th><th>Minimum dimensions</th><th>Deep soil zone (% of site area)</th></tr> </thead> <tbody> <tr> <td>less than 650m²</td><td>-</td><td>7%</td></tr> <tr> <td>650m² - 1,500m²</td><td>3m</td><td></td></tr> <tr> <td>greater than 1,500m²</td><td>6m</td><td></td></tr> <tr> <td>greater than 1,500m² with significant existing tree cover</td><td>6m</td><td></td></tr> </tbody> </table>	Site area	Minimum dimensions	Deep soil zone (% of site area)	less than 650m ²	-	7%	650m ² - 1,500m ²	3m		greater than 1,500m ²	6m		greater than 1,500m ² with significant existing tree cover	6m		<p>Greater than 50% of green spine achieves deep soil + deep soil in Marshall/Berry/Holdsworth Avenue setbacks.</p> <p>Total = 24% of site is deep soil. (1383.6sqm)</p>	<p>Yes</p>
Site area	Minimum dimensions	Deep soil zone (% of site area)															
less than 650m ²	-	7%															
650m ² - 1,500m ²	3m																
greater than 1,500m ²	6m																
greater than 1,500m ² with significant existing tree cover	6m																
<p>Design guidance</p> <p>On some sites it may be possible to provide larger deep soil zones, depending on the site area and context:</p> <p>10% of the site as deep soil on sites with an area of 650m² - 1,500m²</p> <p>15% of the site as deep soil on sites greater than 1,500m²</p> <p>Deep soil zones should be located to retain existing significant trees and to allow for the development of healthy root systems, providing anchorage and stability for mature trees. Design solutions may include:</p> <p>basement and sub-basement car park design that is consolidated beneath building footprints</p> <p>use of increased front and side setbacks</p>	<p>Achieved where possible - see above</p> <p>The proposed landscaping conditions of consent to establish and strengthen the deep soil zones for long term health of vegetation.</p>	<p>Yes</p>															

<p>adequate clearance around trees to ensure long term health</p> <p>co-location with other deep soil areas on adjacent sites to create larger contiguous areas of deep soil</p> <p>Achieving the design criteria may not be possible on some sites including where:</p> <p>the location and building typology have limited or no space for deep soil at ground level (e.g. central business district, constrained sites, high density areas, or in centres)</p> <p>there is 100% site coverage or non-residential uses at ground floor level</p> <p>Where a proposal does not achieve deep soil requirements, acceptable stormwater management should be achieved, and alternative forms of planting provided such as on structure</p>	Achieved																	
<p>3F Visual privacy</p> <p><i>Objective 3F-1</i> Adequate building separation distances are shared equitably between neighbouring sites, to achieve reasonable levels of external and internal visual privacy</p> <p>Design criteria</p> <p>1. Separation between windows and balconies is provided to ensure visual privacy is achieved. Minimum required separation distances from buildings to the side and rear boundaries are as follows:</p> <table><tr><td>Building height</td><td>Habitable rooms and balconies</td><td>Habitable to non-habitable rooms</td><td>Non-habitable rooms</td></tr><tr><td>up to 12m (4 storeys)</td><td>6m</td><td>4.5m</td><td>3m</td></tr><tr><td>up to 25m (5-8 storeys)</td><td>9m</td><td>6m</td><td>4.5m</td></tr><tr><td>over 25m (9+ storeys)</td><td>12m</td><td>9m</td><td>6m</td></tr></table> <p>Design guidance</p> <p>Generally one step in the built form as the height increases due to building separations is desirable. Additional steps should be careful not to cause a 'ziggurat' appearance</p> <p>For residential buildings next to commercial buildings, separation distances should be measured as follows:</p> <p>for retail, office spaces and commercial balconies use the habitable room distances</p>	Building height	Habitable rooms and balconies	Habitable to non-habitable rooms	Non-habitable rooms	up to 12m (4 storeys)	6m	4.5m	3m	up to 25m (5-8 storeys)	9m	6m	4.5m	over 25m (9+ storeys)	12m	9m	6m	<p>Provided</p> <p>Compliance achieved. Building separations will exceed ADG requirements across all streets.</p> <p>All buildings are stepped as per the DCP requirements. All buildings exceed separation distance requirements of the ADG.</p> <p>N/A</p>	Complies
Building height	Habitable rooms and balconies	Habitable to non-habitable rooms	Non-habitable rooms															
up to 12m (4 storeys)	6m	4.5m	3m															
up to 25m (5-8 storeys)	9m	6m	4.5m															
over 25m (9+ storeys)	12m	9m	6m															

<p>for service and plant areas use the non-habitable room distances</p> <p>New development should be located and oriented to maximise visual privacy between buildings on site and for neighbouring buildings. Design solutions include:</p> <p>site layout and building orientation to minimise privacy impacts (see also section 3B Orientation) on sloping sites, apartments on different levels have appropriate visual separation distances (see figure 3F.4)</p> <p>Apartment buildings should have an increased separation distance of 3m (in addition to the requirements set out in design criteria 1) when adjacent to a different zone that permits lower density residential development to provide for a transition in scale and increased landscaping (figure 3F.5)</p> <p>Direct lines of sight should be avoided for windows and balconies across corners</p> <p>No separation is required between blank walls</p>	<p>Satisfactory.</p> <p>N/A.</p> <p>Avoided where possible</p> <p>Provided.</p>	
<p>Objective 3F-2</p> <p>Site and building design elements increase privacy without compromising access to light and air and balance outlook and views from habitable rooms and private open space</p> <p>Design guidance</p> <p>Communal open space, common areas and access paths should be separated from private open space and windows to apartments, particularly habitable room windows. Design solutions may include:</p> <p>setbacks</p> <ul style="list-style-type: none"> • solid or partially solid balustrades to balconies at lower levels • fencing and/or trees and vegetation to separate spaces • screening devices • bay windows or pop out windows to provide privacy in one direction and outlook in another • raising apartments/private open space above the public domain or communal open space • planter boxes incorporated into walls and balustrades to increase visual separation • pergolas or shading devices to limit overlooking of lower apartments or private open space on constrained sites where it can be demonstrated that building layout opportunities are 	<p>Appropriately considered in design.</p> <p>Communal open space is appropriately separated</p> <p>Solid and partially solid balustrades (aluminum powder coated batterns) and landscaping buffers incorporated into design of balconies at lower levels, including 1m high planter boxes. These measures ensure an appropriate balance of privacy and activation between the interface of the private balconies fronting the green spine at ground floor.</p>	<p>Yes</p>

<p>limited, fixed louvres or screen panels to windows and/or balconies</p> <p>Bedrooms, living spaces and other habitable rooms should be separated from gallery access and other open circulation space by the apartment's service areas</p> <p>Balconies and private terraces should be located in front of living rooms to increase internal privacy</p> <p>Windows should be offset from the windows of adjacent buildings</p> <p>Recessed balconies and/or vertical fins should be used between adjacent balconies</p>	<p>Balconies and terraces are located adjacent to living rooms rather than bedrooms.</p> <p>Clear glass balustrade with aluminum frames. Provided where possible.</p> <p>Generally, complies.</p>	
3G Pedestrian access and entries		
<p><i>Objective 3G-1</i></p> <p>Building entries and pedestrian access connects to and addresses the public domain</p> <p>Design guidance</p> <p>Multiple entries (including communal building entries and individual ground floor entries) should be provided to activate the street edge</p> <p>Entry locations relate to the street and subdivision pattern and the existing pedestrian network</p> <p>Building entries should be clearly identifiable and communal entries should be clearly distinguishable from private entries</p> <p>Where street frontage is limited and multiple buildings are located on the site, a primary street address should be provided with clear sight lines and pathways to secondary building entries</p>	<p>Accessible connectivity provided addressing public domain from Marshall Avenue, Berry Road and Holdsworth Avenue.</p> <p>The proposal provides lobby/lift entrance with accessible entrances, improving street activation at Berry Road and Holdsworth Avenue in accordance with the ADG along with separate entrances to between private and public access.</p> <p>Satisfactory</p> <p>Satisfactory.</p> <p>Satisfactory.</p>	Yes
<p><i>Objective 3G-2</i></p> <p>Access, entries and pathways are accessible and easy to identify</p> <p>Design guidance</p> <p>Building access areas including lift lobbies, stairwells and hallways should be clearly visible from the public domain and communal spaces</p> <p>The design of ground floors and underground car parks minimise level changes along pathways and entries</p> <p>Steps and ramps should be integrated into the overall building and landscape design.</p>	<p>Provided.</p> <p>Clearly visible primary pedestrian access to Holdsworth Avenue and Berry Road with lifts, ramps and stairs, and within the basement parking areas.</p> <p>Satisfactory.</p> <p>Highly integrated into landscape design with no bends or returns and maximise potential for landscaping.</p>	Yes

<p>For large developments 'way finding' maps should be provided to assist visitors and residents (see figure 4T.3)</p> <p>For large developments electronic access and audio/video intercom should be provided to manage access</p>	<p>Would be provided, if required.</p> <p>Would be provided, if required.</p>	
<p>Objective 3G-3</p> <p>Large sites provide pedestrian links for access to streets and connection to destinations</p> <p>Design guidance</p> <p>Pedestrian links through sites facilitate direct connections to open space, main streets, centres and public transport</p> <p>Pedestrian links should be direct, have clear sight lines, be overlooked by habitable rooms or private open spaces of dwellings, be well lit and contain active uses, where appropriate</p>	<p>No east-west pedestrian link is proposed to the south of Area 15. The link would enable greater pedestrian access and connections through the site between Holdsworth Avenue to Berry Road.</p> <p>The link with pedestrian footpaths either side would have clear sightlines, is viewed by habitable rooms of buildings with Areas 14 and 15 and would be well lit.</p>	Yes
3H Vehicle access		
<p>Objective 3H-1</p> <p>Vehicle access points are designed and located to achieve safety, minimise conflicts between pedestrians and vehicles and create high quality streetscapes</p> <p>Design guidance</p> <p>Car park access should be integrated with the building's overall facade. Design solutions may include:</p> <p>the materials and colour palette to minimise visibility from the street</p> <p>security doors or gates at entries that minimise voids in the facade</p> <p>where doors are not provided, the visible interior reflects the facade design and the building services, pipes and ducts are concealed</p> <p>Car park entries should be located behind the building line</p> <p>Vehicle entries should be located at the lowest point of the site minimising ramp lengths, excavation and impacts on the building form and layout</p> <p>Car park entry and access should be located on secondary streets or lanes where available</p> <p>Vehicle standing areas that increase driveway width and encroach into setbacks should be avoided</p> <p>Access point locations should avoid headlight glare to habitable rooms</p>	<p>Complies</p> <p>Vehicular access point off southern end of Holdsworth Avenue and integrated with the proposed design.</p> <p>Not possible in this instance.</p> <p>Provided at the near the lowest point on Holdsworth Avenue Road.</p> <p>Complies</p> <p>No vehicle standing areas proposed. Appropriate driveway widths to be maintained where possible and is satisfactory.</p> <p>Access point is double height opening. Headlight glare avoided.</p>	Yes

<p>Adequate separation distances should be provided between vehicle entries and street intersections</p> <p>The width and number of vehicle access points should be limited to the minimum</p> <p>Visual impact of long driveways should be minimised through changing alignments and screen planting</p> <p>The need for large vehicles to enter or turn around within the site should be avoided</p> <p>Garbage collection, loading and servicing areas are screened</p> <p>Clear sight lines should be provided at pedestrian and vehicle crossings</p> <p>Traffic calming devices such as changes in paving material or textures should be used where appropriate</p> <p>Pedestrian and vehicle access should be separated and distinguishable. Design solutions may include:</p> <p>changes in surface materials, level changes the use of landscaping for separation</p>	<p>Assessed by Council's Traffic Section as being adequate.</p> <p>Limited to one vehicle access point from Holdsworth Avenue and supported by Council's Traffic officers.</p> <p>External Driveway is only 4m long. Satisfactorily designed.</p> <p>Occurs within basement and appropriately designed for.</p> <p>Garbage collection loading and servicing screened within the basement area.</p> <p>Capable of complying</p> <p>Not required.</p> <p>Pedestrian and vehicle access adequately separated and are clearly distinguishable.</p> <p>Provided.</p>	
<p>3J Bicycle and car parking</p>		
<p>Objective 3J-1</p> <p>Car parking is provided based on proximity to public transport in metropolitan Sydney and centres in regional areas</p> <p>Design criteria</p> <p>For development in the following</p> <p>1. locations:</p> <p>on sites that are within 800 metres of a railway station or light rail stop in the Sydney Metropolitan Area; or</p> <p>on land zoned, and sites within 400 metres of land zoned, B3 Commercial Core, B4 Mixed Use or equivalent in a nominated regional centre</p>	<p>Parking provided in accordance with Council's DCP rather than the ADG.</p>	<p>Yes</p>

<p>the minimum car parking requirement for residents and visitors is set out in the Guide to Traffic Generating Developments, or the car parking requirement prescribed by the relevant council, whichever is less</p> <p>The car parking needs for a development must be provided off street</p> <p>Design guidance</p> <p>Where a car share scheme operates locally, provide car share parking spaces within the development. Car share spaces, when provided, should be on site</p> <p>Where less car parking is provided in a development, council should not provide on street resident parking permits</p>		
<p>Objective 3J-2</p> <p>Parking and facilities are provided for other modes of transport</p> <p>Design guidance</p> <p>Conveniently located and sufficient numbers of parking spaces should be provided for motorbikes and scooters</p> <p>Secure undercover bicycle parking should be provided that is easily accessible from both the public domain and common areas</p> <p>Conveniently located charging stations are provided for electric vehicles, where desirable</p>	<p>Suitable additional other modes of transport are available including bicycles and motorcycles.</p> <p>The development includes 36 motorcycle parking spaces</p> <p>47 bicycle parking spaces are proposed for residents and 20 bicycle parking spaces are proposed for visitors. Spaces located in lower ground floor basement. Level 01 basement, and Level 02 basement.</p>	Yes
<p>Objective 3J-3</p> <p>Car park design and access is safe and secure</p> <p>Design guidance</p> <p>Supporting facilities within car parks, including garbage, plant and switch rooms, storage areas and car wash bays can be accessed without crossing car parking spaces</p> <p>Direct, clearly visible and well-lit access should be provided into common circulation areas</p> <p>A clearly defined and visible lobby or waiting area should be provided to lifts and stairs</p> <p>For larger car parks, safe pedestrian access should be clearly defined and circulation</p>	<p>Car park design has been reviewed and is consistent with Objective 3J-3 to provide for safe and secure access.</p>	Yes

areas have good lighting, colour, line marking and/or bollards		
<p>Objective 3J-4</p> <p>Visual and environmental impacts of underground car parking are minimised</p> <p>Design guidance</p> <p>Excavation should be minimised through efficient car park layouts and ramp design</p> <p>Car parking layout should be well organised, using a logical, efficient structural grid and double loaded aisles</p> <p>Protrusion of car parks should not exceed 1m above ground level. Design solutions may include stepping car park levels or using split levels on sloping sites</p> <p>Natural ventilation should be provided to basement and sub-basement car parking areas</p> <p>Ventilation grills or screening devices for car parking openings should be integrated into the facade and landscape design</p>	<p>Underground carpark is well integrated with building and not visible from the public domain.</p> <p>Utilises existing basement/car parking layout where possible.</p> <p>The parking layout is well-designed and double loaded aisles provided where possible.</p> <p>N/A</p> <p>Ventilation would be detailed at Construction Certificate stage.</p> <p>Achieved</p>	Yes
<p>Objective 3J-5</p> <p>Visual and environmental impacts of on-grade car parking are minimised</p> <p>Design guidance</p> <p>On-grade car parking should be avoided</p> <p>Where on-grade car parking is unavoidable, the following design solutions are used:</p> <p>parking is located on the side or rear of the lot away from the primary street frontage</p> <p>cars are screened from view of streets, buildings, communal and private open space areas</p> <p>safe and direct access to building entry points is provided</p> <p>parking is incorporated into the landscape design of the site, by extending planting and materials into the car park space</p> <p>stormwater run-off is managed appropriately from car parking surfaces</p> <p>bio-swales, rain gardens or on-site detention tanks are provided, where appropriate</p> <p>light coloured paving materials or permeable paving systems are used and shade trees are planted between every 4-5 parking spaces to reduce increased surface temperatures from large areas of paving</p>	<p>No on-grade parking is proposed</p>	N/A
<p>Objective 3J-6</p> <p>Visual and environmental impacts of above ground enclosed car parking are minimised</p>	<p>No above ground parking is proposed</p>	N/A

<p>Design guidance</p> <p>Exposed parking should not be located along primary street frontages</p> <p>Screening, landscaping and other design elements including public art should be used to integrate the above ground car parking with the facade. Design solutions may include:</p> <p>car parking that is concealed behind the facade, with windows integrated into the overall facade design (approach should be limited to developments where a larger floor plate podium is suitable at lower levels)</p> <p>car parking that is 'wrapped' with other uses, such as retail, commercial or two storey Small Office/Home Office (SOHO) units along the street frontage (see figure 3J.9)</p> <p>Positive street address and active frontages should be provided at ground level</p>	No on-grade parking is proposed	
--	---------------------------------	--

ADG Ref	Item description	Proposal	Compliance
PART 4 Designing the building			
4A Solar and daylight access			
	<p><i>Objective 4A-1</i></p> <p>To optimise the number of apartments receiving sunlight to habitable rooms, primary windows and private open space</p> <p>Design criteria</p> <p>1. Living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 2 hours direct sunlight between 9 am and 3 pm at mid-winter in the Sydney Metropolitan Area and in the Newcastle and Wollongong local government areas</p> <p>2. In all other areas, living rooms and private open spaces of at least 70% of apartments in a building receive a minimum of 3 hours direct sunlight between 9 am and 3 pm at mid-winter</p> <p>3. A maximum of 15% of apartments in a building receive no direct sunlight between 9 am and 3 pm at mid-winter</p> <p>Design guidance</p> <p>The design maximises north aspect and the number of single aspect south facing apartments is minimised</p> <p>Single aspect, single storey apartments should have a northerly or easterly aspect</p> <p>Living areas are best located to the north and service areas to the south and west of apartments</p>	<p>The proposal provides for the following:</p> <p>72% apartments exceed a compliant 2 hours solar access to Living rooms and POS during mid-winter between 9am and 3pm.</p> <p>Complies</p> <p>2% overall. Complies.</p> <p>South facing apartments avoided where possible. Positioning windows face southern building that will reflect light</p> <p>In line with ADG design criteria.</p> <p>Satisfactory</p>	Yes

ADG Ref Item description	Proposal	Compliance
<p>To optimise the direct sunlight to habitable rooms and balconies a number of the following design features are used:</p> <ul style="list-style-type: none"> . dual aspect apartments . shallow apartment layouts . two storey and mezzanine level apartments . bay windows <p>To maximise the benefit to residents of direct sunlight within living rooms and private open spaces, a minimum of 1m² of direct sunlight, measured at 1m above floor level, is achieved for at least 15 minutes</p> <p>Achieving the design criteria may not be possible on some sites. This includes:</p> <ul style="list-style-type: none"> . where greater residential amenity can be achieved along a busy road or rail line by orientating the living rooms away from the noise source . on south facing sloping sites . where significant views are oriented away from the desired aspect for direct sunlight <p>Design drawings need to demonstrate how site constraints and orientation preclude meeting the design criteria and how the development meets the objective</p>	<p>The proposal provides for a high number of dual aspect apartments where possible.</p> <p>Provided</p> <p>Provided.</p>	
<p><i>Objective 4A-2</i></p> <p>Daylight access is maximised where sunlight is limited</p> <p>Design guidance</p> <p>Courtyards, skylights and high-level windows (with sills of 1,500mm or greater) are used only as a secondary light source in habitable rooms</p> <p>Where courtyards are used:</p> <p>use is restricted to kitchens, bathrooms and service areas</p> <p>building services are concealed with appropriate detailing and materials to visible walls</p> <p>courtyards are fully open to the sky</p> <p>access is provided to the light well from a communal area for cleaning and maintenance</p> <p>acoustic privacy, fire safety and minimum privacy separation distances (see section 3F Visual privacy) are achieved</p> <p>Opportunities for reflected light into apartments are optimised through:</p> <p>reflective exterior surfaces on buildings opposite south facing windows</p> <p>positioning windows to face other buildings or surfaces (on neighbouring sites or within the site) that will reflect light</p> <p>integrating light shelves into the design</p> <p>light coloured internal finishes</p>	<p>Achieved – high level windows on levels 7 – 10 and levels, 1 and 2 on southern side of Area 13 and northern elevation of Area 15 to provide secondary light source. Primary light source from full height glass sliding doors of adjoining balconies.</p> <p>Ground floor courtyards are generally open to the sky.</p> <p>Can comply.</p> <p>Reflected light is optimised where possible. Including high reflectivity ('Cool Roofing')</p>	<p>Yes</p>
<p><i>Objective 4A-3</i></p>		<p>Yes</p>

ADG Ref Item description	Proposal	Compliance
<p>Design incorporates shading and glare control, particularly for warmer months</p> <p>Design guidance</p> <p>A number of the following design features are used:</p> <p>balconies or sun shading that extend far enough to shade summer sun, but allow winter sun to penetrate living areas</p> <p>shading devices such as eaves, awnings, balconies, pergolas, external louvres and planting</p> <p>horizontal shading to north facing windows</p> <p>vertical shading to east and particularly west facing windows</p> <p>operable shading to allow adjustment and choice</p> <p>high performance glass that minimises external glare off windows, with consideration given to reduced tint glass or glass with a reflectance level below 20% (reflective films are avoided)</p>	<p>Passive solar shading has been incorporated into the design, such as vertical louvres and screens, vertical blade walls, privacy screens and balconies.</p>	
4B Natural ventilation		
<p><i>Objective 4B-1</i></p> <p>All habitable rooms are naturally ventilated</p> <p>Design guidance</p> <p>The building's orientation maximises capture and use of prevailing breezes for natural ventilation in habitable rooms</p> <p>Depths of habitable rooms support natural ventilation</p> <p>The area of unobstructed window openings should be equal to at least 5% of the floor area served</p> <p>Light wells are not the primary air source for habitable rooms</p> <p>Doors and openable windows maximise natural ventilation opportunities by using the following design solutions:</p> <p>adjustable windows with large effective openable areas</p> <p>a variety of window types that provide safety and flexibility such as awnings and louvres</p> <p>windows which the occupants can reconfigure to funnel breezes into the apartment such as vertical louvres, casement windows and externally opening doors</p>	<p>Provided where possible.</p> <p>All habitable rooms have openable windows or doors.</p> <p>Compliant. Apartment depths are limited to 12m for open plan layout to maximise airflow.</p> <p>Provided.</p> <p>Provided.</p> <p>Not relied upon.</p> <p>Large openable areas provided to apartments on all elevations to maximise natural ventilation.</p>	<p>Yes</p>
<p><i>Objective 4B-2</i></p> <p>The layout and design of single aspect apartments maximises natural ventilation</p> <p>Design guidance</p>	<p>Depth minimised in accordance with ratio for single aspect apartments, to maximise natural ventilation.</p>	<p>Yes</p>

<p>Apartment depths are limited to maximise ventilation and airflow (see also figure 4D.3)</p> <p>Natural ventilation to single aspect apartments is achieved with the following design solutions:</p> <p>primary windows are augmented with plenums and light wells (generally not suitable for cross ventilation)</p> <p>stack effect ventilation / solar chimneys or similar to naturally ventilate internal building areas or rooms such as bathrooms and laundries</p> <p>courtyards or building indentations have a width to depth ratio of 2:1 or 3:1 to ensure effective air circulation and avoid trapped smells</p>		
<p>Objective 4B-3</p> <p>The number of apartments with natural cross ventilation is maximised to create a comfortable indoor environment for residents</p> <p>Design criteria</p> <p>1. At least 60% of apartments are naturally cross ventilated in the first nine storeys of the building. Apartments at ten storeys or greater are deemed to be cross ventilated only if any enclosure of the balconies at these levels allows adequate natural ventilation and cannot be fully enclosed</p> <p>1. Overall depth of a cross-over or cross-through apartment does not exceed 18m, measured glass line to glass line</p> <p>Design guidance</p> <p>The building should include dual aspect apartments, cross through apartments and corner apartments and limit apartment depths</p> <p>In cross-through apartments external window and door opening sizes/areas on one side of an apartment (inlet side) are approximately equal to the external window and door opening sizes/areas on the other side of the apartment (outlet side) (see figure 4B.4)</p> <p>Apartments are designed to minimise the number of corners, doors and rooms that might obstruct airflow</p> <p>Apartment depths, combined with appropriate ceiling heights, maximise cross ventilation and airflow</p>	<p>63% of apartments directly achieved cross-ventilation compliance based on the ADG design criteria.</p> <p>Cross over units do not exceed 18m glass line to glass line.</p> <p>Achieved where possible.</p> <p>Achieved.</p> <p>Achieved where possible.</p> <p>Achieved</p>	Yes
<p>Objective 4C-1</p> <p>Ceiling height achieves sufficient natural ventilation and daylight access</p>	Achieved. 3.2m floor to floor heights achieved	Yes
<p>Design criteria</p> <p>1. Measured from finished floor level to finished ceiling level, minimum ceiling heights are:</p>		
<p>Minimum ceiling height 2.7m (residential) 3.3m commercial</p>	<p>3.2m floor to floor heights achieved.</p> <p>Minimum 2.7m for habitable.</p>	Yes

	Minimum 2.4m for non-habitable.													
<p><i>Objective 4C-2</i></p> <p>Ceiling height increases the sense of space in apartments and provides for well-proportioned rooms</p> <p>Design guidance</p> <p>A number of the following design solutions can be used:</p> <p>the hierarchy of rooms in an apartment is defined using changes in ceiling heights and alternatives such as raked or curved ceilings, or double height spaces well-proportioned rooms are provided, for example, smaller rooms feel larger and more spacious with higher ceilings</p> <p>ceiling heights are maximised in habitable rooms by ensuring that bulkheads do not intrude. The stacking of service rooms from floor to floor and coordination of bulkhead location above non-habitable areas, such as robes or storage, can assist.</p>	Proposal exceeds the minimum floor to ceiling heights of the ADG.	Yes												
<p><i>Objective 4C-3</i></p> <p>Ceiling heights contribute to the flexibility of building use over the life of the building</p> <p>Design guidance</p> <p>Ceiling heights of lower level apartments in centres should be greater than the minimum required by the design criteria allowing flexibility and conversion to non-residential uses (see figure 4C.1)</p>	Provided.	Yes												
4D Apartment size and layout														
<p><i>Objective 4D-1</i></p> <p>The layout of rooms within an apartment is functional, well organised and provides a high standard of amenity</p>	Provided.	Yes												
<p>Design criteria</p> <p>1. Apartments are required to have the following minimum internal areas:</p>														
<table><tr><td>Apartment type</td><td>Minimum internal area</td></tr><tr><td>Studio</td><td>35m2</td></tr><tr><td>1 bedroom</td><td>50m2</td></tr><tr><td>2 bedroom</td><td>70m2</td></tr><tr><td>3 bedroom</td><td>90m2</td></tr><tr><td>4 bedroom</td><td>102m2</td></tr></table>	Apartment type	Minimum internal area	Studio	35m2	1 bedroom	50m2	2 bedroom	70m2	3 bedroom	90m2	4 bedroom	102m2	The proposed apartment sizes are consistent with the minimum apartment sizes and are exceeded.	Yes
Apartment type	Minimum internal area													
Studio	35m2													
1 bedroom	50m2													
2 bedroom	70m2													
3 bedroom	90m2													
4 bedroom	102m2													
<p>The minimum internal areas include only one bathroom. Additional bathrooms increase the minimum internal area by 5m2 sqm each</p> <p>A fourth bedroom and further additional bedrooms increase the minimum internal area by 1 sqm each.</p>	Achieved	Yes												
<p>Every habitable room must have a window in an external wall with a total minimum glass area of not</p>	Provided. There is no borrowed light to habitable room.	Yes												

<p>less than 10% of the floor area of the room. Daylight and air may not be borrowed from other rooms</p> <p>Design guidance</p> <p>Kitchens should not be located as part of the main circulation space in larger apartments (such as hallway or entry space)</p> <p>A window should be visible from any point in a habitable room</p> <p>Where minimum areas or room dimensions are not met apartments need to demonstrate that they are well designed and demonstrate the usability and functionality of the space with realistically scaled furniture layouts and circulation areas. These circumstances would be assessed on their merits</p>	<p>Provided where possible.</p> <p>Provided where possible.</p> <p>N/A. Minimum areas and dimensions have been met.</p>	
<p>Objective 4D-2</p> <p>Environmental performance of the apartment is maximised</p> <p>Design criteria</p> <p>Habitable room depths are limited to a maximum of 2.5 x the ceiling height</p> <p>In open plan layouts (where the living, dining and kitchen are combined) the maximum habitable room depth is 8m from a window</p> <p>Design guidance</p> <p>Greater than minimum ceiling heights can allow for proportional increases in room depth up to the permitted maximum depths</p> <p>All living areas and bedrooms should be located on the external face of the building</p>	<p>Provided. Consistent with ADG Requirements.</p> <p>Where possible, apartment depths are limited to 8m for open plan layout measured from a window.</p> <p>Noted.</p>	Yes
<p>Objective 4D-3</p> <p>Apartment layouts are designed to accommodate a variety of household activities and needs</p> <p>Design criteria</p> <ol style="list-style-type: none"> Master bedrooms have a minimum area of 10m² and other bedrooms 9m² (excluding wardrobe space) Bedrooms have a minimum dimension of 3m (excluding wardrobe space) Living rooms or combined living/dining rooms have a minimum width of: <ul style="list-style-type: none"> 3.6m for studio and 1-bedroom apartments 4m for 2 and 3-bedroom apartments The width of cross-over or cross-through apartments are at least 4m internally to avoid deep narrow apartment layouts <p>Design guidance</p>	<p>Provided. Consistent with ADG Requirements.</p> <p>Minimum dimension achieved and shown on plans.</p> <p>Achieved and detailed on plans.</p> <p>Minimum width achieved.</p> <p>Provided where possible.</p> <p>Provided where possible.</p>	Yes

<p>Access to bedrooms, bathrooms and laundries is separated from living areas minimising direct openings between living and service areas</p> <p>All bedrooms allow a minimum length of 1.5m for robes</p> <p>The main bedroom of an apartment or a studio apartment should be provided with a wardrobe of a minimum 1.8m long, 0.6m deep and 2.1m high</p> <p>Apartment layouts allow flexibility over time, design solutions may include:</p> <ul style="list-style-type: none"> • dimensions that facilitate a variety of furniture arrangements and removal • spaces for a range of activities and privacy levels between different spaces within the apartment • dual master apartments • dual key apartments <i>Note: dual key apartments which are separate but on the same title are regarded as two sole occupancy units for the purposes of the Building Code of Australia and for calculating the mix of apartments</i> <p>room sizes and proportions or open plans (rectangular spaces (2:3) are more easily furnished than square spaces (1:1))</p> <p>efficient planning of circulation by stairs, corridors and through rooms to maximise the amount of usable floor space in rooms</p>	<p>Provided.</p> <p>Usable floor area maximised and suitable flexibility in space, with a focus of the layouts provided.</p>																
4E Private open space and balconies																	
<p><i>Objective 4E-1</i></p> <p>Apartments provide appropriately sized private open space and balconies to enhance residential amenity</p>		Yes															
<p>1. All apartments are required to have primary balconies as follows:</p>																	
<table border="1"> <thead> <tr> <th>Dwelling type.</th><th>Minimum area.</th><th>Minimum depth.</th></tr> </thead> <tbody> <tr> <td>Studio</td><td>4m²</td><td>N/A</td></tr> <tr> <td>1 bedroom</td><td>8m²</td><td>2.0m</td></tr> <tr> <td>2 bedroom</td><td>10m²</td><td>2.0m</td></tr> <tr> <td>3 bedroom</td><td>12m²</td><td>2.4m</td></tr> </tbody> </table> <p>The minimum balcony depth to be counted as contributing to the balcony area is 1m</p>	Dwelling type.	Minimum area.	Minimum depth.	Studio	4m ²	N/A	1 bedroom	8m ²	2.0m	2 bedroom	10m ²	2.0m	3 bedroom	12m ²	2.4m	<p>Achieved.</p> <p>Apartments are provided with storage facilities meeting or exceeding the ADG requirements.</p>	Yes
Dwelling type.	Minimum area.	Minimum depth.															
Studio	4m ²	N/A															
1 bedroom	8m ²	2.0m															
2 bedroom	10m ²	2.0m															
3 bedroom	12m ²	2.4m															
<p>2 For apartments at ground level or on a podium or similar structure, a private open space is provided instead of a balcony. It must have a minimum area of 15m² and a minimum depth of 3m</p>	<p>Provided.</p>	Yes															
<p>Design guidance</p> <p>Increased communal open space should be provided where the number or size of balconies are reduced</p>	<p>Not applicable.</p> <p>None proposed.</p>	Yes															

<p>Storage areas on balconies is additional to the minimum balcony size</p> <p>Balcony use may be limited in some proposals by: consistently high wind speeds at 10 storeys and above close proximity to road, rail or other noise sources exposure to significant levels of aircraft noise heritage and adaptive reuse of existing buildings</p> <p>In these situations, juliet balconies, operable walls, enclosed wintergardens or bay windows may be appropriate, and other amenity benefits for occupants should also be provided in the apartments or in the development or both. Natural ventilation also needs to be demonstrated</p>		
<p><i>Objective 4E-2</i></p> <p>Primary private open space and balconies are appropriately located to enhance liveability for residents</p> <p>Design guidance</p> <p>Primary open space and balconies should be located adjacent to the living room, dining room or kitchen to extend the living space</p> <p>Private open spaces and balconies predominantly face north, east or west</p> <p>Primary open space and balconies should be orientated with the longer side facing outwards or be open to the sky to optimise daylight access into adjacent rooms</p>	<p>Appropriately located.</p> <p>Provided.</p> <p>Balconies are located at facade to maximise the daylight access, and directly access from living area, and bedrooms where are possible</p> <p>Provided.</p>	<p>Yes</p>
<p><i>Objective 4E-3</i></p> <p>Private open space and balcony design is integrated into and contributes to the overall architectural form and detail of the building</p> <p>Design guidance</p> <p>Solid, partially solid or transparent fences and balustrades are selected to respond to the location. They are designed to allow views and passive surveillance of the street while maintaining visual privacy and allowing for a range of uses on the balcony. Solid and partially solid balustrades are preferred</p> <p>Full width full height glass balustrades alone are generally not desirable</p> <p>Projecting balconies should be integrated into the building design and the design of soffits considered</p> <p>Operable screens, shutters, hoods and pergolas are used to control sunlight and wind</p> <p>Balustrades are set back from the building or balcony edge where overlooking or safety is an issue</p>	<p>Well integrated.</p> <p>The modulation of the balconies is designed to give greater architectural variation.</p> <p>Combination of balustrading materials proposed.</p> <p>A range of treatments proposed. Glass balustrades at upper level are accompanied by moveable privacy screens for environmental performance.</p> <p>Privacy screens have been provided for the balconies on the northern elevation of area 14 to prevent overlooking to area 12</p> <p>No unduly projected balconies.</p>	<p>Yes</p>

<p>Downpipes and balcony drainage are integrated with the overall facade and building design</p> <p>Air-conditioning units should be located on roofs, in basements, or fully integrated into the building design</p> <p>Where clothes drying, storage or air conditioning units are located on balconies, they should be screened and integrated in the building design</p> <p>Ceilings of apartments below terraces should be insulated to avoid heat loss</p> <p>Water and gas outlets should be provided for primary balconies and private open space</p>	<p>Provided where possible.</p> <p>Suitable landscape buffer or screening provided.</p> <p>Successfully integrated within screened roof top plant enclosure.</p> <p>Achieved. Centralised air conditioning system with units located on roof tops behind screened condenser enclosure.</p> <p>To be screened.</p> <p>Designed in accordance with BASIX.</p> <p>Guidance only.</p>	
---	---	--

<p>Objective 4E-4</p> <p>Private open space and balcony design maximises safety</p> <p>Design guidance</p> <p>Changes in ground levels or landscaping are minimised</p>	<p>Achieved. Balustrades require to be BCA compliant.</p> <p>Achieved where possible on sloping site.</p>	<p>Yes</p>
4F Common circulation and spaces		
<p>Objective 4F-1</p> <p>Common circulation spaces achieve good amenity and properly service the number of apartments</p> <p>Design criteria</p> <p>1. The maximum number of apartments off a circulation core on a single level is eight</p> <p>2. For buildings of 10 storeys and over, the maximum number of apartments sharing a single lift is 40</p> <p>Design guidance</p> <p>Greater than minimum requirements for corridor widths and/ or ceiling heights allow comfortable movement and access particularly in entry lobbies, outside lifts and at apartment entry doors</p> <p>Daylight and natural ventilation should be provided to all common circulation spaces that are above ground</p>	<p>Satisfactory in this instance.</p> <p>Satisfactory in this instance.</p> <p>Achieved where possible.</p> <p>All common lobby corridors have access to natural light.</p>	<p>Yes</p>

<p>Windows should be provided in common circulation spaces and should be adjacent to the stair or lift core or at the ends of corridors</p> <p>Longer corridors greater than 12m in length from the lift core should be articulated. Design solutions may include:</p> <ul style="list-style-type: none"> • a series of foyer areas with windows and spaces for seating • wider areas at apartment entry doors and varied ceiling heights <p>Design common circulation spaces to maximise opportunities for dual aspect apartments, including multiple core apartment buildings and cross over apartments</p> <p>Achieving the design criteria for the number of apartments off a circulation core may not be possible. Where a development is unable to achieve the design criteria, a high level of amenity for common lobbies, corridors and apartments should be demonstrated, including:</p> <ul style="list-style-type: none"> • sunlight and natural cross ventilation in apartments • access to ample daylight and natural ventilation in common circulation spaces • common areas for seating and gathering • generous corridors with greater than minimum ceiling heights • other innovative design solutions that provide high levels of amenity <p>Where design criteria 1 is not achieved, no more than 12 apartments should be provided off a circulation core on a single level</p> <p>Primary living room or bedroom windows should not open directly onto common circulation spaces, whether open or enclosed. Visual and acoustic privacy from common circulation spaces to any other rooms should be carefully controlled</p>	<p>Achieved where possible.</p> <p>Satisfactory. Multiple windows on eastern and southern ends of common corridors.</p> <p>Achieved.</p> <p>Complies.</p>	
<p>Objective 4F-2</p> <p>Common circulation spaces promote safety and provide for social interaction between residents</p> <p>Design guidance</p> <p>Direct and legible access should be provided between vertical circulation points and apartment entries by minimising corridor or gallery length to give short, straight, clear sight lines</p> <p>Tight corners and spaces are avoided</p> <p>Circulation spaces should be well lit at night</p> <p>Legible signage should be provided for apartment numbers, common areas and general wayfinding</p>	<p>Lobby areas are well-designed and secured.</p>	<p>Yes</p>

<p>Incidental spaces, for example space for seating in a corridor, at a stair landing, or near a window are provided</p> <p>In larger developments, community rooms for activities such as owner's corporation meetings or resident use should be provided and are ideally co-located with communal open space</p> <p>Where external galleries are provided, they are more open than closed above the balustrade along their length</p>												
<p>Objective 4G-1</p> <p>Adequate, well designed storage is provided in each apartment</p> <p>Design criteria</p> <p>1. In addition to storage in kitchens, bathrooms and bedrooms, the following storage is provided:</p>	<p>Storage complies.</p>	<p>Yes</p>										
<table><tr><td>Dwelling type</td><td>Storage size volume</td></tr><tr><td>Studio</td><td>4m2</td></tr><tr><td>1 bedroom</td><td>6m2</td></tr><tr><td>2 bedroom</td><td>8m2</td></tr><tr><td>3 bedroom</td><td>10m2</td></tr></table> <p>At least 50% of the required storage is to be located within the apartment.</p>	Dwelling type	Storage size volume	Studio	4m2	1 bedroom	6m2	2 bedroom	8m2	3 bedroom	10m2	<p>Can comply with suitable areas in the basement and within each unit. Built-in storage provided to all bedrooms and living rooms. All units have 50% of the storage internal to the unit.</p>	<p>Yes</p>
Dwelling type	Storage size volume											
Studio	4m2											
1 bedroom	6m2											
2 bedroom	8m2											
3 bedroom	10m2											
<p>Design guidance Storage is accessible from either circulation or living areas. Storage provided on balconies (in addition to the minimum balcony size) is integrated into the balcony design, weather proof and screened from view from the street Left over space such as under stairs is used for storage</p>	<p>Satisfactory.</p>	<p>Yes</p>										
<p>Objective 4G-2</p> <p>Additional storage is conveniently located, accessible and nominated for individual apartments</p> <p>Design guidance</p> <p>Storage not located in apartments is secure and clearly allocated to specific apartments</p> <p>Storage is provided for larger and less frequently accessed items</p> <p>Storage space in internal or basement car parks is provided at the rear or side of car spaces or in cages so that allocated car parking remains accessible</p> <p>If communal storage rooms are provided they should be accessible from common circulation areas of the building</p> <p>Storage not located in an apartment is integrated into the overall building design and is not visible from the public domain</p>	<p>Satisfactory.</p>	<p>Yes</p>										
<p>4H Acoustic privacy</p>												

<p><i>Objective 4H-1</i></p> <p>Noise transfer is minimised through the siting of buildings and building layout</p> <p>Design guidance</p> <p>Adequate building separation is provided within the development and from neighbouring buildings/adjacent uses (see also section 2F Building separation and section 3F Visual privacy)</p> <p>Window and door openings are generally orientated away from noise sources</p> <p>Noisy areas within buildings including building entries and corridors should be located next to or above each other and quieter areas next to or above quieter areas</p> <p>Storage, circulation areas and non-habitable rooms should be located to buffer noise from external sources</p> <p>The number of party walls (walls shared with other apartments) are limited and are appropriately insulated</p> <p>Noise sources such as garage doors, driveways, service areas, plant rooms, building services, mechanical equipment, active communal open spaces and circulation areas should be located at least 3m away from bedrooms</p>	<p>Acoustic privacy addressed as per recommendations of acoustic assessment.</p> <p>Acoustic privacy further addressed- condition added. See conditions F8A and F8B in draft conditions.</p>	<p>Yes</p>
<p><i>Objective 4H-2</i></p> <p>Noise impacts are mitigated within apartments through layout and acoustic treatments</p> <p>Design guidance</p> <p>Internal apartment layout separates noisy spaces from quiet spaces, using a number of the following design solutions:</p> <p>rooms with similar noise requirements are grouped together</p> <p>doors separate different use zones</p> <p>wardrobes in bedrooms are co-located to act as sound buffers</p> <p>Where physical separation cannot be achieved noise conflicts are resolved using the following design solutions:</p> <p>double or acoustic glazing</p> <p>acoustic seals</p> <p>use of materials with low noise penetration properties</p> <p>continuous walls to ground level courtyards where they do not conflict</p>	<p>Acoustic privacy addressed as per recommendations of acoustic assessment.</p> <p>Acoustic privacy further addressed- condition added. See conditions F8A and F8B in draft conditions.</p>	<p>Yes</p>
<p>4J Noise and pollution</p>		
<p><i>Objective 4J-1</i></p> <p>In noisy or hostile environments the impacts of external noise and pollution are minimised through the careful siting and layout of buildings</p>	<p>Acoustic privacy addressed- condition added. See conditions F8A and F8B in draft conditions.</p>	<p>Yes</p>

<p>Design guidance</p> <p>To minimise impacts the following design solutions may be used:</p> <p>physical separation between buildings and the noise or pollution source</p> <p>residential uses are located perpendicular to the noise source and where possible buffered by other uses</p> <p>non-residential buildings are sited to be parallel with the noise source to provide a continuous building that shields residential uses and communal open spaces</p> <p>non-residential uses are located at lower levels vertically separating the residential component from the noise or pollution source. Setbacks to the underside of residential floor levels should increase relative to traffic volumes and other noise sources</p> <p>buildings should respond to both solar access and noise. Where solar access is away from the noise source, non-habitable rooms can provide a buffer where solar access is in the same direction as the noise source, dual aspect apartments with shallow building depths are preferable (see figure 4J.4)</p> <p>landscape design reduces the perception of noise and acts as a filter for air pollution generated by traffic and industry</p> <p>Achieving the design criteria in this Apartment Design Guide may not be possible in some situations due to noise and pollution. Where developments are unable to achieve the design criteria, alternatives may be considered in the following areas:</p> <p>solar and daylight access</p> <p>private open space and balconies</p> <p>natural cross ventilation</p>		
<p>Objective 4J-2</p> <p>Appropriate noise shielding or attenuation techniques for the building design, construction and choice of materials are used to mitigate noise transmission</p> <p>Design guidance</p> <p>Design solutions to mitigate noise include:</p> <p>limiting the number and size of openings facing noise sources</p> <p>providing seals to prevent noise transfer through gaps using double or acoustic glazing, acoustic louvres or enclosed balconies (wintergardens)</p> <p>using materials with mass and/or sound insulation or absorption properties e.g. solid balcony balustrades, external screens and soffits</p>	<p>Acoustic privacy addressed as per recommendations of acoustic assessment.</p>	<p>Yes</p>
<p>4K Apartment mix</p>		
<p>Objective 4K-1</p> <p>A range of apartment types and sizes is provided to cater for different household types now and into the future</p> <p>Design guidance</p> <p>A variety of apartment types is provided</p>	<p>The proposed apartment mix is appropriate being a suitable range of units proposed.</p>	<p>Yes</p>

<p>The apartment mix is appropriate, taking into consideration:</p> <ul style="list-style-type: none"> the distance to public transport, employment and education centres the current market demands and projected future demographic trends the demand for social and affordable housing different cultural and socioeconomic groups <p>Flexible apartment configurations are provided to support diverse household types and stages of life including single person households, families, multi-generational families and group households</p>		
<p>Objective 4K-2</p> <p>The apartment mix is distributed to suitable locations within the building</p> <p>Design guidance</p> <p>Different apartment types are located to achieve successful facade composition and to optimise solar access (see figure 4K.3)</p> <p>Larger apartment types are located on the ground or roof level where there is potential for more open space and on corners where more building frontage is available</p>	Provided.	Yes
4L Ground floor apartments		
<p>Objective 4L-1</p> <p>Street frontage activity is maximised where ground floor apartments are located</p> <p>Design guidance</p> <p>Direct street access should be provided to ground floor apartments</p> <p>Activity is achieved through front gardens, terraces and the facade of the building. Design solutions may include:</p> <ul style="list-style-type: none"> both street, foyer and other common internal circulation entrances to ground floor apartments private open space is next to the street doors and windows face the street <p>Retail or home office spaces should be located along street frontages</p> <p>Ground floor apartment layouts support small office home office (SOHO) use to provide future opportunities for conversion into commercial or retail areas. In these cases provide higher floor to ceiling heights and ground floor amenities for easy conversion</p>	<p>Street frontage activity is maximized on Berry Road and Holdsworth Avenue.</p> <p>Individual and communal access maximised at Berry and Holdsworth Avenue.</p>	Yes
<p>Objective 4L-2</p> <p>Design of ground floor apartments delivers amenity and safety for residents</p>	Appropriate amenity and safety provided.	Yes

<p>Design guidance</p> <p>Privacy and safety should be provided without obstructing casual surveillance. Design solutions may include:</p> <p>elevation of private gardens and terraces above the street level by 1-1.5m (see figure 4L.4)</p> <p>landscaping and private courtyards</p> <p>window sill heights that minimise sight lines into apartments</p> <p>integrating balustrades, safety bars or screens with the exterior design</p> <p>Solar access should be maximised through:</p> <p>high ceilings and tall windows</p> <p>trees and shrubs that allow solar access in winter and shade in summer</p>	<p>Solar access maximized.</p>	
<p>4M Facades</p>		
<p><i>Objective 4M-1</i></p> <p>Building facades provide visual interest along the street while respecting the character of the local area</p> <p>Design guidance</p> <p>Design solutions for front building facades may include:</p> <p>a composition of varied building elements</p> <p>a defined base, middle and top of buildings</p> <p>revealing and concealing certain elements</p> <p>changes in texture, material, detail and colour to modify the prominence of elements</p> <p>Building services should be integrated within the overall facade</p> <p>Building facades should be well resolved with an appropriate scale and proportion to the streetscape and human scale. Design solutions may include:</p> <p>well composed horizontal and vertical elements</p> <p>variation in floor heights to enhance the human scale</p> <p>elements that are proportional and arranged in patterns</p> <p>public artwork or treatments to exterior blank walls</p> <p>grouping of floors or elements such as balconies and windows on taller buildings</p> <p>Building facades relate to key datum lines of adjacent buildings through upper level setbacks, parapets, cornices, awnings or colonnade heights</p> <p>Shadow is created on the facade throughout the day with building articulation, balconies and deeper window reveals</p>	<p>The proposed façade provides a high level of visual interest.</p> <p>Appropriate external materiality schedule submitted with the Development Application with a variety of finishes at both podium and tower levels.</p> <p>Services are either within the basement, ground level to side boundary or on the rooftop.</p> <p>Proposal is highly resolved with proportional articulation, variation in balustrading finishes, ground and roof level landscaping.</p> <p>Suitable analysis provided in the architectural plans of relationship in the existing streetscape of Park and Holdsworth</p> <p>Amended design fully complies with the setback controls to east/west link to create shadow lines and articulation.</p>	<p>Yes</p>
<p><i>Objective 4M-2</i></p> <p>Building functions are expressed by the facade</p> <p>Design guidance</p>	<p>Provided.</p>	<p>Yes</p>

<p>Building entries should be clearly defined</p> <p>Important corners are given visual prominence through a change in articulation, materials or colour, roof expression or changes in height</p> <p>The apartment layout should be expressed externally through facade features such as party walls and floor slabs</p>		
4N Roof design		
<p><i>Objective 4N-1</i></p> <p>Roof treatments are integrated into the building design and positively respond to the street</p> <p>Design guidance</p> <p>Roof design relates to the street. Design solutions may include:</p> <p>special roof features and strong corners use of skillion or very low pitch hipped roofs breaking down the massing of the roof by using smaller elements to avoid bulk using materials or a pitched form complementary to adjacent buildings</p> <p>Roof treatments should be integrated with the building design. Design solutions may include:</p> <p>roof design proportionate to the overall building size, scale and form roof materials compliment the building service elements are integrated</p>	<p>Roof service elements appropriately integrated screened condenser enclosures.</p>	Yes
<p><i>Objective 4N-2</i></p> <p>Opportunities to use roof space for residential accommodation and open space are maximised</p> <p>Design guidance</p> <p>Habitable roof space should be provided with good levels of amenity. Design solutions may include:</p> <p>penthouse apartments dormer or clerestory windows openable skylights</p> <p>Open space is provided on roof tops subject to acceptable visual and acoustic privacy, comfort levels, safety and security considerations</p>	<p>The proposal includes a highly functional rooftop communal open spaces on Area 13.</p>	Yes
<p><i>Objective 4N-3</i></p> <p>Roof design incorporates sustainability features</p> <p>Design guidance</p> <p>Roof design maximises solar access to apartments during winter and provides shade during summer. Design solutions may include:</p> <p>the roof lifts to the north eaves and overhangs shade walls and windows from summer sun</p>	<p>The roof of Area 15 incorporates solar panels.</p>	Yes

Skylights and ventilation systems should be integrated into the roof design		
4O Landscape design		
<p><i>Objective 4O-1</i></p> <p>Landscape design is viable and sustainable</p> <p>Design guidance</p> <p>Landscape design should be environmentally sustainable and can enhance environmental performance by incorporating:</p> <ul style="list-style-type: none"> diverse and appropriate planting bio-filtration gardens appropriately planted shading trees areas for residents to plant vegetables and herbs composting green roofs or walls <p>Ongoing maintenance plans should be prepared</p> <p>Microclimate is enhanced by:</p> <ul style="list-style-type: none"> appropriately scaled trees near the eastern and western elevations for shade a balance of evergreen and deciduous trees to provide shading in summer and sunlight access in winter shade structures such as pergolas for balconies and courtyards <p>Tree and shrub selection consider size at maturity and the potential for roots to compete (see Table 4)</p>	<p>The proposal landscaping has been provided to satisfaction of Council's Landscape Architect and subject to conditions in compliance with Council's DCP, the Landscape Masterplan, maintenance strategies and appropriately selected tree plantings for canopy cover in the medium to long term.</p>	Yes
<p><i>Objective 4O-2</i></p> <p>Landscape design contributes to the streetscape and amenity</p> <p>Design guidance</p> <p>Landscape design responds to the existing site conditions including:</p> <ul style="list-style-type: none"> changes of levels views significant landscape features including trees and rock outcrops <p>Significant landscape features should be protected by:</p> <ul style="list-style-type: none"> tree protection zones (see figure 4O.5) appropriate signage and fencing during construction <p>Plants selected should be endemic to the region and reflect the local ecology</p>	<p>Council's Landscape Assessment Architect is of the view the streetscape planting is highly developed and would soften the visual impact of the building within the streetscape.</p>	Yes
4P Planting on structures		
<p><i>Objective 4P-1</i></p> <p>Appropriate soil profiles are provided</p> <p>Design guidance</p> <p>Structures are reinforced for additional saturated soil weight</p>	<p>Appropriate soil profiles are provided</p>	Yes

<p>Soil volume is appropriate for plant growth, considerations include:</p> <p>modifying depths and widths according to the planting mix and irrigation frequency free draining and long soil life span tree anchorage Minimum soil standards for plant sizes should be provided in accordance with Table 5</p>		
<p><i>Objective 4P-2</i></p> <p>Plant growth is optimised with appropriate selection and maintenance</p> <p>Design guidance</p> <p>Plants are suited to site conditions, considerations include:</p> <p>drought and wind tolerance seasonal changes in solar access modified substrate depths for a diverse range of plants plant longevity A landscape maintenance plan is prepared</p> <p>Irrigation and drainage systems respond to:</p> <p>changing site conditions soil profile and the planting regime whether rainwater, stormwater or recycled grey water is used</p>	<p>Council's Landscape Officers have worked in conjunction with the applicant's landscape architect to provide tree planting that is appropriate to the site, including the requirement for high quality irrigation, and maintenance.</p>	<p>Yes</p>
<p><i>Objective 4P-3</i></p> <p>Planting on structures contributes to the quality and amenity of communal and public open spaces</p> <p>Design guidance</p> <p>Building design incorporates opportunities for planting on structures. Design solutions may include:</p> <p>green walls with specialised lighting for indoor green walls wall design that incorporates planting green roofs, particularly where roofs are visible from the public domain planter boxes</p> <p>Note: structures designed to accommodate green walls should be integrated into the building facade and consider the ability of the facade to change over time</p>	<p>Planting on structures highly contribute to amenity of green spine and roof top gardens of Area 13.</p>	<p>Yes</p>
<p>4Q Universal design</p>		
<p><i>Objective 4Q-1</i></p> <p>Universal design features are included in apartment design to promote flexible housing for all community members</p> <p>Design guidance</p> <p>Developments achieve a benchmark of 20% of the total apartments incorporating the Liveable Housing</p>	<p>Achieved</p>	<p>Yes</p>

<p><i>Objective 4Q-2</i></p> <p>A variety of apartments with adaptable designs are provided</p> <p>Design guidance</p> <p>Adaptable housing should be provided in accordance with the relevant council policy</p> <p>Design solutions for adaptable apartments include:</p> <p>convenient access to communal and public areas high level of solar access minimal structural change and residential amenity loss when adapted larger car parking spaces for accessibility parking titled separately from apartments or shared car parking arrangements</p>	Achieved	Yes
<p><i>Objective 4Q-3</i></p> <p>Apartment layouts are flexible and accommodate a range of lifestyle needs</p> <p>Design guidance</p> <p>Apartment design incorporates flexible design solutions which may include:</p> <p>rooms with multiple functions dual master bedroom apartments with separate bathrooms larger apartments with various living space options open plan 'loft' style apartments with only a fixed kitchen, laundry and bathroom</p>	The design provides for suitable flexibility with provision of larger apartments where possible.	Yes
4R Adaptive reuse		
<p><i>Objective 4R-1</i></p> <p>New additions to existing buildings are contemporary and complementary and enhance an area's identity and sense of place</p> <p>Design guidance</p> <p>Design solutions may include:</p> <p>new elements to align with the existing building additions that complement the existing character, siting, scale, proportion, pattern, form and detailing use of contemporary and complementary materials, finishes, textures and colours Additions to heritage items should be clearly identifiable from the original building</p> <p>New additions allow for the interpretation and future evolution of the building</p>	Achieved.	Yes
<p><i>Objective 4R-2</i></p> <p>Adapted buildings provide residential amenity while not precluding future adaptive reuse</p> <p>Design guidance</p> <p>Design features should be incorporated sensitively into adapted buildings to make up for any physical</p>	Achieved.	Yes

<p>limitations, to ensure residential amenity is achieved. Design solutions may include:</p> <p>generously sized voids in deeper buildings alternative apartment types when orientation is poor using additions to expand the existing building envelope</p> <p>Some proposals that adapt existing buildings may not be able to achieve all of the design criteria in this Apartment Design Guide. Where developments are unable to achieve the design criteria, alternatives could be considered in the following areas:</p> <p>where there are existing higher ceilings, depths of habitable rooms could increase subject to demonstrating access to natural ventilation, cross ventilation (when applicable) and solar and daylight access (see also sections 4A Solar and daylight access and 4B Natural ventilation) alternatives to providing deep soil where less than the minimum requirement is currently available on the site building and visual separation – subject to demonstrating alternative design approaches to achieving privacy common circulation car parking alternative approaches to private open space and balconies</p>		
4S Mixed use		
<p>Objective 4S-1</p> <p>Mixed use developments are provided in appropriate locations and provide active street frontages that encourage pedestrian movement</p> <p>Design guidance</p> <p>Mixed use development should be concentrated around public transport and centres</p> <p>Mixed use developments positively contribute to the public domain. Design solutions may include:</p> <p>development addresses the street active frontages are provided diverse activities and uses avoiding blank walls at the ground level live/work apartments on the ground floor level, rather than commercial</p>	N/A – No active uses required for Areas 13 – 15.	N/A
<p>Mixed use development should maximise retail and commercial</p> <p>Objective 4S-2</p> <p>Residential levels of the building are integrated within the development, and safety and amenity are maximised for residents</p> <p>Design guidance</p>	N/A Not a mixed-use development (100% residential).	N/A

<p>Residential circulation areas should be clearly defined. Design solutions may include:</p> <p>residential entries are separated from commercial entries and directly accessible from the street</p> <p>commercial service areas are separated from residential components</p> <p>residential car parking and communal facilities are separated or secured</p> <p>security at entries and safe pedestrian routes are provided</p> <p>concealment opportunities are avoided</p> <p>Landscaped communal open space should be provided at podium or roof levels</p>		
4T Awnings and signage		
<p><i>Objective 4T-1</i></p> <p>Awnings are well located and complement and integrate with the building design</p> <p>Design guidance</p> <p>Awnings should be located along streets with high pedestrian activity and active frontages</p> <p>A number of the following design solutions are used:</p> <p>continuous awnings are maintained and provided in areas with an existing pattern</p> <p>height, depth, material and form complement the existing street character</p> <p>protection from the sun and rain is provided</p> <p>awnings are wrapped around the secondary frontages of corner sites</p> <p>awnings are retractable in areas without an established pattern</p> <p>Awnings should be located over building entries for building address and public domain amenity</p> <p>Awnings relate to residential windows, balconies, street tree planting, power poles and street infrastructure</p> <p>Gutters and down pipes should be integrated and concealed</p> <p>Lighting under awnings should be provided for pedestrian safety</p>	Achieved with awnings.	Yes
<p><i>Objective 4T-2</i></p> <p>Signage responds to the context and desired streetscape character</p> <p>Design guidance</p> <p>Signage should be integrated into the building design and respond to the scale, proportion and detailing of the development</p> <p>Legible and discrete way finding should be provided for larger developments</p>	No signage proposed at this stage.	N/A

Signage is limited to being on and below awnings and a single facade sign on the primary street frontage		
4U Energy efficiency		
<p><i>Objective 4U-1</i></p> <p>Development incorporates passive environmental design</p> <p>Design guidance</p> <p>Adequate natural light is provided to habitable rooms (see 4A Solar and daylight access)</p> <p>Well located, screened outdoor areas should be provided for clothes drying</p>	BASIX provided.	Yes
<p><i>Objective 4U-2</i></p> <p>Development incorporates passive solar design to optimise heat storage in winter and reduce heat transfer in summer</p> <p>Design guidance</p> <p>A number of the following design solutions are used:</p> <p>the use of smart glass or other technologies on north and west elevations</p> <p>thermal mass in the floors and walls of north facing rooms is maximised</p> <p>polished concrete floors, tiles or timber rather than carpet</p> <p>insulated roofs, walls and floors and seals on window and door openings</p> <p>overhangs and shading devices such as awnings, blinds and screens</p> <p>Provision of consolidated heating and cooling infrastructure should be located in a centralised location (e.g. the basement)</p>	BASIX provided.	Yes
<p><i>Objective 4U-3</i></p> <p>Adequate natural ventilation minimises the need for mechanical ventilation</p> <p>Design guidance</p> <p>A number of the following design solutions are used:</p> <p>rooms with similar usage are grouped together</p> <p>natural cross ventilation for apartments is optimised</p> <p>natural ventilation is provided to all habitable rooms and as many non-habitable rooms, common areas and circulation spaces as possible</p>	Natural ventilation maximised where possible. ADG compliance with 60% of units receiving compliant cross ventilation.	Yes
4V Water management and conservation		
<p><i>Objective 4V-1</i></p> <p>Potable water use is minimised</p> <p>Design guidance</p> <p>Water efficient fittings, appliances and wastewater reuse should be incorporated</p> <p>Apartments should be individually metered</p>	BASIX provided.	Yes

<p>Rainwater should be collected, stored and reused on site</p> <p>Drought tolerant, low water use plants should be used within landscaped areas</p>		
<p><i>Objective 4V-2</i></p> <p>Urban stormwater is treated on site before being discharged to receiving waters</p> <p>Design guidance</p> <p>Water sensitive urban design systems are designed by a suitably qualified professional</p> <p>A number of the following design solutions are used:</p> <p>runoff is collected from roofs and balconies in water tanks and plumbed into toilets, laundry and irrigation</p> <p>porous and open paving materials is maximised on site stormwater and infiltration, including bio-retention systems such as rain gardens or street tree pits</p>	<p>The proposal is provided with OSD and suitable water sensitive urban design measures are implemented.</p>	<p>Yes</p>
<p><i>Objective 4V-3</i></p> <p>Flood management systems are integrated into site design</p> <p>Design guidance</p> <p>Detention tanks should be located under paved areas, driveways or in basement car parks</p> <p>On large sites parks or open spaces are designed to provide temporary on site detention basins</p>	<p>N/A</p>	<p>N/A</p>
4W Waste management		
<p><i>Objective 4W-1</i></p> <p>Waste storage facilities are designed to minimise impacts on the streetscape, building entry and amenity of residents</p> <p>Design guidance</p> <p>Adequately sized storage areas for rubbish bins should be located discreetly away from the front of the development or in the basement car park</p> <p>Waste and recycling storage areas should be well ventilated</p> <p>Circulation design allows bins to be easily manoeuvred between storage and collection points</p> <p>Temporary storage should be provided for large bulk items such as mattresses</p> <p>A waste management plan should be prepared</p>	<p>Waste management is proposed to occur on-site through a central waste collection area in the basement in each building. A linear Waste Chute System will be provided for the development for the reception of waste material only. Common areas e.g. pool, gym, green spine, music room will be supplied with suitably branded waste and recycling bins where considered appropriate. Separate arrangements will be made for both recycling streams with compartments located on each floor of the building for 240-litre recycling bins to be provided in each compartment.</p>	<p>Yes</p>
<p><i>Objective 4W-2</i></p> <p>Domestic waste is minimised by providing safe and convenient source separation and recycling</p> <p>Design guidance</p>	<p>Provided.</p>	<p>Yes</p>

<p>All dwellings should have a waste and recycling cupboard or temporary storage area of sufficient size to hold two days worth of waste and recycling</p> <p>Communal waste and recycling rooms are in convenient and accessible locations related to each vertical core</p> <p>For mixed use developments, residential waste and recycling storage areas and access should be separate and secure from other uses</p> <p>Alternative waste disposal methods such as composting should be provided</p>		
4X Building maintenance		
<p><i>Objective 4X-1</i></p> <p>Building design detail provides protection from weathering</p> <p>Design guidance</p> <p>A number of the following design solutions are used:</p> <p>roof overhangs to protect walls</p> <p>hoods over windows and doors to protect openings</p> <p>detailing horizontal edges with drip lines to avoid staining of surfaces</p> <p>methods to eliminate or reduce planter box leaching</p> <p>appropriate design and material selection for hostile locations</p>	Provided.	Yes
<p><i>Objective 4X-2</i></p> <p>Systems and access enable ease of maintenance</p> <p>Design guidance</p> <p>Window design enables cleaning from the inside of the building</p> <p>Building maintenance systems should be incorporated and integrated into the design of the building form, roof and facade</p> <p>Design solutions do not require external scaffolding for maintenance access</p> <p>Manually operated systems such as blinds, sunshades and curtains are used in preference to mechanical systems</p> <p>Centralised maintenance, services and storage should be provided for communal open space areas within the building</p>	Provided.	Yes
<p><i>Objective 4X-3</i></p> <p>Material selection reduces ongoing maintenance costs</p> <p>Design guidance</p>	Provided.	Yes

<p>A number of the following design solutions are used:</p> <p>sensors to control artificial lighting in common circulation and spaces</p> <p>natural materials that weather well and improve with time such as face brickwork</p> <p>easily cleaned surfaces that are graffiti resistant</p> <p>robust and durable materials and finishes are used in locations which receive heavy wear and tear, such as common circulation areas and lift interiors</p>		
---	--	--