



- NOTES:**
- EXTERNAL LIGHTING TO BE CONTROLLED VIA BUILT IN PE/PIR SENSORS.
 - THE ELECTRICAL CONTRACTOR SHALL ALLOW OVER-RIDE SWITCH LOCATED IN THE RE-USE HUB. FINAL LOCATION OF OVER-RIDE SWITCH TBC ON SITE.
 - ALLOW UNDERGROUND CONDUITS FOR POLE LIGHT CABLING & SWITCHING FED FROM LOCAL RH SWITCHBOARD.
 - WALL MOUNTED EXTERNAL LIGHTING TO BE SWITCHED VIA PE CELL / TIMER.

Issue	Date	Amendment	Int	App
01	18.10.2019	80% TENDER CLIENT REVIEW	RJ	JDC
02	13.11.2019	80% TENDER REVIEW	RJ	JDC
03	11.12.2019	100% REVIEW	RJ	JDC
04	12.12.2019	REVISED 100% REVIEW	RJ	JDC
A	18.12.2019	ISSUED FOR CONSTRUCTION	SR	JDC

CO-ORDINATED REFERENCE DRAWINGS			
SERVICE	DRAWING NUMBER	ISSUE	DATE
ARCH			
ARCH			
MECH			
STRUCT			
ELEC			
CIVIL			

NOTE - SYMBOLS ARE DRAWN IN THE CORRECT POSITION BUT ARE NOT SHOWN TO SCALE

THIS DRAWING IS CONFIDENTIAL AND IS NOT TO BE REPRODUCED IN ANY FORM AS A WHOLE OR IN PART WITHOUT THE EXPRESS WRITTEN AUTHORITY OF EFWF PTY LIMITED. THIS DRAWING IS NOT TO BE USED PREJUDICIAL TO THE INTEREST OF EFWF PTY LIMITED. THIS DRAWING CONTAINS PATENTS PENDING AND INTELLECTUAL PROPERTY OWNED BY EFWF PTY LIMITED. THIS DRAWING IS 'NOT FOR CONSTRUCTION' UNLESS STATED OTHERWISE ELSEWHERE ON THIS DRAWING.

© COPYRIGHT. ALL RIGHTS RESERVED



Project:

RE-USE GOULBURN PROJECT (RUG)

100 SINCLAIR STREET,
GOULBURN NSW 2580

Drawing Title:

**ELECTRICAL SERVICES
RE-USE HUB
(RH)
EXTERNAL LIGHTING
LAYOUT**

CCTV concept layout sketch

North Point:	Design:	SA
	Design Validated:	GA
	Amendment Approved:	JDC
	Drawn:	RJ
Date: DEC 2019	Scale: (A1)	1:200
Job No: 21539 - RH - E - 001	Site Abbrev: -C-	Stage: A

ORIGINAL SIZE: A1