



## NSW RURAL FIRE SERVICE

Shoalhaven City Council  
PO Box 42  
NOWRA NSW 2541

Your reference: (CNR-58361) RA23/1001  
Our reference: DA20230801003371-Original-1

**ATTENTION:** Rebecca Lockart

Date: Thursday 24 August 2023

Dear Sir/Madam,

### Integrated Development Application

s100B - SFPP - Hotel/Motel

124 ISLAND POINT ROAD ST GEORGES BASIN 2540, 1//DP785956, 11//DP1143842, 10//DP1143842

I refer to your correspondence dated 08/08/2023 seeking general terms of approval for the above Integrated Development Application.

The New South Wales Rural Fire Service (NSW RFS) has considered the information submitted. General Terms of Approval, under Division 4.8 of the *Environmental Planning and Assessment Act 1979*, and a Bush Fire Safety Authority, under section 100B of the *Rural Fires Act 1997*, are now issued subject to the following conditions:

### General Conditions

1. The development proposal is to generally comply with the following plans/documents except where amended by the conditions of this Bush Fire Safety Authority.

- The plan titled "Proposed Site & Roof Plan, Drawn by ERA Architects, Job No: 1452022, Sheet No: 1 of 25, Rev: E, Dated 12/04/2023"
- The bush fire assessment prepared by "Set Consultants, Ref: S023004, Dated 31/01/2023"

### Asset Protection Zones

***The intent of measure is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.***

2. From the commencement of building works and in perpetuity, the entire property must be managed as an inner protection area in accordance with Appendix 4.1.1 of *Planning for Bush Fire Protection 2019*.

### Access - Internal Roads

***The intent of measure is to provide safe operational access for emergency services personnel in suppressing a bush fire while residents are accessing or egressing an area.***

#### Postal address

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

#### Street address

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555  
F (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)

3. Access roads for special fire protection purpose (SFPP) developments must comply with the following requirements of Table 6.8b of *Planning for Bush Fire Protection 2019*:

- SFPP access roads are two-wheel drive, all-weather roads;
- access is provided to all structures;
- traffic management devices are constructed to not prohibit access by emergency services vehicles;
- access roads must provide suitable turning areas in accordance with Appendix 3;
- the capacity of road surfaces is sufficient to carry fully loaded firefighting vehicles (up to 23 tonnes); and,
- there is suitable access for a Category 1 fire appliances to within 4m of the static water supply where no reticulated supply is available.

## Water and Utility Services

***The intent of measure is to provide adequate services of water for the protection of buildings during and after the passage of a bush fire, and to locate gas and electricity so as not to contribute to the risk of fire to a building.***

4. The provision of SWS must comply with the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- a 10,000 litre static water supply for fire fighting purposes must be provided on-site,
- an outlet for firefighting purposes is located within the IPA or non-hazard side and away from the structure
- 65mm Storz connection with a ball valve is fitted to the outlet,
- the ball valve, pipes and tank penetration are adequate for the full 50mm inner diameter water flow through the Storz fitting and are constructed of a metal material,
- underground tanks have an access hole of 200mm to allow tankers to refill, direct from the tank,
- a hardened ground surface for truck access is supplied within 4m of the water outlet or access hole,
- above-ground tanks are manufactured from concrete or metal,
- raised tanks have their stands constructed from non-combustible material or bush fire-resisting timber. The bush fire-resisting timbers are Silvertop Ash, Blackbutt, Red or River Gum, Spotted Gum, Red Ironbark, Kwila (Merbau) or Turpentine,
- unobstructed access can be provided at all times,
- underground tanks are clearly marked,
- tanks on the hazard side of a building are provided with adequate shielding for the protection of firefighters,
- all exposed water pipes external to the building are metal, including any fittings,
- where pumps are provided, they are a minimum 5hp or 3kW petrol or diesel-powered pump, and are shielded against bush fire attack,
- any hose and reel for firefighting connected to the pump must be 19mm internal diameter,
- fire hose reels are constructed in accordance with AS/NZS 1221:1997, and installed in accordance with the relevant clauses of AS 2441:2005,
- A Static Water Supply (SWS) sign must be obtained from the local NSW Rural Fire Service (RFS) and positioned for ease of identification by RFS personnel and other users of the SWS. In this regard:
  - Markers must be fixed in a suitable location to be highly visible, and
  - Markers should be positioned adjacent to the most appropriate access for the water supply.
- all exposed water pipes external to the building are metal, including any fittings;
- where pumps are provided, they are a minimum 5hp or 3kW petrol or diesel-powered pump, and are shielded against bush fire attack; any hose and reel for firefighting connected to the pump must be 19mm internal diameter;
- fire hose reels are constructed in accordance with AS/NZS 1221:1997, and installed in accordance with the relevant clauses of AS 2441:2005.

5. The provision of water, electricity and gas must comply with the following in accordance with Table 6.8c of *Planning for Bush Fire Protection 2019*:

- reticulated water is to be provided to the development where available;
- all above-ground water service pipes are metal, including and up to any taps;
- where practicable, electrical transmission lines are underground;
- where overhead, electrical transmission lines are proposed as follows:
  - lines are installed with short pole spacing (30m), unless crossing gullies, gorges or riparian areas; and
  - no part of a tree is closer to a power line than the distance set out in accordance with the specifications in *ISSC3 Guideline for Managing Vegetation Near Power Lines*.
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 and the requirements of relevant authorities, and metal piping is used;
- reticulated or bottled gas is installed and maintained in accordance with AS/NZS 1596:2014 - *The storage and handling of LP Gas*, the requirements of relevant authorities, and metal piping is used;
- all fixed gas cylinders are kept clear of all flammable materials to a distance of 10m and shielded on the hazard side;
- connections to and from gas cylinders are metal; polymer-sheathed flexible gas supply lines are not used; and
- above-ground gas service pipes are metal, including and up to any outlets.

## Landscaping Assessment

***The intent of measure is to minimise the risk of bush fire attack and provide protection for emergency services personnel, residents and others assisting firefighting activities.***

6. Landscaping within the required asset protection zone must comply with Appendix 4 of *Planning for Bush Fire Protection 2019*.

## Emergency and Evacuation Planning Assessment

***The intent of measure is to provide suitable emergency and evacuation arrangements for occupants of SFPP developments.***

7. A Bush Fire Emergency Management and Evacuation Plan must be prepared in accordance with Table 6.8d of *Planning for Bush Fire Protection 2019* and be consistent with the NSW RFS document: A Guide to Developing a Bush Fire Emergency Management and Evacuation Plan. The plan must also include the following:

- a mechanism for the early relocation of occupants on days when adverse fire weather is notified or adverse fire activity occurs in the local government area in which the development operates;
- contact details for the local Rural Fire Service office;
- procedures for coordinated evacuation of the site in consultation with local emergency services.

A copy of the Bush Fire Emergency Management and Evacuation Plan should be provided to the Local Emergency Management Committee for its information prior to the occupation of the development.

## General Advice – Consent Authority to Note

- The proposal has been determined as having a BAL-LOW rating. BAL-LOW generally provides insufficient threat to warrant specific construction requirements, however in this instance due to the large parcel of unmanaged forested vegetation to the east of the proposal, specific construction requirements for ember protection and accumulation of debris are warranted. BAL-12.5 construction requirements, as per section 3 and section 5 (BAL 12.5) Australian Standard AS3959-2018 *Construction of buildings in bushfire-prone areas* or the relevant requirements of the *NASH Standard - Steel Framed Construction in Bushfire Areas* (incorporating amendment A - 2015), are recommended.

For any queries regarding this correspondence, please contact Jamie Winter on 1300 NSW RFS.

Yours sincerely,

Michael Gray





NSW RURAL FIRE SERVICE

# BUSH FIRE SAFETY AUTHORITY

SFPP – Hotel/Motel

124 ISLAND POINT ROAD ST GEORGES BASIN 2540, 1//DP785956, 11//DP1143842, 10//DP1143842

RFS Reference: DA20230801003371-Original-1

Your Reference: (CNR-58361) RA23/1001

This Bush Fire Safety Authority is issued on behalf of the Commissioner of the NSW Rural Fire Service under s100b of the Rural Fires Act (1997) subject to the attached General Terms of Approval.

This authority confirms that, subject to the General Terms of Approval being met, the proposed development will meet the NSW Rural Fire Service requirements for Bush Fire Safety under *s100b of the Rural Fires Act 1997*.

**Michael Gray**

Manager Planning & Environment Services  
Built & Natural Environment

Thursday 24 August 2023