

## Sorrell Rangiihu

---

**From:** TE\_Technical Enquiries <te\_technical.enquiries@essentialenergy.com.au>  
**Sent:** Tuesday, 21 November 2023 11:47 AM  
**To:** Sorrell Rangiihu  
**Subject:** CNR-61961 - A-74281 - 9 POLO FLAT ROAD POLO FLAT 2630

Thank you for seeking comment from Essential Energy in relation to the proposed development at the above property .

Strictly based on the documents submitted, Essential Energy has no comments to make as to potential safety risks arising from the proposed development.

Essential Energy makes the following general comments:

- As part of the subdivision, an easement is created for any existing electrical infrastructure. The easement is to be created using Essential Energy's standard easement terms current at the time of registration of the plan of subdivision;
- If the proposed development changes, there may be potential safety risks and it is recommended that Essential Energy is consulted for further comment;
- Any existing encumbrances in favour of Essential Energy (or its predecessors) noted on the title of the above property should be complied with;
- Council should ensure that a Notification of Arrangement (confirming satisfactory arrangements have been made for the provision of power) is issued by Essential Energy with respect to all proposed lots which will form part of the subdivision, prior to Council releasing the Subdivision Certificate. It is the Applicant's responsibility to make the appropriate application with Essential Energy for the supply of electricity to the subdivision, which may include the payment of fees and contributions;
- In addition, Essential Energy's records indicate there is electricity infrastructure located within the property. Any activities within this location must be undertaken in accordance with the latest industry guideline currently known as *ISSC 20 Guideline for the Management of Activities within Electricity Easements and Close to Infrastructure*;
- Prior to carrying out any works, a "Dial Before You Dig" enquiry should be undertaken in accordance with the requirements of *Part 5E (Protection of Underground Electricity Power Lines)* of the *Electricity Supply Act 1995* (NSW);
- Given there is electricity infrastructure in the area, it is the responsibility of the person/s completing any works around powerlines to understand their safety responsibilities. SafeWork NSW ([www.safework.nsw.gov.au](http://www.safework.nsw.gov.au)) has publications that provide guidance when working close to electricity infrastructure. These include the *Code of Practice – Work near Overhead Power Lines* and *Code of Practice – Work near Underground Assets*.

Should you require any clarification, please do not hesitate to contact us.

Regards,

Essential Energy



PO Box 5730 Port Macquarie NSW 2444 | [essentialenergy.com.au](http://essentialenergy.com.au)

General enquiries: 13 23 91 | Supply interruptions (24hr): 13 20 80

Follow us  