lid

22nd November 2024

Tim Reich - New Release Coordinator **Queanbeyan-Palerang Regional Council**, 50 Morisset St Queanbeyan NSW 2620 E: <u>Tim.Reich@qprc.nsw.gov.au</u>

Re: Response to Council Comments re quantification of the embodied emissions residential and non-residential

Low Impact Development (LID) Consulting has reviewed Council's comments relating to the quantification of the embodied carbon emissions attributable to the proposed development at 50 Morisset St, Queanbeyan NSW 2620. The quantification of the embodied emissions has been summarised and a response is provided below.

Given it is a mixed-use development of retail, car parks and apartments towers above, meeting NSW Planning Systems Sustainable Building SEPP requirements is achieved via the following components:

- The residential units and apartment common areas (including carparks and common areas) have been addressed in the BASIX Report
- The areas that have not been included in the BASIX Report have been addressed via NABERS embodied carbon form.

All areas of the building have been assessed and quantification of emissions has occurred to current SEPP requirements.

BASIX Report

The quantification of materials has been provided for all residential units and common areas. The BASIX Materials embodied carbon score is derived from the quantified materials and selected materials options. The results have been summarised below.

| Floor types | | | | | | | | | | |
|---|-----------|------------|----------------------|--|--|--|--|--|--|--|
| Floor type | Area (m2) | Insulation | Low emissions option | | | | | | | |
| concrete slab on ground, frame: | 2898 | - | none | | | | | | | |
| suspended floor above garage, frame: suspended concrete slab | 3836.4 | - | none | | | | | | | |
| floors above habitable rooms, frame: suspended concrete slab | 10054.8 | - | none | | | | | | | |

| External wall types | | | | | | | | | | |
|----------------------|---|-----------|----------------------|---------------------------------|--|--|--|--|--|--|
| External wall type | Construction type | Area (m2) | Low emissions option | Insulation | | | | | | |
| External wall type 1 | concrete panel/ plasterboard,frame:timber - H2 treated softwood | 6216 | none | rockwool batts, roll or pump-in | | | | | | |
| External wall type 2 | framed (metal clad),frame:timber - H2 treated softwood | 586 | none | rockwool batts, roll or pump-in | | | | | | |

| Internal wall types | | | | | | | | | |
|---|-------------------------------|---|---------------------------------|-------------------------------|---------------------------------|--------------------------|--|--|--|
| Internal wall type | Construction t | уре | Area (m2) | | Insulation | | | | |
| Internal wall type 1 | plasterboard, fra softwood | ame:timber - H2 treated | 6720 | | - | | | | |
| Internal wall type 2 | plasterboard, fra softwood | ame:timber - H2 treated | 9769.6 | | rockwool batts, roll or | pump-in | | | |
| Reinforcement concrete frames/columns | | | | | | | | | |
| Building has reinforced concrete frame/ | Volume (m ³) | Low emission | | ns option | | | | | |
| yes | | 2000 | | | | | | | |
| | | Ceiling an | d roof types | | | | | | |
| Ceiling and roof type | Area (m²) | | Roof Insulation | | Ceiling Insulation | | | | |
| concrete - plasterboard internal, frame: no frame | 1920 | | foil/sarking | | rockwool batts, roll or pump-in | | | | |
| Glazing types Frame types | | | | | | | | | |
| Single glazing (m²) Double glazing (m²) | Triple glazing | (m ²) Aluminium frames (m ²) | Timber frames (m ²) | uPVC frames (m ²) | Steel frames (m ²) | Composite frames (m²) | | | |
| - 200 | - | 200 | | - | - | | | | |

NABERS Embodied Carbon Form

The areas that have not been covered in the BASIX report are summarised in the NABERS embodied carbon form. See material details below.

Structure

- Concrete in-situ GF slabs retail >32 MPa to ≤40 MPa
- Concrete in-situ L1 and L2 suspended slabs >40MPa 50MPA (balance of L1 and L2 slabs not covered by BASIX report)
- Pre-cast panels walls at rear of retail shops
- Reinforcing steel to concrete

Envelope

- Wall cladding around and above brick windows– bricks
- Windows and doors shopfront glazing double glazing
- Stick frame wall system wall above windows aluminium cladding

Permanent internal walls and doors

- Interior walls between retail tenancies timber frame
- Interior walls plasterboard
- Interior walls insulation

Services

• Cold shell – Share of ground floor services allowance from QS report

External works

- Pavements >20 MPa to ≤32 MPa concrete
- Driveways >32 MPa to ≤40 MPa concrete



We trust the above response to the quantification of embodied carbon emissions matters associated with the proposed mixed-use development at 50 Morriset St, Queanbeyan NSW is sufficient.

If you have any queries regarding the above, please do not hesitate to contact us.

Yours sincerely

Zoe Zou Sustainability consultant Low Impact Development (LID) Consulting E: <u>zoezoe@lidconsulting.com.au</u>



Appendix 1 - NABERS Embodied Emissions Materials Form

Step 1: About the building

Fill out blue cells

| Building location and site data | Value | Unit | Note | Comment |
|-------------------------------------|--------------------------------|------|--|---|
| Building address | 50 Morisset Street, Queanbeyan | | | |
| Postcode | 2620 | | Required | Postcode of building |
| Town/city | BEARD + 37 other localities | | Town/city/suburb/region automated from postcode (may not give exact town name) | Town/city/suburb/region of the building site. |
| Distance to nearest major city/town | | km | Enter for rural/regional locations only | Declare the shortest route by road to your site from the centre of your nearest major city (>100,000 people). The route must be traversable a semitrailer truck. |
| Project stage | Development Application | | Required | Stage of development |
| New build or major renovation? | New build | | Required | |
| Brownfield or greenfield site? | Brownfield | | Required | |

| Floor area by NCC building classification | Gross (GFA) | Net (NLA/NSA/UFA) Ur | nit | Note | |
|--|-------------|----------------------|-----|--|---|
| Please enter all floor areas relevant to your building. Leave areas blank if not applicable. Please enter Gross Floor Area (GFA) for all building classifications. Please also enter the corresponding net area (Net Lettable Area, Net Sellable Area or Usable Floor Area where it is commonly used for that building classification. | | | | | |
| Class 1a: Detached residential buildings | | m ^a | 2 | Required for Class 1a: Detached residential houses, townhouses | Gross Floor Area (GFA), as defined by the AIQS Australian Cost Management Manual |
| Class 1b: Boarding houses and hostels | | mi | 2 | Required for Class 1b: Boarding house, guest house, hostel | Net area (Net Lettable Area, Net Sellable Area, Usable Floor Area), as defined by the PCA's Method of Measurement |
| Class 2: Multi-unit residential buildings | | mi | 2 | Required for Class 2: Multi-unit residential, including apartment buildings | |
| Class 3: Other residential buildings | | m ^a | 2 | Required for Class 3: Other residential buildings | |
| Class 4: Residential inside non-residential | | m ^a | 2 | Required for Class 4: Residential building inside a non-residential building, e.g., caretaker re | sidence |
| Class 5: Office buildings | | mi | 2 | Required for Class 5: Office building | |
| Class 6: Retail buildings | 648 | 616 m ⁴ | 2 | Required for Class 6: Retail building, e.g., shop, restaurant, café | |
| Class 7a: Carparks | | m ^a | 2 | Required for Class 7a: Carparks | |
| Class 7b: Warehouse-type buildings | | m ⁴ | 2 | Required for Class 7b: Warehouses, wholesalers and storage facilities | |
| Class 8: Industrial buildings | | m ^a | 2 | Required for Class 8: Industrial buildings, e.g., factories and workshops | |
| Class 9a: Healthcare buildings | | m ^a | 2 | Required for Class 9a: Healthcare, e.g., hospitals, clinics, day surgeries | |
| Class 9b: Civic buildings | | m ⁴ | 2 | Required for Class 9b: Civic buildings, e.g., theatres, civic centres, train stations | |
| Class 9c: Aged care and personal care buildings | | m ^a | 2 | Required for Class 9c: Aged care and personal care | |
| Class 10a: Non-habitable buildings | | m ⁴ | 2 | Required for Class 10a: Non-habitable buildings including sheds, carports and private garag | es |
| Class 10b: Miscellaneous structures | | m ^a | 2 | Required for Class 10b: Miscellaneous structures, including fences, masts, antennas, retain | ing walls and swimming pools |
| Class 10c: Bushfire shelters | | m ^a | 2 | Required for Class 10c: Bushfire shelters not attached to a Class 1a building | |
| Total | 648 | 616 m ² | 2 | Required: Sum of m ² inputs must be more than 0. | |

| Project information | Value | Unit | Note | |
|---|---------|---------------|----------|---|
| Total cost of project | 765,649 | AUD excl. GST | Required | Include labour, materials, transport, plant, equipment and professional fees. Exclude GST, land, finance, escalation and other costs. |
| Building design life | 50 | years | Required | If uncertain, enter 50 years |
| Estimated envelope life | | years | Optional | |
| Estimated replacement cycle for mechanical services | | years | Optional | |
| Estimated replacement cycle for vertical transportation | | vears | Optional | |

| Dimensions of the building and the site | Value | Unit | Note | |
|---|-------|------|---------------------------------------|---|
| Site area | 5,940 | m² | Required | Total area of site to external boundary. |
| Shared services or infrastructure | No | | Required | Indicate if there are shared services that the building utilises, or shared foundations, basement or podium |
| Building footprint area | 648 | m² | Required | Total floor area of the ground floor measured to the outside edge of the floorplate. |
| Typical floor area (if different to building footprint area) | | m² | Only needed if different to row above | |
| Typical floor perimeter | 232 | m | Required | |
| Area of external carpark (not included in GFA) | 212 | m² | Required. Enter 0 if not applicable. | |
| Area of external hardstand (not included in GFA) | 1,760 | m² | Required. Enter 0 if not applicable. | |
| Area of other hard landscaping (not included in GFA) | 421 | m² | Required. Enter 0 if not applicable. | Include all other impervious areas. For example, patios, paths and driveways (not already included in carparks and hardstands above). |
| Number of floors/storeys above ground, including ground floor | 2 | no. | Required | |
| Number of floors/storeys below ground | 0 | no. | Required. Enter 0 if not applicable. | |
| Number of floors/storeys of car parking | 2 | no. | Required. Enter 0 if not applicable. | |
| Total height above ground | 6 | m | Required | Measured from the average finished grade to the highest point of the building, excluding protrusions (lighting rods, masts, chimneys, etc.) |
| | • | | | · |
| | | | | |

| Structural material choices | Value | Note | |
|-----------------------------|----------------|----------|--|
| Foundation type | Slab-on-ground | Required | |

| Frame type (dominant) | Hybrid: Steel, reinforced concrete | Required | |
|--|------------------------------------|--|--|
| Suspended floor type (typical) | Reinforced concrete | Only needed for multi-storey buildings | |
| Describe low carbon materials specified in your building (e.g. green concrete, low carbon bricks) | Non | Required | |
| Describe recycled content specified in your building (e.g. recycled steel) | Non | Required | |

Step 2: Quantity of materials Complete all blue cells that are applicable to the building<u>Leave items that aren't applicable</u>blank.

Fill out blue cells

| Material category | Sub-category 1 | Sub-category 2 | Sub-category 3 | Value | Unit of mea | sure Comment | AIQS ACMM Code | ICMS3 (Level 3 Codes Constructi |
|---|-----------------------------------|-----------------------------|-------------------------------|--------------------------------|----------------|--|------------------------|---------------------------------|
| Structure | | | | | | | | |
| The structural parts of the building th | hat are below ground (substructur | e) and above ground (sup | erstructure). | | | | | |
| This includes fill below the substruct It excludes external areas such as ha | | s, suspended floors, wall s | tructure, roof structure, sta | irs, lift shafts and balconies | s. | | | |
| Coverage of structural material spend | - | - | - | 80 |) % | Required. Coverage of <u>spend</u> for structural elements entered below. Minimum requirement = 80%. Exclude head contractor preliminaries and margins. | | |
| Concrete in-situ | ≤10 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >10 MPa to ≤20 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >20 MPa to ≤32 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >32 MPa to ≤40 MPa | - | - | 129.6 | 6 m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >40 MPa to ≤50 MPa | - | - | 534.0 |) m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >50 MPa to ≤60 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >60 MPa to ≤80 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >80 MPa to ≤100 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete in-situ | >100 MPa | - | - | | m³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 01_SB or 02-11 | 02 or 03 |
| Concrete pre-cast panel | - | - | - | 102.0 |) m³ | Please enter reinforcing steel in relevant line items below. If not known at DA stage, please your best estimate. If not known at CC stage, please ask your supplier. | nake 01_SB or 02-11 | 02 or 03 |
| Concrete block | Hollow core | - | - | | m³ | Enter as <u>cubic metres</u> , calculated as (area in m ²) * (thickness in mm / 1000). Please include all block fill concrete and all reinforcing steel in relevant line items above/belo | w. 01_SB | 02 or 03 |
| Concrete block/brick | Solid | - | - | | m³ | Enter as cubic metres, calculated as (area in m ²) * (thickness in mm / 1000) | 01_SB | 02 or 03 |
| Concrete block/brick | Solid AAC | - | - | | m³ | Solid Aerated Autoclaved Concrete (AAC) block. Enter as <u>cubic metres</u> , calculated as (area in m²) * (thickness in mm / 1000). | 01_SB | 02 or 03 |
| Mortar | | | - | | kg | | 01_SB | 02 or 03 |
| Reinforcing steel | Bar & mesh | - | | 765,600 |) kg | Include all reinforcing steel bar/mesh in the building's structure in this rowUsually this calculated as kg/m^2 per concrete element and then summed. Example: 10 m ³ of 40 MPa cor @ 100 $kg/m^2 + 5$ m ³ of 50 MPa concrete @ 150 $kg/m^2 = 1,750$ kg reinforcing steel. | | 02 or 03 |
| Reinforcing steel | Fibre & strand | - | | | ka | Include all steel fibre reinforcing and steel strand in the building's structure in this row | v. 01 SB or 02-11 | 02 or 03 |
| tructural steel | Hot rolled structural | | | | ť | Examples include universal beams, universal columns and welded beams | 01_SB | 02 or 03 |
| tructural steel | Cold formed structural | - | | | t | Examples include C purlins, Z purlins and all light gauge steel framing | 01_SB | 02 or 03 |
| structural steel | Other welded structural | | | | t | | 01_SB | 02 or 03 |
| structural steel | Plate | - | - | | t | Include any allowance for connections here | 01_SB | 02 or 03 |
| structural steel | Sheet | | | | t | , | 01_SB | 02 or 03 |
| Stainless steel | - | - | | | t | Primarily for engineered timber structure connections | 02 11 | 02 or 03 |
| | A | | | | | Please enter reinforcing steel in the line below. If not known at DA stage, please make your | | 22.22 |
| Reinforced concrete piles | Concrete | - | - | - | m ³ | estimate. If not known at CC stage, please ask your supplier. If not known at DA stage, please make your best estimate. If not known at CC stage, please | - | 02 or 03 |
| Reinforced concrete piles | Steel reinforcing | | | | kg | your supplier. | 01_SB | 02 or 03 |
| Steel piles | - | - | - | | t | Where concrete and reinforcing steel are also used, enter these in the rows above. | 01_SB | 02 or 03 |
| ïmber poles/piles | - | - | - | | m³ | Where concrete and reinforcing steel are also used, enter these in the rows above. | 01_SB | 02 or 03 |
| ïmber (solid) | Sawn softwood | - | - | | m³ | | 02_11 | 02 or 03 |
| ïmber (solid) | Sawn hardwood | - | - | | m³ | | 02_11 | 02 or 03 |
| imber (engineered) | CLT | - | - | | m³ | | 02_11 | 02 or 03 |
| ïmber (engineered) | Glulam | | - | | m³ | | 02_11 | 02 or 03 |
| imber (engineered) | LVL | - | - | | m³ | | 02_11 | 02 or 03 |
| ïmber (engineered) | OSB | - | - | | m³ | Enter as cubic metres, calculated as (area of wall in m ²) * (thickness in mm / 1000) | 02_11 | 02 or 03 |
| Irick | Heat cured | - | | | m³ | Enter as cubic metres, calculated as (area of wall in m ²) * (thickness in mm / 1000) | 02_11 | 02 or 03 |
| tructural Insulated Panel (SIP) | Steel outer | - | | | m² | | 01_SB | 02 or 03 |
| structural Insulated Panel (SIP) | Aluminium outer | - | - | | m² | | 01_SB | 02 or 03 |
| Structural Insulated Panel (SIP) | Engineered timber outer | - | - | | m² | | 01_SB | 02 or 03 |
| | - | - | | | t | Include purchased material only. Exclude site-won material. | 01_SB | 01 |
| Sand & gravel | - | - | | | t | Include purchased material only. Exclude site-won material and sand/gravel in concrete. | _ 01_SB | 01 |
| Vaterproofing membrane | Bituminous | - | - | | m² | - | 01_SB | 01 or 02 or 03 |
| Vaterproofing membrane | Polyethylene | - | - | | m² | | 01 SB | 01 or 02 or 03 |
| | · · | | | | - | | on | |

| Other structural (Describe and add unit >>) | - | - | Please enter a description for any structural material that does not fit a predefined classification |
|---|---|---|--|
| Other structural (Describe and add unit >>) | - | - | Please enter a description for any structural material that does not fit a predefined classification |

Envelope

The skin of the building that separates the internal building from the external environment. This includes the roof cladding, wall cladding, windows, doors and internal/external shading. It also includes insulation and the internal wall lining of envelope walls.

| This includes the root clauding, wait cla | duling, willdows, doors and litter | nal/external shaung. It as | so includes insulation and th | e internar wan inning of e | ivelope walls. | | | |
|---|------------------------------------|----------------------------|-------------------------------|----------------------------|----------------|---|--------------------|----------|
| Coverage of envelope material spend | - | - | - | 80 | % | Required. Coverage of <u>spend</u> for the envelope items you have entered below. Minimum requirement = 80%. Exclude head contractor preliminaries and margins. | | |
| | | | | | | Enter as m ² of roof area. Exclude allowances for overlap in the roofing sheets. This row include | 5 | |
| Roof cladding | Profiled steel | | | | m² | all metal-coated and pre-painted steel sheets where steel is the base metal. Examples include: | 05 BE | 03 or 04 |
| | | | | | | all metal-coated and pre-painted steel sheets where steel is the base metal. Examples include: galvanised steel, zinc-aluminium (zincalume) coated steel and zinc-aluminium-magnesium (ZAI | A)**=** | |
| | | | | | | coated steel, whether painted or unpainted. | | |
| Roof cladding | Profiled aluminium | - | - | | m² | Enter as m ² of roof area. Exclude allowances for overlap in the roofing sheets. This row also includes pre-painted aluminium sheets. | 05_RF | 03 or 04 |
| | | | | | | Enter as m ² of roof area. Exclude allowances for overlap in the roofing sheets. This row also | | |
| Roof cladding | Profiled zinc | - | - | | m² | includes pre-painted zinc sheets. | 05_RF | 03 or 04 |
| Roof cladding | Membrane | | | | m² | Enter as m ² of roof area. Exclude allowances for overlap in the membrane sheets. | 05_RF | 03 or 04 |
| Roof cladding | Tiles (traditional clay) | | | | m² | Enter as m ² of roof area. Exclude allowances for overlap between the tiles. | 05_RF | 03 or 04 |
| Roof cladding | Tiles (concrete) | | | | m ² | Enter as m ² of roof area. Exclude allowances for overlap between the tiles. | 05_RF | 03 or 04 |
| Roof cladding | Other (Please describe >>) | - | | | m ² | Please enter a description for any roofing that does not fit a predefined classification | 05_RF | 03 or 04 |
| Root cladding | Other (Please describe >>) | | - | | HI- | | 03_KF | 03 01 04 |
| Wall cladding | Bricks (heat cured) | | - | 306 | m² | Enter as m ² of wall area. Heat-cured bricks use a kiln or furnace to raise the brick temperature | 06 EW | 03 or 04 |
| U U | | | | | | above ambient temperature during curing process. | _ | |
| Wall cladding | Bricks (air dried) | - | - | | m² | Enter as m ² of wall area. Air-dried bricks are cured using ambient temperature. | 06_EW | 03 or 04 |
| Wall cladding | Bricks (under fired) | - | - | | m² | Enter as m ² of wall area. | 06_EW | 03 or 04 |
| Wall cladding | Bricks (concrete) | - | | | m² | Enter as m ² of wall area | 06_EW | 03 or 04 |
| Wall cladding | Mortar and render | - | - | | kg | | 06_EW | 03 or 04 |
| - | | | | | 1 | Enter as m ² of wall area. Exclude allowances for overlap in the cladding sheets, offcuts, etc. Th | s – | |
| Wall cladding | Profiled steel | | | | m ² | row includes all metal-coated and pre-painted steel sheets where steel is the base metal. | 06 EW | 03 or 04 |
| Wall cladding | | | | | | Examples include: galvanised steel, zinc-aluminium (zincalume) coated steel and zinc-aluminiu | m-00_211 | 00 01 04 |
| | | | | | | magnesium (ZAM) coated steel, whether painted or unpainted. | | |
| Wall cladding | Profiled aluminium | - | | | m² | Enter as m ² of wall area. Exclude allowances for overlap in the cladding sheets, offcuts, etc. Th row also includes pre-painted aluminium sheets. | ^s 06_EW | 03 or 04 |
| | | | | | | Enter as m ² of wall area. Exclude allowances for overlap in the cladding sheets, offcuts, etc. Th | e | |
| Wall cladding | Profiled zinc | - | - | | m² | row also includes pre-painted zinc sheets. | 5 06_EW | 03 or 04 |
| | | | | | | | | |
| Wall cladding | GRC cladding | - | - | | m² | Enter as m ² of wall area. GRC = Glass Reinforced Concrete. | 06_EW | 03 or 04 |
| Wall cladding | Timber weatherboards | | | | m² | Enter as m ² of wall area. Exclude allowances for overlap between weatherboards, offcuts, etc. | 06_EW | 03 or 04 |
| Wall cladding | Fibre cement board | | - | | m² | Enter as m ² of wall area. Exclude allowances for offcuts, etc. | 06 EW | 03 or 04 |
| Wall cladding | Terracotta | | | | m² | Enter as m ² of wall area, Exclude allowances for offcuts, etc. | 06 EW | 03 or 04 |
| Wall cladding | Brick tiles / veneers | | | | m² | Enter as m ² of wall area. Exclude allowances for offcuts, etc. | 06_EW | 03 or 04 |
| Ū. | | | | | | Enter as m ² of wall area. Exclude allowances for offcuts, etc. Include both external wall linings a internet wall linings of a payloge walls. | 00_L11 | |
| Wall cladding | Plasterboard | - | - | | m² | internal wall linings for envelope walls. | "12_WF or 06_EW | 03 or 04 |
| | | | | | | Enter as m ² of wall area. Exclude allowances for offcuts, etc. Include both external wall linings a | in | |
| Wall cladding | Plywood | - | - | | m² | internal wall linings for envelope walls. | 12_WF or 06_EW | 03 or 04 |
| Wall cladding | Other (Please describe >>) | | - | | m² | Please enter a description for any wall cladding that does not fit a predefined classification | 06_EW or 12_WF | 03 or 04 |
| Windows & doors | Aluminium frame | Single glazed | - | | m² | Include all single glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Aluminium frame | Double glazed | - | 267 | m² | Include all double glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Aluminium frame | Triple glazed | | | m² | Include all triple glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Timber frame | Single glazed | - | | m² | Include all single glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Timber frame | Double glazed | - | | m ² | Include all single glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| | | - | - | | | | | |
| Windows & doors | Timber frame | Triple glazed | - | | | Include all triple glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | uPVC frame | Single glazed | - | | m² | Include all single glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | uPVC frame | Double glazed | - | | m² | Include all double glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | uPVC frame | Triple glazed | - | | m² | Include all triple glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Frameless | Single glazed | | | m² | Include all single glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Frameless | Double glazed | | | m² | Include all double glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Frameless | Triple glazed | | | m² | Include all triple glazing, including standard, toughened, laminated and low-E | 07_WW or 08_ED | 03 or 04 |
| Windows & doors | Other (Please describe >>) | | | | m² | Please enter a description for any windows or doors that do not fit a predefined classification | 07_WW or 08_ED | 03 or 04 |
| | . / | L | | | 1 | Please declare all single-skin façade area in this section. All double-skin façade area should be | | |
| Curtain wall | Single skin façade | Glazed panel | Single glazed | | m² | entered in the next section. Include all single glazing, including standard, toughened, laminated | 06_EW | 03 or 04 |
| | | | | | | and low-E | | |
| Curtain wall | Single skin façade | Glazed panel | Double glazed | | m² | Include all double glazing, including standard, toughened, laminated and low-E | 06_EW | 03 or 04 |
| | | | | | | | | |

| Curtain wall | Single skin façade | Glazed panel | Triple glazed | | m² | Include all triple glazing, including standard, toughened, laminated and low-E | 06_EW |
|---|----------------------------|---------------------|----------------------|-----|----------------|--|----------------|
| Curtain wall | Single skin façade | Opaque panel | Aluminium cladding | | m² | | 06_EW |
| Curtain wall | Single skin façade | Opaque panel | GRC cladding | | m² | GRC = Glass-fibre Reinforced Concrete | 06_EW |
| Curtain wall | Single skin façade | Opaque panel | Insulated shadow box | | m² | | 06_EW |
| Curtain wall | Single skin façade | Opaque panel | Brick cladding | | m² | | 06_EW |
| Curtain wall | Single skin façade | Opaque panel | Stone cladding | | m² | | 06_EW |
| Curtain wall | Double skin façade | Glazed panel | Single glazed | | m² | Please declare all double-skin façade area in this section. Please declare as the area of the curtain wall and do not enter the inner and outer skins twice. Include all single glazing, including standard, toughened, laminated and low-E. | 06_EW |
| Curtain wall | Double skin façade | Glazed panel | Double glazed | | m² | The type of glazing refers to the building's envelope wall, not including the outer skin | 06_EW |
| Curtain wall | Double skin façade | Glazed panel | Triple glazed | | m² | The type of glazing refers to the building's envelope wall, not including the outer skin | 06_EW |
| Curtain wall | Double skin façade | Opaque panel | Aluminium cladding | | m² | | 06_EW |
| Curtain wall | Double skin façade | Opaque panel | GRC cladding | | m² | GRC = Glass-fibre Reinforced Concrete | 06_EW |
| Curtain wall | Double skin façade | Opaque panel | Insulated shadow box | | m² | | 06_EW |
| Curtain wall | Double skin façade | Opaque panel | Brick cladding | | m² | | 06_EW |
| Curtain wall | Double skin façade | Opaque panel | Stone cladding | | m² | | 06_EW |
| Curtain wall | Other (Please describe >>) | | | | m² | Please enter a description for any curtain wall that does not fit a predefined classification | 06_EW |
| Stick-framed wall system | Aluminium frame | Glazed section | Single glazed | | m² | Include all single glazing, including standard, toughened, laminated and low-E | 06_EW |
| Stick-framed wall system | Aluminium frame | Glazed section | Double glazed | | m² | Include all double glazing, including standard, toughened, laminated and low-E | 06_EW |
| Stick-framed wall system | Aluminium frame | Glazed section | Triple glazed | | m² | Include all triple glazing, including standard, toughened, laminated and low-E | 06_EW |
| Stick-framed wall system | Aluminium frame | Opaque section | Aluminium cladding | 180 | m² | include an type glazing, including standard, todghened, taninated and tow-E | 06_EW |
| Stick-framed wall system | Aluminium frame | Opaque section | GRC cladding | 100 | m² | GRC = Glass-fibre Reinforced Concrete | 06_EW |
| Stick-framed wall system | Aluminium frame | Opaque section | Insulated shadow box | | m ² | | 06_EW |
| Stick-framed wall system | Aluminium frame | Opaque section | Brick cladding | | m ² | | 06_EW |
| Stick-framed wall system | Aluminium frame | Opaque section | Stone cladding | | m ² | | 06_EW |
| Stick-framed wall system | Steel frame | Glazed section | - | | | Include all single glazing, including standard, toughened, laminated and low-E | 06_EW |
| , | Steel frame | Glazed section | Single glazed | | m- ? | | - |
| Stick-framed wall system | Steel frame | Glazed section | Double glazed | | m² | Include all double glazing, including standard, toughened, laminated and low-E | 06_EW |
| Stick-framed wall system | | | Triple glazed | | m- | Include all triple glazing, including standard, toughened, laminated and low-E | 06_EW |
| Stick-framed wall system | Steel frame | Opaque section | Aluminium cladding | | m- | | 06_EW |
| Stick-framed wall system | Steel frame | Opaque section | GRC cladding | | m- | GRC = Glass-fibre Reinforced Concrete | 06_EW |
| Stick-framed wall system | Steel frame | Opaque section | Insulated shadow box | | m² | | 06_EW |
| Stick-framed wall system | Steel frame | Opaque section | Brick cladding | | m² | | 06_EW |
| Stick-framed wall system | Steel frame | Opaque section | Stone cladding | | m² | | 06_EW |
| Stick-framed wall system | Other (Please describe >>) | | - | | m² | Please enter a description for any wall system that does not fit a predefined classification | 06_EW |
| Wall louvre system | Aluminium | - | - | | m² | | 06_EW |
| External shading system | Aluminium frame | Aluminium cladding | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Aluminium frame | GRC cladding | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000). GRC = Glass-fibre Reinforced Concrete. | 06_EW |
| External shading system | Aluminium frame | Terracotta cladding | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Aluminium frame | Stone cladding | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Aluminium frame | Pre-cast concrete | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Aluminium frame | Timber | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Aluminium frame | Glass (opague) | | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Aluminium frame | Steel | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| External shading system | Other (Please describe >>) | | - | | m² | Please enter as m ² of shaded area = linear metres * (width in mm / 1000) | 06_EW |
| Roller doors | Steel profile | - | - | | m² | Please note unit is <u>square metres</u> , not quantity | 08_ED |
| Roller doors | Hardwood over steel | - | - | | m² | Please note unit is <u>square metres</u> , not quantity | 08_ED |
| Roller doors | Softwood over steel | - | - | | m² | Please note unit is <u>square metres</u> , not quantity | 08_ED |
| Revolving doors | Glass/aluminium/steel | - | - | | no. | | 08_ED |
| Fire-rated doors | Engineered timber | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 08_ED |
| Fire-rated doors | Steel | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 08_ED |
| Fire-rated doors | Aluminium/glass | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 08_ED |
| Insulation | Glass wool / fibreglass | - | - | | m² | Please include both wall and ceiling insulation | 05_RF or 06_EW |
| Insulation | Stone wool | - | - | | m² | Please include both wall and ceiling insulation | 05_RF or 06_EW |
| Insulation | Polyester | - | - | | m² | Please include both wall and ceiling insulation | 05_RF or 06_EW |
| Insulation | Expanded polystyrene | - | | | m² | Please include both wall and ceiling insulation | 05_RF or 06_EW |
| Insulation | Other (Please describe >>) | | · · | | m² | Please include both wall and ceiling insulation | 05_RF or 06_EW |
| Other (Please describe and add unit >>) | | - | | | | Please enter a description for any envelope material that does not fit a predefined classification | |
| | | | | | | | |

03 or 04

03 or 04

03 or 04

03 or 04 03 or 04

| Other (Please describe and add unit >>) | - | - | | Please enter a description for any envelope material that does not fit a predefined classification |
|---|---|---|--|--|
| Other (Please describe and add unit >>) | - | - | | Please enter a description for any envelope material that does not fit a predefined classification |

Permanent internal walls and doors

Walls and doors within the building that are either structural or designed to be permanent.

| Coverage of material spend on permanent in | nternal walls and doors | | | 80 | | Enter the % coverage of <u>spend</u> for the items you have entered below. There is no minimum requirement: enter what you know. This should include all structural walls. Exclude head contractor preliminaries and margins. | | |
|--|-----------------------------|---|---|-------|-----|---|----------------|----------|
| Interior wall (permanent) | Steel (light framing) | - | - | | t | | 09_NW | 03 or 04 |
| Interior wall (permanent) | Timber framing | - | - | 1.7 | m³ | | 09_NW | 03 or 04 |
| Interior wall (permanent) | AAC panel (reinforced) | - | - | | m² | Panels of autoclaved aerated concrete (AAC) with reinforcing steel. E.g., Hebel. | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Concrete-filled steel panel | - | - | | m² | Panels made from a steel sheet outer with an aerated concrete core. E.g., Speedpanel. | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Plasterboard | - | - | 448 | m² | Enter as single-layer equivalent. If using 2 layers, multiply the area by 2. | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Plywood | - | - | | m² | Enter as single-layer equivalent. If using 2 layers, multiply the area by 2. | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Fibre cement sheet | - | - | | m² | Enter as single-layer equivalent. If using 2 layers, multiply the area by 2. | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Insulation | - | - | 156.0 | m² | | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Glass | - | - | | m² | | 09_NW or 12_WF | 03 or 04 |
| Interior wall (permanent) | Other (Please describe >>) | | - | | m² | Please enter a description for any internal wall that does not fit a predefined classification | 09_NW or 12_WF | 03 or 04 |
| Internal door (permanent) | Aluminium/glass | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 11_ND | 03 or 04 |
| Internal door (permanent) | Timber/glass | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 11_ND | 03 or 04 |
| Internal door (permanent) | Timber solid lightweight | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 11_ND | 03 or 04 |
| Internal door (permanent) | Fire resistant | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 11_ND | 03 or 04 |
| Internal door (permanent) | Steel | - | - | | no. | Please enter as single-leaf equivalent. For double-leaf doors, multiply the quantity by 2. | 11_ND | 03 or 04 |
| Internal door (permanent) | Other (Please describe >>) | | - | | no. | Please enter a description for any internal door that does not fit a predefined classification | 11_ND | 03 or 04 |
| Other (Please describe and add unit >>) | | - | - | | | Please enter a description for any material that does not fit a predefined classification | | |
| Other (Please describe and add unit >>) | | - | - | | | Please enter a description for any material that does not fit a predefined classification | | |
| Other (Please describe and add unit >>) | | - | - | | | Please enter a description for any material that does not fit a predefined classification | | |

Unit of measure

Services

Building services included<u>within the main building contrac</u>. If the building components that are the subject of the development application or the construction certificat are base building only, then only enter these items. If you cannot split services by type, please enter them all in the "Other services" category at the bottom. Enter all values as material costs in dollars.

| Mechanical services | | - | - | | AUD excl. GS |
|----------------------------------|---|---|---|-------|--------------|
| Vertical transportation | | - | | | AUD excl. GS |
| Electrical services | - | - | - | 2,720 | AUD excl. GS |
| Solar photovoltaic installations | | - | | | AUD excl. GS |
| Plumbing/hydraulic services | | - | | 2,720 | AUD excl. GS |
| Fire services | | | | | AUD excl. GS |
| Other services (Please describe) | | - | - | | AUD excl. GS |

| cl. GST | Where possible, enter material costs excluding labour, plant, equipment, margins and taxes | 28_SS | 05 |
|---------|---|----------------------------------|----------|
| cl. GST | Where possible, enter material costs excluding labour, plant, equipment, margins and taxes | 28_SS | 05 |
| cl. GST | Electrical services including the main power supply, backup generators, security and communications. Excluding solar installations. Where possible, enter material costs excluding labour, plant, equipment, margins and taxes. | 26_LP | 05 |
| cl. GST | Where possible, enter material costs excluding labour, plant, equipment, margins and taxes | 26_LP_LPGP | 05 |
| cl. GST | Where possible, enter material costs excluding labour, plant, equipment, margins and taxes | 18_PD and 19_WS | 05 or 06 |
| cl. GST | Where possible, enter material costs excluding labour, plant, equipment, margins and taxes | 25_FPSS04 or 39 XWAW_03 or 41_XF | 05 |
| cl. GST | Please group all other services here, meaning that coverage will always be 100% for services. Enter only the material costs (excluding labour, plant, equipment, margins and taxes). | 29_SS or multiple | |

External works

The materials associated with hard landscaping and outbuildings on the site but outside the building envelope. This includes hardstands, carparks, driveways, covered walkways, decks, patios, awnings, fences, gates, etc. Soft landscaping should be excluded.

| overage of spend on external works | | - | - | 80 % | Required. Coverage of <u>spend</u> for external works (excluding soft landscaping) entered below. Minimum requirement = 80%. Exclude head contractor preliminaries and margins. | |
|------------------------------------|--------------------|---|---|----------------------|--|----------------------------------|
| sphalt | | - | - | t | | 33_XR |
| oncrete in-situ | ≤10 MPa | - | - | m ³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 33_XR or 34_XN or 35_XB or 36_XL |
| oncrete in-situ | >10 MPa to ≤20 MPa | - | - | m ³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 33_XR or 34_XN or 35_XB or 36_XL |
| oncrete in-situ | >20 MPa to ≤32 MPa | - | - | 146.0 m ³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 33_XR or 34_XN or 35_XB or 36_XL |
| oncrete in-situ | >32 MPa to ≤40 MPa | - | - | 206.0 m ³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 33_XR or 34_XN or 35_XB or 36_XL |
| oncrete in-situ | >40 MPa to ≤50 MPa | - | - | m ³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 33_XR or 34_XN or 35_XB or 36_XL |
| ncrete in-situ | >50 MPa | - | - | m ³ | Please enter reinforcing steel as part of "Reinforcing steel" below | 33_XR or 34_XN or 35_XB or 36_XL |
| avers, bricks and blocks | Concrete | - | - | m² | | 33_XR |
| avers, bricks and blocks | Clay | | | m² | | 33_XR |

| Reinforcing steel | Bar & mesh | | - | 35,200 k | Include all reinforcing steel bar/mesh in the external works in this rowUsually this is calculated as kg/m² per concrete element and then summed. Example: 10 m² of 40 MPa concretr33_XR or 34_XN or 35_XB or 36_XL @ 100 kg/m² + 5 m² of 50 MPa concrete @ [50 kg/m² = 1,750 kg reinforcing steel. | 07 |
|---|----------------|---|---|----------|---|----|
| Reinforcing steel | Fibre & strand | - | - | k | Include all steel fibre reinforcing and steel strand in the external works in this row. 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Structural steel | - | | - | t | 02_11 | 07 |
| Structural aluminium | - | | - | t | Includes structures, louvre systems, etc. 35_XB | 07 |
| External roof/wall cladding | Polycarbonate | | - | n | Enter as profiled polycarbonate sheet that would ordered, including allowance for overlap 35_XB | 07 |
| External roof/wall cladding | PVC | | - | n | Enter as profiled PVC sheet that would ordered, including allowance for overlap 35_XB | 07 |
| External roof/wall cladding | Bitumen sheet | | - | n | Enter as bituminous sheet that would ordered, including allowance for overlap 35_XB | 07 |
| External roof/wall cladding | Steel profile | | - | n | Enter as profiled steel sheet that would ordered, including allowance for overlap 35_XB | 07 |
| Fill | - | | - | t | Include purchased material only. Exclude site-won material. 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Sand & gravel | - | | - | t | Include purchased material only. Exclude site-won material and sand/gravel in concrete. 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Timber (solid) | Sawn softwood | | - | n | 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Timber (solid) | Sawn hardwood | | - | n | 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Timber (engineered) | CLT | | - | n | 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Timber (engineered) | Glulam | - | - | n | 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Timber (engineered) | LVL | | - | n | 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Timber (engineered) | OSB | | - | n | 33_XR or 34_XN or 35_XB or 36_XL | 07 |
| Fabric (awning/sunshade) | | | | n | 35_XB or 36_XL | 07 |
| Other (Please describe and add unit >>) | | | - | | Please enter a description for any external works that does not fit a predefined classification | |
| Other (Please describe and add unit >>) | | | - | | Please enter a description for any external works that does not fit a predefined classification | |
| Other (Please describe and add unit >>) | | - | - | | Please enter a description for any external works that does not fit a predefined classification | |

Step 3: Certifier details

Fill out blue cells

The material quantities must be determined through an itemised list of building materials (such as a bill of quantities) and certified by a quantity surveyor, designer, engineer or NABERS Assessor.

| Person that completed this form | Value | Note |
|---------------------------------|----------------|----------|
| Name | Craig Harris | Required |
| Company | LID Consulting | Required |
| ABN | | |
| Profession | ESD Engineer | Required |
| Qualification or registration | ESD Engineer | Required |

| Person that certified the details in this form | Value | Note |
|--|----------------|----------|
| Name | Zoe Zou | Required |
| Company | LID Consulting | Required |
| ABN | | |
| Profession | ESD Engineer | Required |
| Qualification or registration | ESD Engineer | Required |

| Confirmation of certification | Value | Note |
|---|-------|----------|
| Are 80% of material costs captured for the building's structure, envelope and external works? | Yes | Required |
| If no - why not? | | |

Additional comments from data provider

This report covers the balance of the areas not covered by the BASIX embodied carbon assessment. The BASIX assessment covers all apartmetns, common areas an dthe car parks within the building. This report covers the retial spaces, external carparks, hard stand areas, landscaping and spaces other components

Additional comments of certifier

Attach this Excel spreadsheet to your development application or construction certificate application.