

Fire Assessment

Boorowa 1B Solar Farm



DOCUMENT CONTROL

Report Title		Fire Assessment – Boorowa 1B Solar Farm					
Rev	Date	Status	Author/s	Reviewed By	Approved		
1	12/02/2021	For Submission	A Ngo	A Nicholls	Z Aznam		

A person or organisation choosing to use documents prepared by ITP Development accepts the following:

- (a) Conclusions and figures presented in draft documents are subject to change. ITP Development accepts no responsibility for use outside of the original report.
- (b) The document is only to be used for purposes explicitly agreed to by ITP Development.
- (c) All responsibility and risks associated with the use of this report lie with the person or organisation who chooses to use it.

Unless otherwise specified, all intellectual property in this report remains the exclusive property of ITP Development, and may be used only to evaluate and implement the findings and recommendations in this report. Intellectual property includes but is not limited to designs, drawings, layouts, charts, data, formulas, technical information, recommendations, and other written content.

ITP Development Pty Ltd ABN 38 633 420 309

Office: Level 1, 19-23 Moore St Turner ACT 2612

Postal: PO Box 6127 O'Connor ACT 2602 Australia

Email: info@itpau.com.au Phone: +61 (0) 2 6257 3511

itpau.com.au Fire Assessment of the Boorowa 1B Solar Farm May 2021



ABOUT ITP DEVELOPMENT

ITP Development Pty Ltd (ITP) is a developer of town-scale solar farms in regional Australia designed to match current and future electricity demand. We undertake solar farm landholder engagement, system design, planning approvals, financing, electrical connection approvals and commissioning. ITPD maintains relationships with multiple stakeholders to ensure projects are successfully delivered in accordance with their expectations.

We are part of the international ITPEnergised Group, one of the world's largest, most experienced and respected specialist engineering consultancies focussing on renewable energy, energy efficiency, and carbon markets. The Group has undertaken over 2,000 contracts in energy projects encompassing over 150 countries since it was formed in 1981.



ABBREVIATIONS

AC	Alternating current
BESS	Battery energy storage system
Ha	Hectare
ITPD	ITP Development
MW	Megawatt, unit of power (1 million Watts)
MWp	Megawatt-peak, unit of power at standard test conditions used to indicate PV system capacity
NSW	New South Wales
PV	Photovoltaic

TABLES

ble 1 - Site information6

FIGURES

Figure 1 - Proposed 38.4 ha solar farm site and surrounding farm area (note the project wi	II
comprise 11.6 ha within this area)	7
Figure 2 – Potentially hazardous industry risk screening procedure outlined in the Applying]
SEPP33 Guidelines	.12
Figure 3 - NSW RFS Search	.17
Figure 4 - Boorowa General Arrangement with the APZ in Highlight	.18
Figure 5 - BESS Infrastructure Setout with APZ in Highlight	.19



TABLE OF CONTENTS

1	INT	RODUCTION	6
2	PRC	OJECT DESCRIPTION	8
3	LEG	GISLATIVE CONTEXT	9
	3.1	Boorowa Local Environmental Plan 2012	9
	3.2	State Environmental Planning Policy (Infrastructure) 2007	9
4	HAZ	ZARD ANALYSIS	10
	4.1	Methodology	10
	4.2	Existing Environment	10
	Risk	< screening	10
	4.3	Potential impacts	
	Dan	gerous goods on-site	13
	Sum	nmary of screening method	14
	Res	ults of screening method	15
	4.4	Management and mitigation	15
5	PRC	DJECT DESIGN DERROR! BOOKMARK NOT DE	FINED.
	5.1	Project Layout/Location	
	5.2	Inverter Station/Battery Station Arrangement	
	5.3	Material Equipment Selected/Onboard Technology	
	5.4	Installation	20
	5.5	Bushfire Assessment	21
6	SUN	MMARY	22
7	REF	ERENCES	23



1 INTRODUCTION

The proposed Boorowa 1B Solar Farm (referred to as the Project) is located on Meads Lane to the south of the Boorowa township, within the Hilltops Council area, NSW (Figure 1). ITP Development (ITPD) is proposing to construct a 6.4 MW DC solar facility within the 38.4 ha site.

Parameter	Description
Solar farm name	Boorowa 1B Solar Farm
Site reference	Boorowa 1B
Lot/DP(s)	Parts of Lots 130-133 and 136-139 of DP 2493
Street address	Meads Lane Boorowa, NSW 2586
Council	Hilltops Council
AC capacity	5 MW
DC capacity	6.4 MW
Site area	38.4 ha
Project area	11.6 ha
Current land use	Mixed Cropping/Grazing

Table 1 - Site information

This report provides an assessment to support the Development Application for the project in relation to the safety in design in terms of fire. It provides a:

- Desktop review of the hazards and material handling risks of installing utility grade lithium-ion batteries.
- Desktop review of the design requirements to ensure appropriate setbacks and clearances between assets to act as a defendable area.
- Desktop review of the fire safety requirements of the automated fire protection and suppression systems built into the battery.





Figure 1 - Proposed 38.4 ha solar farm site and surrounding farm area (note the project will comprise 11.6 ha within this area)



2 PROJECT DESCRIPTION

ITPD is proposing to construct a solar farm with a DC capacity of 6.4 MWp and AC output of 5 MW on an approximately 38.4 ha site that is currently used minimally for mixed cropping and grazing.

There are to be approximately 12,100 solar modules installed in 140 rows (each row being approximately 103 m long and 2 m wide) running east to west. Each row of solar photovoltaic (PV) modules will rotate to track the sun across the sky from east to west each day. There is approximately 6.25 m spacing between each row. The maximum height of each module is 2.75 m.

The solar farm will also consist of an inverter station and a containerised battery energy storage system (BESS). The inverter station incorporates the high/medium voltage switchgear and transformers two 3 MW inverter. The inverter station is ground mounted and incorporated on a 12.19 m skid.

The proposed battery is a prefabricated, off the shelf 5.7 MWh lithium-ion battery stored within two shipping containers installed adjacent to the inverter station.

The mounting system is constructed on piles that are driven into the ground. During construction there is expected to be 50 personnel on site working from 7 am - 4 pm Monday to Friday. The construction is expected to take approximately 3 months. Once operational the site will be unmanned. Maintenance is expected to be carried out quarterly by a crew of 2 – 3 people.

Solar panels and related infrastructure will be decommissioned and removed upon cessation of operations. This is likely to occur within two years of the end of the project. The site will be returned to the pre-development land use of agriculture.



3 LEGISLATIVE CONTEXT

3.1 Boorowa Local Environmental Plan 2012

The Boorowa Local Environmental Plan 2012 aims to make local environmental planning provisions for land in Hilltops Council in accordance with the relevant standard environmental planning instrument. The Plan does not provide specific management requirements for BESS systems but rather focuses on urban planning and conflicting land use management. The Plan provides the prohibited and permitted types of development within the local area. Some types of development are also regulated by specific state environmental planning policies.

The Plan has specific requirements pertaining to earthworks undertaken to ensure the development does not have detrimental environmental impacts on the land.

3.2 State Environmental Planning Policy (Infrastructure) 2007

Division 4 of the State Environmental Planning Policy (Infrastructure) 2007 relates to 'Electricity generating works or solar energy systems'. The policy states electricity storage falls into the same category as of electricity generating works. This policy within Division 4 does not specifically state the fire design requirements of a BESS system however within Division 5 of the SEPP, electricity transmission or distribution network, some of the fire safety risks are mentioned. As well, other safety issues such as electrocution, fire risks, risks relating to voltage rises or risks to the integrity of an electricity transmission or distribution network are considered.



4 HAZARD ANALYSIS

The purpose of this analysis is to outline a hazard assessment of the proposed, nominal 5.7 MWh BESS and hazardous goods associated with the Boorowa Solar Farm project undertaken by ITPD. Although the project is not a State Significant Development, ITP Development has voluntarily undertaken a Hazard Analysis using *State Environmental Planning Policy No. 33* – *Hazardous and Offensive Development*¹ ("SEPP 33") and *Hazardous Industry Planning Advisory Paper No. 6 – Guidelines for Hazard Analysis*² as a framework, drawing on the expertise of relevant members of ITP's Engineering Division. Background information about the division is available on the ITP Renewables website³.

This hazard assessment is intended to provide further context to the Development Application for the project to Hilltops Council and the Western Regional Planning Panel.

4.1 Methodology

SEPP 33 requires a Preliminary Hazard Assessment (PHA) to be prepared for potentially hazardous or offensive development. Appendix 3 of *Hazardous and Offensive Development Application Guidelines – Applying SEPP 33*⁴ (known hereon in as "the Guidelines") lists industries that may fall within SEPP 33. However, the list in Appendix 3 does not include solar farms and energy storage facilities. In instances where the applicability of SEPP 33 is not immediately apparent, projects can be assessed through the risk screening procedure outlined in Appendix 2 of the Guidelines.

4.2 Existing Environment

Risk screening

SEPP 33 outlines the screening and risk assessment process for a potentially hazardous development. The process is outlined graphically in Figure 2. The document suggests that the potential risk of a proposed development typically depends on five main factors:

- the properties of the substance(s) being handled or stored;
- the conditions of storage or use;
- the quantity involved;
- the location with respect to the site boundary; and
- the surrounding land use.

¹ <u>State Environmental Planning Policy No. 33 – Hazardous and Offensive Development</u>

² Hazardous Industry Planning Advisory Paper No. 6 – Guidelines for Hazard Analysis

³ ITP Renewables

 ⁴ <u>Hazardous and Offensive Development Application Guidelines – Applying SEPP 33</u>
 Fire Assessment of the Boorowa 1B Solar Farm May 2021



Incorporating these factors, and following the procedure outlined in Figure 2 and detailed in the Guidelines, a risk screening analysis was completed for the Boorowa Solar project.

According to the *Australian Code for the Transport of Dangerous Goods by Road and Raif*⁶ ("ADG Code"), all dangerous goods are to be carried in a secure, safe and environmentally controlled manner. The ADG Code lists the following classes of dangerous goods:

- Class 1 Explosives
- Class 2 Gases
- Class 3 Flammable liquids
- Class 4 Flammable solids
- Class 5 Oxidising substances and organic peroxides
- Class 6 Toxic and infectious substances
- Class 7 Radioactive material
- Class 8 Corrosive substances
- Class 9 Miscellaneous dangerous substances and articles, including environmentally hazardous substances

A development which exceeds the screening thresholds identified in Appendix 4 of the Guideline would be considered potentially hazardous, and a PHA would need to be submitted with a Development Application. Where quantities of dangerous goods are below the Appendix 4 thresholds, SEPP 33 indicates that there is unlikely to be a significant off-site risk, in the absence of other risk factors.

⁵ <u>Australian Code for the Transport of Dangerous Goods by Road and Rail</u> Fire Assessment of the Boorowa 1B Solar Farm May 2021





Figure 2 - Potentially hazardous industry risk screening procedure outlined in the Applying SEPP33 Guidelines



4.3 Potential impacts

Dangerous goods on-site

The dangerous goods that would require transportation and storage during construction or operation of the Boorowa Solar site are identified in Table 1 below, detailing the ADG Code classification, the quantities and applicable thresholds. The planned storage of the dangerous goods is within the proposed Laydown Area as shown on the General Arrangement Plan⁶ submitted in the DA Drawing Pack. All dangerous goods on site will be stored at quantities that are lower than the SEPP33 thresholds.

The proposed Boorowa Solar BESS facility configuration will be of Lithium-ion technology, sourced from a tier-one international equipment manufacturer and already possess certification and compliance with applicable Australian standards, licences and codes.

The system will comprise multiple containerised systems of approximately 3MWh capacity per container, mounted on an engineered foundation and electrically connected together onsite. Each container has a fire detection and suppression system (usually inert gas or water deluge) to contain and help prevent the spread of fire.

Irrespective of the technology deployed, the BESS facility will include a series of foundations, suitably spaced for optimum operations and maintenance and separated by gravel/road-base to assist in fire management. The final decision on the preferred technology provider and detailed technology specification would be confirmed during the detailed design phase of the project, and as stated will comply with applicable Australian standards, licences and codes.

	Storage	Transport Threshold			Project	
Hazardous Material	Threshold	Movements	Quantities	Storage	Compliance	
Class 3 – Flammable liquids: Fuel (petrol)	5 tonnes	Approx. 50/week	3-5 tonnes	Stored in tanks on the site service vehicles and would not be stored at quantities greater than the storage or transport thresholds.	Yes, final quantity to be determined during detailed design but will not exceed storage or transport thresholds.	
Class 6.1 – Toxic Substances Pesticides (herbicides)	2.5 tonnes	All	1-3 tonnes	Stored at the laydown area (refer General Arrangement Plan) in appropriately bunded area designed in accordance with AS1940-2004.	Yes, final quantity to be determined during detailed design but will not exceed thresholds.	

Table 1 - List of hazardous materials on site, quantities and screening thresholds

⁶ Drawing No. **BOO1B-G-2100**

Fire Assessment of the Boorowa 1B Solar Farm May 2021



Class 9 – Miscellaneous dangerous substances and articles Li-ion batteries certified to UN 34.80	No storage threshold listed (UN Code 3480)	No limit (for Boorowa project, an estimated 5 deliveries are anticipated)	No limit (for Boorowa project, an estimated 1MW batteries per delivery)	Batteries will be stored within the BESS Station compound.	Yes, no threshold applies.
---	---	--	--	--	-------------------------------

Summary of screening method

The SEPP 33 screening process does not specify a screening threshold for ADG Code Class 9 materials (Miscellaneous Hazardous material). As Lithium-Ion batteries are categorised as Class 9 goods, a PHA is not triggered based solely on the screening threshold.

The SEPP 33 documentation states that the hazardous materials screening method applied in Table 2 will not be considered in isolation when determining whether an industry is considered potentially hazardous and would therefore require a PHA to be carried out. The SEPP33 documentation refers to 'other factors'.

Whilst what is included as 'other factors' is not specifically defined. However, examples are given indicating that it must include issues such as the risk to people, property or environment if two hazardous goods were to combine, even if the quantities of both were below the threshold. This is something that is not captured in the ADG code.

Taking a precautionary approach, other factors that may warrant consideration in the screening process to determine whether the proposed lithium-ion batteries could be considered potentially hazardous are described in Table 2 and an assessment of the risk of the Boorowa project is provided.

Гable 2 - Othe	r factors	assessment for	the	OCEP	proj	iect

Other factors	Assessment of risk for OCEP Project
The inherent risk of fire when storing large volumes of electro- chemical energy on site. These risks can and would be mitigated, but without control systems in place the risk could be significant.	The cubicle or container type of BESS facility as described above limits the potential risk of this factor, given the system will have fire mitigation controls.
The possibility of a cascading failure involving the battery system. This could be in the form of an externally initiated bushfire or electrical surge.	It is envisaged that the nature of the battery design with sufficient separation distance and fire mitigations would manage any potential risk should a bushfire or electrical surge occur. The batteries are designed to contain or suppress fire within each individual cubicle or container as appropriate and are not anticipated to spread to other parts of the system.

Results of screening method

As a result of numerous factors, including the preliminary screening, it is considered that a PHA is not required for dangerous goods to be stored on the Boorowa site. However, in the interests of adopting a conservative approach, a number of management measures have been recommended to be implemented at the Boorowa site, as described in Section **Error! Reference source not found.** below.

4.4 Management and mitigation

The risk of potentially hazardous materials will be addressed through the management and mitigation measures presented in Table 3. These high-level measures will form the basis for a construction environmental management plan, which will be developed and implemented by the contractors engaged for the Engineering, Procurement and Construction (EPC) phase of the project.

A decommissioning plan will also be developed prior to the construction phase, in order to ensure that any hazardous material is removed from the site and disposed of appropriately at the end of the operational life of the project.

No.	Safeguard and mitigation measures
HM1	 The Boorowa site would manage the fire risks associated with the BESS by: Installing reliable, automated monitoring and control systems, with an alarm and shutdown response capability. Taking reasonable and safe measures to prevent the risks of external heat effects in the event of a bushfire. Designing appropriate separation and isolation between battery cubicles, and between the BESS and other infrastructure, in accordance with the manufacturers' recommendations, and including gravel set-off areas around the facility. Compliance with all applicable Australian codes and standards. Preparation of a BESS-specific fire response plan, in conjunction with the NSW Rural Fire Service.

Table 3 - Recommended mitigation measures for potential hazardous materials risks



	 Installing an adequate automatic fire suppression system integrated into the detection and control system. Disposal (and where possible, recycling) of any potentially hazardous material in accordance with the best international practices available at that time.
HM2	Fuels and pesticides/herbicides in use at the site will be stored at the laydown area in appropriately bunded areas designed in accordance with AS1940-2004.



5 PROJECT DESIGN

The proposed solar farm at Boorowa incorporates a number of fire safety in design principles embedded into a number of aspects such as the:

- Project layout and location
- Inverter and battery station arrangement
- Material/equipment selected and onboard technology
- Installation
- Operation and maintenance of hazardous material

Each of the above criteria will be detailed within this report considering strategy, implementation and compliance in terms of fire safety effectiveness.

5.1 **Project Layout and Location**

As illustrated in Figure 3, NSW Rural Fire Service data does not declare the proposed solar farm to be located in a bushfire prone area. However, precautions are still built into the design of the project exceeding what is ordinarily required.



Figure 3 - NSW RFS Search

The layout of the solar array is proposed to include an Asset Protection Zone (APZ) surrounding the entire site with a 10m setback from a non-combustible chain-link fence. The APZ will not be located on land exceeding a slope of 18 degrees. This 10m APZ is also



intended to act as a defendable space and a buffer against radiant heat effects for emergency services.



Figure 4 illustrates the APZ encompassing the project site. A landscape vegetation screening corridor is adjacent to this fence and is setback a minimum of 10m from the solar array.

Furthermore, a minimum 10m APZ shall be established around the battery station (which includes the cubicles, switching station and associated structures of the BESS) and other infrastructure including gravel off-set areas. Road access to the site and fencing are excluded from the APZ. Internal curves of the APZ and inner protection area (IPA) are designed with minimum 6m radius turning circles to assist in vehicle access. As well, the vertical clearance above the APZ/IPA exceed 6m in height.



Figure 4 - Boorowa General Arrangement with the APZ in Highlight

There will be no infrastructure within the APZ. The ongoing maintenance of APZs are recognised under 100C of the *Rural Fires Act* 1997 and supported by 2.8(1)(d) of the



Biodiversity Conservation Act 2016. Any clearing of vegetation within the site to allow the development to occur may require assessment under the *Biodiversity Conservation Act* 2016.

At the commencement of building works and for the life of the development, a 10m APZ around the solar panels, BESS station and other infrastructure shall be managed as an IPA, in accordance with Appendix 4 of Planning for Bushfire Protection 2019 and NSW Rural Fire Service 'Standards for Asset Protection Zones'.

The presence and ongoing maintenance of the APZ assists in lowering the impact of direct flame contact and spread, as well as radiant heat effects on the development.

5.2 Inverter and Battery Station Arrangement

Figure 5 illustrates the indicative layout plan for the battery station, which is comprised of two 40-foot containers housing the battery cells, and a switchgear station in the centre.

Similarly, it is intended a 10m APZ will surround the inverter station and battery station/electrical kiosk to act as a defendable area and buffer against heat effects between the equipment and solar array.



Figure 5 - BESS Infrastructure Setout with APZ in Highlight

Wood piles, wooden sheds, combustible material storage areas, large areas/quantities of garden mulch and stacked flammable building materials are not proposed as part of this development.

5.3 Material/Equipment Selected and Onboard Technology

The proposed solar farm is comprised of equipment, plant and material designed to be installed outdoors in the elements to suit a variety of environmental challenges and operate continuously for over 40 years.



The solar arrays are connected to the inverter station which contains comprehensive remote monitoring and automatic protection systems that operate 24x7 with dual redundant back to base alarm systems to advise of any faults and issues. The system is also designed with onboard sensors and fail-safes that are pre-programmed to trip the generating plant, isolating it from the grid should any operating parameters fall outside of the normal range.

The generating plant also features 24x7 constant isolation resistance monitoring which electronically checks the integrity of all the cabling within the arrays against the environment, air and moisture, including those underground. This provides an early warning measure for issues such as earth faults which could potentially lead to a fire. In the event of fault alarms, the system's internal fail-safes will activate, isolating the system from the grid and the system will not operate until the fault is acknowledged and cleared. The isolating procedure will ensure any faults that may develop remain local and do not spread.

These fail safe and safety systems provide a very early warning system of issues and automatically puts into process safety systems to prevent uncontrolled outbreaks of hazards such as electricity disturbances on the grid or localised issues such as fire.

The solar array tracking system is based on self-powered motors energised by internal batteries and charged by individual and independent solar panels, not requiring a grid connected power supply. The system operates on 24V DC which is regarded as extra low voltage (ELV), a comparable voltage to small domestic technology products such as laptops. The ELV component ensures the voltages involved are not hazardous should issues develop. The design of the piling system ensures the entire array is self-grounding.

As a last line of defence, the generation system features its own circuit breakers which can trip in the event of overcurrent. The distribution network service provider (DNSP) at Boorowa, Essential Energy, also has remote access and trip authorisation via SCADA controls to the plant with inhibit rights, which prevents the plant from re-energising the grid without a physical confirmation from the owner to the Essential Energy control room.

The BESS system contains a self-integrated automated fire detection and suppression system to guard against an unlikely event of a fire. Common systems include Novec 1230 Fire Fighting (Suppression) System (FFS) with IEC, ISO and NFPA 2001 certifications that are located inside the battery container and integrated into the solar system's monitoring systems. The FFS includes smoke detectors, temperature detectors, alarm devices and gas release devices.

The system operates through the use of clean fire suppression gas. Before the gas blowout action, the fire system controller will issue a signal to the HVAC main power switch to stop operating, also powering down the fans and thus achieving a self-containing fire suppression process upon the release of the gas.

Compliance of the off the shelf BESS system is achieved with AS 4214-2002 Gaseous fire extinguishing systems and the appropriate sections in AS1670.1-2018 Fire detection, warning,



control, and intercom systems. Certificates and Schedules of conformity for the FSS are also available.

5.4 Installation

The solar farm is comprised of ready made off the shelf components that meet Australian standards and are certified for use in Australia.

The installation and construction process will involve minimal hot works, with the exception of the use of hand-held power tools and a drop saw for cutting excess metal off.

The solar arrays are constructed using prefabricated components and nuts, bolts and screw fixings which are installed with battery powered drivers and wrenches. The solar piling is a dry percussion process in which there are no heat procedures/hot works other than the piling and excavator rigs which are diesel powered.

The inverters, switchgear, BESS and transformer skids are all prefabricated components that arrive from overseas in containers which are craned into position on site and electrically connected.

The main sources of fire ignition during the construction will be localised to a cutting station to be setup in a controlled environment where excess metal cutting/grinding can take place equipped with hand-held fire extinguishers and fire blankets. Works also subject to any total fire bans which may be in place and to be integrated into safety procedures in safe work method statements (SWMS), job hazard analysis (JHA) and construction environmental management plans (CEMPs).

5.5 Bushfire Assessment

Although there are similar design aspects, this fire assessment does not assess the design criteria requirements against the effects of a bushfire. An important fact to note is the Boorowa RFS is located 3.5 km from the site (an approximately 5-minute drive). As well, the Boorowa Fire and Rescue Station is situate 3.3 km north of the site (4-minute drive).



6 SUMMARY

The proposed solar project with BESS integration is an emerging form of renewable energy infrastructure in NSW that has an associated set of fire safety requirements.

As detailed within this report, the Boorowa solar farm with battery storage can be made safer through the integration of safety in design principles from the bushfire standards including APZ clearances, internal protection areas, comprehensive system fault monitoring, automated fire detection and suppression systems and safety procedures built into WHS policies and procedures to ensure these farm assets and the surrounding area is protected from the risk of fire.



7 **REFERENCES**

Boorowa Local Environmental Plan 2012. Accessed 5 February 2021 https://legacy.legislation.nsw.gov.au/~/pdf/view/epi/2012/252/whole.

Department of Industry, Resources and Energy NSW (2016) Fact Sheet: Solar farms in NSW.

- NSW Rural Fire Service (2018). Planning for Bushfire Protection A Guide for Councils, Planners, Fire Authorities, Developers and Home Owners, NSW Rural Fire Service.
- NSW Rural Fire Service (2019). Planning for Bush Fire Protection. Available online https://www.rfs.nsw.gov.au/__data/assets/pdf_file/0005/130667/Planning-for-Bush-Fire-Protection-2019.pdf.
- NSW Rural Fire Service (2005). Standards for Asset Protection Zones. NSW Rural Fire Service, Sydney.

Sungrow 2021. Technical Specification BESS not published.



ITP Development Pty Ltd ABN 38 633 420 309

Office: Level 1, 19-23 Moore St Turner ACT 2612

Postal: PO Box 6127 O'Connor ACT 2602 Australia

Email: info@itpau.com.au Phone: +61 (0) 2 6257 3511

itpau.com.au