

Illoura Place, 28 Elizabeth St,
Liverpool

Hydraulics & Electrical

Services Infrastructure Report_DA submission

Prepared for: Altis Bulky Retail Pty Ltd ATF Trustee for Altis ARET Sub Trust 20 (Altis)

Attention: Nick Murdoch

Date: 29 October 2021

Prepared by: Antonio Lo Monte

Ref: 301350263

Stantec Australia Pty Ltd

Level 6, Building B, 207 Pacific Highway, St Leonards NSW 2065

Tel: +61 2 8484 7000 Web: www.stantec.com

P:\301350263\BRIEFEL_HY-001_EXISTING SERVICES REPORT_V2.DOCX

Revision

Revision	Date	Comment	Prepared By	Approved By
001	5.10.21	Pre-DA Issue	ALM	ALM
002	29.10.21	Pre-DA Issue	ALM	ALM

Contents

1.	Introduction	1
	Electrical Services	2
1.1	Existing Electrical Infrastructure	2
1.2	Proposed Supply Infrastructure	3
1.3	Proposed Communications Infrastructure	4
2.	Hydraulic Services	6
2.1	Site Infrastructure Services	6
3.	Appendix 1 - Endeavour Energy Substation	9
4.	Appendix 2 – Sydney Water Pressure and Flow	11

1. Introduction

28 Elizabeth Street, Liverpool, known as Illoura Place is being developed by Altis Bulky Retail Pty Ltd ATF Trustee for Altis ARET Sub Trust 20 (Altis).

As an overview, the Project consists of the following:

Site area	3,609m ²
Proposed GFA	36,000m ²
Building Height	~128m
Stories	33 Stories
Residential Units	312 Units
Parking	411 Residential 100 commercial 31 Retail 65 Com bicycle 312 Res Bicycle 29 Motorcycle

This document outlines the existing services available to the site and the proposed engineering allowances and checks that have been allowed.

This information contained within this report has been based on the following documents received to date:

- Client documents
- Turner Architectural documents
- Multiple design meetings and client discussion and coordination
- NCC 2019 Amendment 1
- Relevant codes and design standards for electrical, fire, hydraulic and mechanical services
- DBYD Existing Services
- Preliminary Services Calculations




Electrical Services

1.1 Existing Electrical Infrastructure

1.1.1 Power

The Supply Authority for the site is Endeavour Energy.

A search on DBYD indicates that the site does not currently contain any substations, and that a substation is located adjacent within site 26 Elizabeth Street, however Google maps indicates that the entire block is demolished.



Endeavour Energy DBYD showing substation is adjacent site



Google Streetview showing that the existing block has been demolished.

1.1.2 Communications

A search on DBYD indicates that the site currently has various pit and pipe infrastructure servicing communication to the site, however these existing services will be removed as part of the demolition/basement excavation for the new development.



The max demand of the project assumes the following:

- Electrical Cooktop & HWU
- Limited to 600A for EV charging provision and on load management control
- Retail 400VA/m² (food and beverage) - subject to confirmation from Altis / Murdoch
- Commercial 100VA/m² - subject to final system selection and design, to be confirmed further as design progresses
- Total Mech loads: TBC - to be confirmed further as design progresses
- Total Hyd loads: TBC - to be confirmed further as design progresses
- Total Fire loads: TBC - to be confirmed further as design progresses


In order to service the expected max demand 3 off 1500kVA transformers are required and located within chamber substations around the site. In order to cater for future flexibility in supply and overcome any potential power restrictions on the site, we understand that the preference is to allow space for 4 transformer substations.

Refer to Appendix A for Endeavour Energy drawing showing the chamber substations. The final design/requirements of the substation shall be advised by the Level 3 ASP designer.

1.3 Proposed Communications Infrastructure

A check on the NBNco website has confirmed that NBN infrastructure has been rolled out in the area, and that the technology being used will likely be Fibre-To-The-Premises (ie. fibre will be provided to each tenant/apartment).

This is subject to approval following the NBN Application process.



An application to NBN will be made in due course.

Specific requirements for the provision of NBN fibre to the new development are outlined in the NBN Building Design Guide – New Developments document. We have summarised these requirements below however the reader shall refer to the NBN document for specific requirements regarding the NBN installation.

Client shall confirm if NBN is the preferred communication provider or an alternative Integrated Communications Network Provider (eg Opticomm, LBNCo etc)

1.3.1 Lead-in Fibre

Similar to the new consumers mains, new lead-in NBN / other fibre operator fibre shall enter the new development at basement level from the streets from 2 locations (1 from Elizabeth Street and 1 from George Street) as a grade A office building requirement. The lead-in fibre cable shall be reticulated to the Main Comms Room via a P100 lead-in telecommunications conduit laid on new cable tray/duct to the Main Comms Room as required. The telecommunications



conduit shall run to the nearest NBN/Telstra pit in the road reserve and stop inside the private property with a marker to indicate the location.

NOTE: the lead-in pit location is required to be confirmed as part of the detailed design phase



2. Hydraulic Services

2.1 Site Infrastructure Services

2.1.1 Sewer Services

There is currently a 300mm vitreous clay sewer servicing the site we will be connecting to this sewer connections

The 300mm sewer main traversing through the site will be classified as 'Asset Affected' by Sydney Water as it is passing through the building footprint and excavation zone. A WSC is engaged to design the deviation around the site and as part of that design a sewer connection will be provided for connection to our internal sewer reticulation in the south east corner of the site. See Image 1

We anticipate the site will utilise 2x225mm connections, final locations and details to be determined in liaison with Sydney Water. The suitability of these connections will be validated by Sydney Water within the Notice of Requirements (NoR).




Image 1: Sewer intruding on site boundary: Source: DBYD



- A 150mm combined potable and fire connection will be main into the water 300mm water main located within Elizabeth St. The connection will be a new connection at the corner of Elizabeth and George Street to the proposed master water meter and fire hydrant booster assembly. See image 2.
- An RPZD (Reduced Pressure Zone Device) backflow prevention device will be required on the new incoming supply. Supplementary backflow prevention devices – RPZD's are to be provided in accordance with AS3500.1 requirements including hair dressing salon and dirty utility areas.
- Final connection details to be co-ordinated as apart of Section 73 process with Sydney Water



2.1.3 Gas Services

There is a 75dia, 7kPa network main owned and operated by Jemena within Elizabeth St. Current discussions with Jemena. A formal enquiry to Jemena has determined that there is no capacity to extend gas through to the building services, gas supply will be supplied to the retail tenancies only will be provided.




Image 3: Available gas main: Source: DBYD

3. Appendix 1 - Endeavour Energy Substation




Figure 1:
Three (3) transformer substation




Figure 2:
Four (4) transformer substation




Figure 3 :
Two (2) transformer substation

Typical sizes for transformers and HV switchgear in one (1) room			
No. of transformers	Minimum internal room size, mm (approx.)		
	Width	Depth	Height
1	5700	4600	2700
2	6000	7600	2700
3 (Dry only)	8500	7600	2700
4 (Dry only)	11000	7600	2700



4. Appendix 2 – Sydney Water Pressure and Flow



Statement of Available Pressure and Flow

Catherine Jones
207 Pacific Highway
St Leonards, 2065

Attention: Catherine Jones

Date: 26/04/2021

Pressure & Flow Application Number: 1094131
Your Pressure Inquiry Dated: 2021-03-19
Property Address: Elizabeth Street, Liverpool 2170

The expected maximum and minimum pressures available in the water main given below relate to modelled existing demand conditions, either with or without extra flows for emergency fire fighting, and are not to be construed as availability for normal domestic supply for any proposed development.

ASSUMED CONNECTION DETAILS

Street Name: Elizabeth Street	Side of Street: South
Distance & Direction from Nearest Cross Street	20 metres East from George Street
Approximate Ground Level (AHD):	14 metres
Nominal Size of Water Main (DN):	150 mm

EXPECTED WATER MAIN PRESSURES AT CONNECTION POINT

Normal Supply Conditions	
Maximum Pressure	51 metre head
Minimum Pressure	39 metre head

WITH PROPERTY FIRE PREVENTION SYSTEM DEMANDS	Flow l/s	Pressure head m
Fire Hose Reel Installations (Two hose reels simultaneously)	0.66	39
Fire Hydrant / Sprinkler Installations (Pressure expected to be maintained for 95% of the time)	5	41
	10	41
	15	41
	20	40
	26	40
	30	40
	40	39
	50	38
Fire Installations based on peak demand (Pressure expected to be maintained with flows combined with peak demand in the water main)	5	39
	10	39
	15	39
	20	39
	26	38
	30	38
	40	37
	50	36
Maximum Permissible Flow	67	34

(Please refer to reverse side for Notes)

For any further inquiries regarding this application please email :

swtapin@sydneywater.com.au

Sydney Water Corporation ABN 49 776 225 038
1 Smith St Parramatta 2150 | PO Box 399 Parramatta 2124 | DX 14 Sydney | T 13 20 92 | www.sydneywater.com.au
Delivering essential and sustainable water services for the benefit of the community



Design with
community in mind

Level 6, Building B
207 Pacific Highway
St Leonards NSW 2065
Tel +61 2 8484 7000

For more information please visit
www.stantec.com

