

# Referral Response - Building Surveying

<b>Application Number:</b>	Rev23/0008
<b>Referral Officer</b>	Drago Vrh
<b>Referral Unit</b>	Building Surveying
<b>Date of referral</b>	12 February 2024
<b>Land to be developed (Address):</b>	Lot 3003 DP 1184498 184 Lord Sheffield Circuit PENRITH NSW 2750
<b>Proposed Development:</b>	Review of Determination (Refusal) of DA22/0214 for Construction of Part 13 and Part 25 Storey Mixed Use Development, One Level of Basement Car Parking, Five Storey Podium with Above-Ground Parking, Retail and Commercial Tenancies and Two Residential Towers. Tower C has 74 Apartments and Tower D has 163 Apartments. Proposal includes an Offer for Community Infrastructure for Further Embellishment Works to Proposed Through-Site Link (Concurrent Review Application Rev23/0007 for DA22/0213).

## Recommendation

No objections - subject to conditions

## Detailed assessment

Rev 23/0008 has been submitted in relation to the previous DA22/0214 determination.

No record of any previous building comments/conditions could be found. In this case building conditions will be provided for this revision request.

A BCA report has been provided stating that a "Performance Solution" will be formulated for some non-compliant deemed to satisfy requirements. The PCA will need to assess the solution prior to the issue of a OC.

No objection is raised to the application subject to the recommended building conditions being included should consent be granted.

Yours sincerely,

Name Drago Vrh

**Position Building Surveyor**

## Recommended Conditions:

### General

- 1 The development shall not be used or occupied until an Occupation Certificate has been issued.
- 2 A Construction Certificate shall be obtained prior to commencement of any building works.

### BCA Issues

- 3 All aspects of the building design shall comply with the applicable performance requirements of the Building Code of Australia so as to achieve and maintain acceptable standards of structural sufficiency, safety (including fire safety), health and amenity for the on-going benefit of the community. Compliance with the performance requirements can only be achieved by:
- (a) complying with the deemed to satisfy provisions, or
  - (b) formulating an alternative solution which:
    - complies with the performance requirements, or
    - is shown to be at least equivalent to the deemed to satisfy provision, or
  - (c) a combination of (a) and (b).

It is the owner's responsibility to place on display, in a prominent position within the building at all times, a copy of the latest fire safety schedule and fire safety certificate/ statement for the building.

## Construction

- 4 Stamped plans, specifications, a copy of the development consent, the Construction Certificate and any other Certificates to be relied upon shall be available on site at all times during construction.

The following details are to be displayed in a maximum of 2 signs to be erected on the site:

- the name of the Principal Certifying Authority, their address and telephone number,
- the name of the person in charge of the work site and telephone number at which that person may be contacted during work hours,
- that unauthorised entry to the work site is prohibited,
- the designated waste storage area must be covered when the site is unattended, and
- all sediment and erosion control measures shall be fully maintained until completion of the construction phase.

Signage but no more than 2 signs stating the above details are to be erected:

- at the commencement of, and for the full length of the, construction works onsite, and
- in a prominent position on the work site and in a manner that can be easily read by pedestrian traffic.

All construction signage is to be removed when the Occupation Certificate has been issued for the development.

- 5 Prior to the commencement of construction works:

(a) Toilet facilities at or in the vicinity of the work site shall be provided at the rate of one toilet for every 20 persons or part of 20 persons employed at the site. Each toilet provided must be:

- a standard flushing toilet connected to a public sewer, or
- if that is not practicable, an accredited sewage management facility approved by the council, or
- alternatively, any other sewage management facility approved by council.

(b) All excavations and back filling associated with the erection or demolition of a building must be executed safely and in accordance with the appropriate professional standards. All excavations associated with the erection or demolition of a building must be properly guarded and protected to prevent them from being dangerous to life or property.

(c) If an excavation associated with the erection or demolition of a building extends below the level of the base of the footings of a building on an adjoining allotment of land, the person causing the excavation to be made:

- must preserve and protect the building from damage, and
- if necessary, must underpin and support the building in an approved manner, and
- must, at least 7 days before excavating below the level of the base of the footings of a building on an adjoining allotment of land, give notice of intention to do so to the owner of the adjoining allotment of land and furnish particulars of the excavation to the owner of the building being erected or demolished. The owner of the adjoining allotment of land is not liable for any part of the cost of work carried out for the purposes of this condition, whether carried out on the allotment of land being excavated or on the adjoining allotment of land, (includes a public road and any other public place).

(d) If the work involved in the erection or demolition of a building is likely to cause pedestrian or vehicular traffic in a public place to be obstructed or rendered inconvenient, or involves the enclosure of a public place, a hoarding or fence must be erected between the work site and the public place:

- if necessary, an awning is to be erected, sufficient to prevent any substance from, or in connection with, the work falling into the public place,
- the work site must be kept lit between sunset and sunrise if it is likely to be hazardous to persons in the public place, and
- any such hoarding, fence or awning is to be removed when the work has been completed.

## Certification

- 6 Prior to the commencement of any earthworks or construction works on site, the proponent is to:
- (a) employ a Principal Certifying Authority to oversee that the said works carried out on the site are in accordance with the development consent and related Construction Certificate issued for the approved development, and with the relevant provisions of the Environmental Planning and Assessment Act and accompanying Regulation, and
  - (b) submit a Notice of Commencement to Penrith City Council.

The Principal Certifier shall submit to Council an "Appointment of Principal Certifying Authority" in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.

### Information to accompany the Notice of Commencement

Two (2) days before any earthworks or construction/demolition works are to commence on site (including the clearing site vegetation), the proponent shall submit a "Notice of Commencement" to Council in accordance with Section 81A of the Environmental Planning and Assessment Act 1979.