



## NSW RURAL FIRE SERVICE

Carrathool Shire Council  
PO Box 12  
GOOLGOWI NSW 2652

Your reference: DA2022/029 (EAR 1353)  
Our reference: DA-2019-02007-EIS & DA  
Exhibition-1

**ATTENTION:** Leigh Jackson

Date: Friday 15 July 2022

Dear Sir/Madam,

**Development Application**

**Other - Part3A - (none)**

**Extractive Industry - 439 WILTSHIRE RD RANKINS SPRINGS NSW 2669, 1//DP821515**

I refer to your correspondence regarding the above proposal which was received by the NSW Rural Fire Service on 06/04/2022.

The NSW RFS has considered the information submitted and raises no objection to the proposed Extractive Industry 'Western Riverina Quarry', subject to development consent including a condition to ensure compliance with the bush fire management and mitigation measures listed in sections 5.9.2.3, 5.9.2.4 and Table 5.22 of the Environmental Impact Statement (EIS) prepared by RW Corkery & Co P/L dated February 2022 and the following:

- Asset Protection Zones in accordance with Table 5.22 of the EIS and Appendix 4 of *Planning for Bush Fire Protection 2019* are provided around built asset within the Ancillary Components Area.
- Proposed access roads around the perimeter of the site shall be suitable for a Category 1 fire fighting vehicle.
- On site water for fire fighting shall be a minimum 20,000L.

For any queries regarding this correspondence, please contact Anna Jones on 1300 NSW RFS.

Yours sincerely,

James Killen  
**Manager Planning & Environment Services**  
**Built & Natural Environment**

**Postal address**

NSW Rural Fire Service  
Locked Bag 17  
GRANVILLE NSW 2142

**Street address**

NSW Rural Fire Service  
4 Murray Rose Ave  
SYDNEY OLYMPIC PARK NSW 2127

**T** (02) 8741 5555  
**F** (02) 8741 5550  
[www.rfs.nsw.gov.au](http://www.rfs.nsw.gov.au)