



NOTES

1. ACTUAL DIMENSIONS AND CLEARANCES MAY VARY SUBJECT TO SITE CONDITIONS.
2. DIMENSIONS OF ELECTRICAL EQUIPMENT ARE INDICATIVE ONLY. ACTUAL DIMENSIONS TO BE CONFIRMED.
3. LOCATION OF ESSENTIAL ENERGY 33kV OVERHEAD LINE AND SYSTEM CONNECTION POINT TO BE CONFIRMED.
4. EXISTING ESSENTIAL ENERGY 33kV POLE IS FOR ILLUSTRATION ONLY. ACTUAL POSITION IS SUBJECT TO THE ACTUAL MEASUREMENT ON SITE.
5. SITE STORAGE AND AMENITY FACILITIES TO BE ON SITE ONLY DURING CONSTRUCTION PHASE. NO PERMANENT BUILDINGS TO BE KEPT ON SITE AFTER CONSTRUCTION COMPLETED.
6. FENCE HEIGHT WITHIN EASEMENT TO BE CONFIRMED PER ESSENTIAL ENERGY REQUIREMENT.
7. FINAL LANDSCAPING POSITIONS TO BE CONFIRMED ON SITE.

LEGEND

-  PROPOSED PV ARRAY
 SECURITY FENCE
 PROPERTY BOUNDARY
 EXISTING UNDERGROUND CABLE
 33kV ESSENTIAL ENERGY POWER LINE WITH EASEMENT

SYSTEM SPECIFICATIONS				
MODULE CAPACITY	550	W	MODULE MODEL	LR5-72HPH-550M
INVERTER MODEL	SMA-SC2660 UP	-	NO. OF INVERTERS	2
DC CAPACITY	6.42	MW	NO. OF STRINGS	432
NO. OF MODULES PER STRING	27	-	TOTAL MODULES	11664

FOR INFORMATION

[illegible]

19 MURRY STREET, HAY, NSW 2711
5.04 MVA PV EXPORT SYSTEM
SITE PLAN

DATE:08/05/23	DRN: MG	CHK: ACE	ENG: MG	Q.A: ACE	SCALE: 1:1500
PROJ No NSW-02	DRG No				REV D