



Australian Government
Civil Aviation Safety Authority

Air Navigation, Airspace and Aerodromes

File Ref: F20/7984-26
Your Ref: Email 22/12/2020

13/01/2021

Mr David Binskin
Bankstown Airport
Sydney Metro Airports
PO Box 6450
WETHERILL PARK DC 1851
By Email

Dear Mr Binskin,

**PROPERTY BUILDING DEVELOPMENT
48-50 WELLINGTON ROAD CHESTER HILL**

I refer to the request for advice from CASA under the Airports (Protection of Airspace) Regulations 1996 regarding the above proposal.

CASA has assessed the proposed 5 storey apartment building at 48-50 Wellington Rd Chester Hill, NSW.

The height of the proposed building is 52.7 m above AHD or approximately 18 m Above Ground Level. At this height, the proposed building will not infringe the conical surface.

CASA has determined that the building will not be a hazardous object under the regulation 139.180 of the Civil Aviation Safety Regulations 1998.

CASA is not recommending obstacle marking or lighting in this instance.

Yours sincerely,

A handwritten signature in black ink that reads 'David Alder'.

David Alder
Aerodrome Engineer